



Assest Number	A00755		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.4	17.0	8.5
X5	5.2	5.1	5.3
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00771		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	18.3	17.1	17.6
X5	6.2	5.1	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A07762		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.6	17.2	17.4
X5	5.4	5.2	5.5
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00767		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.6	17.3	17.8
X5	5.4	5.4	5.5
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00763		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.3	17.9	17.1
X5	5.2	5.2	5.0
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00800		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.9	17.0	17.3
X5	5.3	5.3	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00758		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.5	17.5	17.8
X5	5.4	5.2	5.8
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00759		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.1	17.1	17.4
X5	5.2	5.2	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00796		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.1	17.4	16.9
X5	5.2	5.0	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00809		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	18.1	16.9	17.4
X5	5.9	5.2	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00766		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.0	17.4	17.4
X5	5.0	5.4	5.2
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	A00770		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.2	17.6	17.4
X5	5.2	5.7	5.3
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	16998		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.9	17.3	6.7
X5	5.0	4.9	4.8
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30

Assest Number	19723		Date: 8th February 2023
Distro Type	MD11		
Visual	1	2	3
Insulation Resistance	✓	✓	✓
E - L1	>200	N/A	N/A
E - L2	N/A	>200	>200
E - L3	N/A	N/A	N/A
E - N	>200	>200	>200
N - L1	>200	N/A	N/A
N - L2	N/A	>200	>200
N - L3	N/A	N/A	N/A
L1 - L2	N/A	N/A	N/A
L1 - L3	N/A	N/A	N/A
L2 - L3	N/A	N/A	N/A
Earth Impedance			
L1	0.0	N/A	N/A
L2	N/A	0.0	0.0
L3	N/A	N/A	N/A
N	0.0	0.0	0.0
E	0.0	0.0	0.0
RCD			
1/2	>300	>300	>300
X1	17.8	16.9	FAIL
X5	5.5	4.9	FAIL
Size	16	16	16
Type	C	C	C
RCD Setting	30	30	30