



FIRE PROTECTION LEGEND

F	-FIRE PROTECTION PIPING
⊙	-RECESSED PENDANT SPRINKLER HEAD FOR AREAS WITH FINISHED TILED CEILING
◀	-DRY SIDE WALL, HIGH TEMPERATURE SPRINKLER HEAD, DISPLAT ROOMS.
○	- UPRIGHT SPRINKLER HEAD
●	-CONCEALED PLATE SPRINKLER HEAD (IN AREAS WITH GYPSBOARD CEILING)
⊙	-UPRIGHT SPRINKLER HEAD WITH PROTECTIVE CAGE (IN GOLF FITTING CENTER)
⌘	-DRY/ANTI-FREEZE CONCEALED PLATE SPRINKLER HEAD
X	-EXISTING TO REMAIN

HEAD TYPE	AREA
RECESSED PENDANT	AREAS WITH FINISHED TILED CEILING
UPRIGHT	EXPOSED AREAS
CONCEALED	SHEETROCK AND GYPSER VAULTED CEILING

FIRE PROTECTION NOTES:

A. MODIFY EXISTING FIRE PROTECTION SYSTEM AS REQUIRED FOR NEW CEILING AND PARTITIONS. FIRE PROTECTION CONTRACTOR SHALL PROVIDE NEW HEADS, PIPING, ETC., AS REQUIRED TO PROVIDE A CODE COMPLIANT SPRINKLER SYSTEM. CONTRACTOR SHALL VISIT SITE AND FIELD VERIFY EXISTING CONDITIONS PRIOR TO START OF ANY WORK.

B. FIRE PROTECTION SYSTEM SHALL BE AN EXISTING WET SPRINKLER SYSTEM AND SHALL BE DESIGNED PER THE LATEST EDITION OF NFPA 13, FM AND ALL LOCAL AND STATE FIRE CODES.

C. REFER TO SPECIFICATIONS FOR HAZARD CLASSIFICATION AND ALL DESIGN DETAILS.

D. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION ON SPRINKLER HEADS.

E. A MINIMUM 8" CLEARANCE SHALL BE PROVIDED FROM THE BOTTOM OF THE SPRINKLER PIPING TO THE SUSPENDED CEILING.

F. PROVIDE AN INSPECTOR'S TEST CONNECTION WITH DRAINS LOCATED TO THE EXTERIOR OF THE BUILDING OR INTO SANITARY DRAINS OF ADEQUATE SIZE TO PERMIT FULL FLOW DRAIN TESTS.

G. NEW SPRINKLER PIPING TO BE INSTALLED WITHIN BAR JOISTS WITH MAINS INSTALLED TIGHT TO BOTTOM OF JOISTS. FIT ALL PIPING FOR PROPER DRAINAGE.

H. FIRE EXTINGUISHERS SHALL BE AS SPECIFIED AND TO BE SET WITH WALL BRACKET. NUMBER AND LOCATIONS OF EXTINGUISHERS TO BE AS DIRECTED BY LOCAL FIRE MARSHAL. REFER TO ARCHITECTURAL PLANS FOR ADDITIONAL INFORMATION.

I. ALL SPRINKLER PIPING AND HEADS SHALL BE INSTALLED TO PERMIT THE INSTALLATION OF ALL MECHANICAL AND ELECTRICAL SYSTEMS. SPRINKLER CONTRACTOR SHALL RELOCATE PIPING AND HEADS IF REQUIRED TO ACCOMMODATE MECHANICAL AND ELECTRICAL SYSTEMS.

J. NO WET SPRINKLER PIPING SHALL BE INSTALLED AT LOCATIONS SUBJECT TO FREEZING. PROVIDE ANTIFREEZE SYSTEM DRY PIPE SYSTEM FOR AREAS NOTED; VESTIBULES, DISPLAY WINDOWS OR ANY SPACE EXTERIOR OR NOT CLIMATE CONTROLLED.

K. THIS DRAWING IS INTENDED TO PROVIDE GENERAL LOCATIONS AND TYPES OF SPRINKLER HEADS NOT ALL SPRINKLER HEADS ARE INDICATED ON THE DRAWING. SPRINKLER CONTRACTOR SHALL PROVIDE ADDITIONAL SPRINKLER HEADS AS REQUIRED BY NFPA 13 AND LOCAL JURISDICTIONAL REQUIREMENTS.

L. SPRINKLER HEADS SHALL BE INSTALLED ABOVE AND BELOW ALL DUCTWORK GREATER THAN 48" WIDE.

M. ALL PIPE PENETRATIONS OF FIRE RATED WALLS SHALL BE FIRE STOPPED TO MAINTAIN FIRE RATING OF WALL.

N. ALL FIRE PROTECTION DRAWINGS, HYDRAULIC CALCULATIONS AND SUPPORTING DOCUMENTATION SHALL BE COMPLETED BY THE FIRE PROTECTION CONTRACTOR AND SUBMITTED TO LOCAL AUTHORITIES HAVING JURISDICTION AND TO DICK'S INSURANCE UNDERWRITER FOR REVIEW AND APPROVAL PRIOR TO FABRICATION OF ANY PIPING OR SYSTEM COMPONENTS. REFER TO SPECIFICATIONS FOR DICK'S INSURANCE UNDERWRITER INFORMATION.

O. COORDINATE INSTALLATION OF SPRINKLER PIPING WITH DUCTWORK, LIGHTS, AND PARTITION LAYOUT. LIGHTS ARE NOT TO BE MOVED, SPRINKLER PIPING SHALL BE ROUTED AROUND LIGHTS AS REQUIRED.

P. HANGER NOTES:

- PIPES LARGER THAN 4 IN. RUNNING PARALLEL TO BAR JOIST SHALL BE HUNG FROM TRAPEZE HANGERS SUPPORTED NEARLY EQUALLY BY TWO JOISTS.
- ONLY ONE PIPE SHALL BE SUPPORTED FROM A SINGLE TRAPEZE HANGER UNLESS OTHERWISE APPROVED IN WRITING BY THE STRUCTURAL ENGINEER OF RECORD.
- HANGERS WITH MORE THAN 150 POUNDS OF LOAD SHOULD BE ATTACHED TO THE JOIST AT A PANEL POINT.
- COORDINATE ALL HANGER TYPES AND LOCATIONS WITH THE STRUCTURAL ENGINEER OF RECORD.

THIS DRAWING IS FOR REFERENCE ONLY. FIRE PROTECTION CONTRACTOR FOR THIS PROJECT SHALL PROVIDE FULLY DETAILED SPRINKLER PLANS AND CALCULATIONS.

MICHAEL CRISLIP ARCHITECT

25001 Emory Road, Suite 400
Cleveland, Ohio 44128
216.232.3200 mcrislip@mcra.com

DICK'S SPORTING GOODS

3600 GALLERIA DRIVE
GREENVILLE, NC 27834
STORE #008

Project No.: 24.0122
Drawn By: AML
Date: 04-19-24
Issue: BID/ PERMIT

CONTRACTOR MUST VERIFY ALL CLEARANCES AND DIMENSIONS IN FIELD

DESIGNER STATEMENT

I hereby certify that the design of this building complies with the mechanical systems, service systems and equipment requirements of the 2018 North Carolina State Building Code & Energy Conservation Code.

Signed: _____
Date: _____

Mc&A
Consulting Engineers est. 1980

25001 Emory Road, Suite #200
Warrsville Heights, Ohio 44128
Phone: 216.292.4696
Fax: 216.292.6074
Email: mc&a@mc&aengineers.com
North Carolina Certificate Number: C-0885

FP1.0

FIRE PREVENTION PLAN

Design and construction documents are instruments of service and remain the property of Michael Crislip, Architect. The use of this design and these construction documents for purposes other than the specific project named herein is strictly prohibited without expressed written consent of Michael Crislip, Architect.

SELF-DEVELOPED STORES
At work, materials, and systems shown in these plans and specifications, including but not limited to, are the property of Dick's Sporting Goods, Inc. and are not to be used, copied, or reproduced in any form without the written consent of Dick's Sporting Goods, Inc.