

# ITv2 Integration for C•CURE 9000 v3.00

## Release Notes

A163816HV5

Document Revision: B

January 2023

This document provides important information about the installation of the ITv2 Integration for C•CURE 9000 v3.00 on both server and client machines. In case of discrepancy, the information in this document supersedes the information in any document referenced herein.

Read this document before you install the product.

**Product:** C•CURE 9000 ITv2 Integration

- Integration Software Version: 6.0.9.9

This driver release is qualified with C•CURE 9000 when installed on:

- victor Unified Systems v4.00 (C•CURE v3.00 and victor v6.0)

### Overview

---

The C•CURE 9000 ITv2 Integration provides an advanced integration with the DSC PowerSeries Neo and Pro Panels. You can monitor and configure Neo and Pro devices, hardware, and alarms from the C•CURE 9000 Monitoring Station and Administration Station.

### Features

---

Major features supported by C•CURE 9000 ITv2 Integration are as follows:

- DSC PowerSeries Neo and Pro Panels
- Filter Status messages: Enables events buffer
- Maintenance Mode is used to limit information, about an object, displayed on the Monitoring Station.
- Synchronization of the following objects from the panel:
  - Partition
  - Zones
  - Output
  - Virtual Zones
  - Users
- Synchronization of the following objects to the panel:
  - Partition
  - Zones
  - Output
  - Virtual Zones
  - Users
- Actions to control the Neo or Pro objects from C•CURE 9000:
  - Partition: Arm, Disarm, System Test
  - Zone: Bypass or Reset
  - Output: Activate or Deactivate.
- Creation and application of Templates for the panel
- Alarm Filtering, Virtual Keypad, Audit, and Journal log
- Instant scheduling of Events and Actions
- Supports TLS 1.2 for security

## Software Requirements

The C•CURE 9000 ITv2 Integration requires the following software:

- C•CURE 9000 Security and Event Management System: v3.00

## Qualified hardware and firmware

The C•CURE 9000 ITv2 Integration supports the following hardware and firmware:

**Table 1: Neo Versions Supported**

Hardware Version	Hardware Model	Firmware Version Supported
UA621 REV03	HS2016 / HS2032 / HS2064 / HS2128 / HS2128E	v01.12.01.13 / v01.14.01.10 / v1.20.01.31 / v1.21.01.01 / v01.30.01.08 / v01.30.01 / v1.31.01.01 / v1.35.01.07 / v1.37.01.12
UA601 Rev03	TL280 / TL280R / TL2803G	v04.11.04.31
UA628 Rev03	HS2LCD	v01.10.01.51 / v01.11.01.13 / v1.20.01.29 / v1.30.01.04 / v1.35.01.03
UA685 Rev01	TL280 / TL280R / TL2803G / TL280E / TL280RE	v5.00.04.27 / v05.20.01.29 / v05.02.04.03 / v5.03.04.04 / v5.41.04.01

**Table 2: Pro Versions Supported**

Hardware Version	Hardware Model	Firmware Version Supported
UA718Rev03	HS3128PCB / HS3248PCB	v1.30
UA628 Rev03	HS2LCD	v2.30

- Expansion Module: Output expander / Zone expander (HSM2108/HSM2208)
- Wireless Module: HSM2HOST / PG4984 / PG4945

## Installation package contents

The table below lists the contents of the installation package:

**Table 3: Contents of installation**

File	Description
DSC_ITv2-6.0.9.9.exe	Installation program for the ITv2 Integration software
UM-CC9K-ITv2-v3-00-A163816HVY-B-en.pdf	ITv2 Integration for C•CURE 9000 v3.00 - User Guide
RN-CC9K-ITv2-v3-00-A163816HV5-B-en.pdf	ITv2 Integration for C•CURE 9000 v3.00 - Release Notes

## Supported installation types

---

The ITv2 Integration for C•CURE 9000 supports the following installation types:

- Unified Standalone
- C•CURE 9000 Standalone
- Unified Enterprise
- C•CURE 9000 Enterprise

## Installation

---

For installation instructions, refer to the *ITv2 Integration for C•CURE 9000 - User Guide*.

## Upgrading the ITv2 integration

---

Before upgrading the driver from v2.80 to v3.0 and v2.90 to v3.0, the below services must be stopped in the Server Configuration Application.

- CrossFire Framework Service
- CrossFire Server Component Framework Service

The 3.00 ITv2 driver supports the following upgrade scenarios:

- Upgrade from v2.80 to v3.00
- Upgrade from v2.90 to v3.00

To upgrade the ITv2 driver from a version earlier than v2.80 to v3.00, follow an incremental upgrade path to get to version 2.80.

You must upgrade the C•CURE installation before you upgrade the ITv2 Intrusion Integration. For example:

- If the current driver is a C•CURE v2.60 compatible driver, upgrade incrementally to a C•CURE v2.80 compatible driver, and then upgrade to a C•CURE v3.00 compatible driver to maintain data integrity.
- If the current driver is a C•CURE v2.70 compatible driver, upgrade incrementally to C•CURE v2.80 or v2.90 compatible driver, and then upgrade to a C•CURE v3.00 compatible driver to maintain data integrity.

### Caution

- If you have made any changes in the configuration file: `ITV2Configuration.xml`, ensure that you back up the file before upgrading. The configuration file is located at `Tyco\CrossFire\ServerComponents`.
- If you upgrade C•CURE and reboot your system before you upgrade the ITv2 integration, the ITv2 driver is stopped. You must upgrade the ITv2 integration to a C•CURE v3.00 compatible driver before you can start the ITv2 driver.

### Follow the steps below to upgrade the ITv2 integration to v3.00:

1. Use the Unified installer to upgrade to C•CURE 9000 v3.00.  
**Note:** Click **Later** on the prompt that appears after you upgrade C•CURE. Do not click **Reboot**.
2. Upgrade the ITv2 integration.
3. Reboot the machine.

## Scalability

---

This driver is qualified with the following panels:

- DSC PowerSeries Neo - 500 panels per server
- DSC PowerSeries Pro - 50 panels per server

**Note:** The DSC PowerSeries Pro Panel support 4 times the number of Partitions (Total of 8 Partitions in Neo versus 32 in Pro Series) and double the number of zones (Total of 128 Zones in Neo and up to 248 Zones in Pro Series). The performance numbers for the DSC PowerSeries Pro Panels are run with a fully loaded set of Zones and Partitions per Panel. The actual number of Panels which is possible to support at customer sites may depend on the capacity usage of the Partition Zone association per Panel.

## Language support

This driver supports the English (US) language.

## Compatibility matrix

The table below lists the Compatibility Matrix for the ITv2 integration.

**Table 4: Compatibility matrix**

<b>C•CURE 9000 version 3.00</b>	
Partner	DSC
Partner Product	PowerSeries Neo and Pro
Partner Product version	<ul style="list-style-type: none"> <li>• Hardware version: UA628 REV03, Keypad Model: HS2LCD, and Firmware version: v01.10.01.51, v01.11.01.13, v1.20.01.29, v1.30.01.04, v1.33.01.02, and v1.35.01.03</li> <li>• Hardware version: UA601 REV03, Communicator Model: TL280/TL280R/TL2803G, and Firmware version: v04.11.04.31</li> <li>• Hardware version: UA685 REV01, Communicator Model: TL280E/TL280RE, and Firmware version: v5.00.04.27, v05.02.04.03, v5.03.04.04, v5.40.04.07 and v5.41.04.01</li> <li>• Hardware version: UA621 REV03, DSC Neo Panel Model: HS2016, HS2032, HS2064, HS2128, HS2128 E, and Firmware version: v01.12.01.13, v01.14.01.10, v1.20.01.31, v1.21.01.01, v01.30.01.08, v1.31.01.01, v1.33.01.05, v1.35.01.07 and v1.37.01.12</li> <li>• Expansion Module: Output expander/Zone expander (HSM2108/HSM2208)</li> <li>• Wireless Module: HSM2HOST/PG4984/PG4945</li> <li>• Hardware version (Pro Panel): UA718 Rev03, Hardware Model: HS3128PCB / HS3248PCB, and Firmware version: v1.30</li> <li>• Hardware version (Pro Panel): UA628 Rev03, Hardware Model: HS2LCD, and Firmware version: v2.30</li> </ul>
Integration driver version	6.0.9.9
C•CURE 9000 License option	CC9000-Neo
Enterprise Certified	Yes
Redundancy Certified	No
Supported Server OS	All OS supported by C•CURE 9000 server
Supported Client OS	All OS supported by C•CURE 9000 Client

Supported SQL	All SQL supported by C•CURE 9000 server
---------------	---

## Known issues and limitations

This section describes the C•CURE 9000 ITv2 Integration known limitations.

- If **Connection Strings Encrypted** checkbox is selected at C•CURE v2.8/v2.9, then after upgrading to v3.0 and, when v3.0 compatible ITv2 Integration is installed, **Connection Strings Encrypted** check box is de-selected.
  - **Workaround:** Enable the check-box **Connection Strings Encrypted** again.
- One panel can be associated with only one alarm filter.
- If you install the ITv2 Integration on remote clients, the Integration Setup dialogue box appears, and you may be prompted to select an Installation Option for Redundancy sever. Ignore this message and click **Next** to continue with installation. If you select the Redundancy server installation using supported third-party redundancy check box, provide the virtual server location, and then click **Next**; this selection is ignored and there is no functional impact.
- The ITv2 Integration with C•CURE 2.40 onwards does not support EMC AutoStart or RepliStor products due to their End-Of-Life status.
- Migration of a standalone machine with ITv2 Driver to SAS is not supported.
- Apply template feature will not be successful, until the panel capabilities (like number of zones/partition/output/user) are extracted from the panel.
  - **Workaround:** Synchronization from Panel before applying template.
- ITv2 driver stop will not be successful, if the synchronization/configuration read of more than 200 panels are in progress.
  - **Workaround:** Restart the driver and there will be no impact on the functional.
- Duress Code Attribute (DCA) write to the panel will not be successful, if Duress Code option is not enabled in panel programming.
  - **Workaround:** Enable Duress Code option in Panel programming. Refer to the Panel User manual.
- Bulk Output activate will not be successful, if the Partition Assignment tab output is not proper.
  - **Workaround:** Assign output to the enable partition.
- Zones removal from partition are not getting reflected in the Partition-Zone Assignment tab on partition editor.
  - **Workaround:** After Zone removal, sync from panel to be performed to reflect the exact configuration of the panel.
- Master User modification is not allowed through the integration.
- Panel access code length and C•CURE PIN length requires to be same to read and write the user information.
- During Status synchronization of 500 Neo panels, first batch synchronization takes fifty percent of the complete sync process time.
- When trying for 500 Neo panels to bring online, panels start loading online gradually instead of being loaded immediately.
- Output labels write to the panel is not supported.
- When Partition status is changed to **Arm**, the status image is not getting updated in C•CURE **Monitoring Station**.
- If multiple intrusion integrations (such as ITv2, DMP, Galaxy, Sur-Gard and Bosch) are installed on the system, then performing the uninstallation of individual intrusion integration with the option **Database Drop** selected is not recommended as this will cause the other intrusion integrations to malfunction.
- If multiple intrusion integrations (such as ITv2, DMP, Galaxy, Sur-Gard and Bosch) are installed on the system, then performing the upgrade of individual intrusion integration is not recommended. User must perform the upgrade of all the intrusion integrations at the same time.
- In virtual keypad partitions are not sorted in alphabetical order.

- While assigning **Personnel** to ITv2 Panel's user (under ITv2 Panel-->User tab), if you click the browse button then the **Personnel** from all the C•CURE **Partitions** (including **Default Partition**) gets listed and, also are allowed to assign.
  - **Workaround:** It is recommended to select the **Personnel** belonging to C•CURE **Partition** same as of ITv2 Panel's Partition.
- This version of driver has fixes for C•CURE **Partition** assignment issue for ITv2 Objects. Hence after upgrading to this version of driver perform the **Sync from Panel** on ITv2 Panel, so that all objects have correct C•CURE Partitions assigned to them.
- After upgrading from previous versions to this version of driver, if ITv2 Panel needs to be moved from one C•CURE **Partition** to another then perform the **Sync from Panel** on ITv2 Panel before moving the ITv2 Panel, so that all objects have correct C•CURE Partitions assigned to them.
- When upgrade is performed from C•CURE v2.8/v2.9 with multiple Integrations and post C•CURE v3.0 upgrade, then upgrade of all Integrations is mandatory. If any of the Integrations is not upgraded, then it may lead to malfunctioning of other integration services or CF services. User must perform the upgrade of all the integrations.
- The following list of Alarm Filter categories were not tested in the Alarm Filter functionality due to lack of information on simulating the Alarm/Event notifications:
  - Receiver Events
  - Wireless Device Events
  - Alternate Communicator
  - Maintenance OPenClose Events
  - Fire Alarm

## Defects Fixed

---

The following table lists the defects fixed in this version of the software:

**Table 5: General Fixes**

Category	SPAR Number	SPAR Description
Driver	835823	ITv2 Alarm Filter does not prevent ITv2 Alarms and messages from getting written to the C•CURE 9000 Journal database.

## End of Release Notes

---

The trademarks, logos, and service marks displayed on this document are registered in the United States [or other countries]. Any misuse of the trademarks is strictly prohibited, and Johnson Controls will aggressively enforce its intellectual property rights of the law, including pursuit of criminal prosecution wherever necessary. All trademarks not owned by Johnson Controls are the property of their respective owners and are used with permission or allowed under applicable laws.

Product offerings and specifications are subject to change without notice. Actual products may vary from photos. Not all products include all features. Availability varies by region; contact your sales representative.

© 2023 Johnson Controls. All rights reserved. JOHNSON CONTROLS, TYCO and SOFTWARE HOUSE are trademarks of Johnson Controls.