



**American Dynamics**

*From Tyco Security Products*

# victor EntraPass Integration Guide

---

## **Notice**

The information in this manual was current when published. The manufacturer reserves the right to revise and improve its products. All specifications are therefore subject to change without notice.

## **Copyright**

Under copyright laws, the contents of this manual may not be copied, photocopied, reproduced, translated or reduced to any electronic medium or machine-readable form, in whole or in part, without prior written consent of Tyco Security Products. © 2016 Tyco Security Products. All Rights Reserved.

American Dynamics  
6600 Congress Avenue  
Boca Raton, FL 33487 U.S.A.

## **Customer Service**

Thank you for using American Dynamics products. We support our products through an extensive worldwide network of dealers. The dealer through whom you originally purchased this product is your point of contact if you need service or support. Our dealers are empowered to provide the very best in customer service and support. Dealers should contact American Dynamics at (800) 507-6268 or (561) 912-6259 or on the Web at [www.americandynamics.net](http://www.americandynamics.net).

## **Trademarks**

Windows® is a registered trademark of Microsoft Corporation. PS/2® is a registered trademark of International Business Machines Corporation.

The trademarks, logos, and service marks displayed on this document are registered in the United States [or other countries]. Any misuse of the trademarks is strictly prohibited and Tyco Security Products will aggressively enforce its intellectual property rights to the fullest extent of the law, including pursuit of criminal prosecution wherever necessary. All trademarks not owned by Tyco Security Products are the property of their respective owners, and are used with permission or allowed under applicable laws.

Product offerings and specifications are subject to change without notice. Actual products may vary from photos. Not all products include all features. Availability varies by region; contact your sales representative.

---

## Introduction

EntraPass Integration Overview .....	5
Product Components .....	5
Features .....	6

## Installation

Minimum Requirements .....	7
Hardware .....	7
Software .....	7
Installation .....	8

## Operation

Administration Functions .....	9
Hardware Information .....	9
Adding EntraPass Servers .....	9
Editing EntraPass Servers .....	10
victor Integration .....	13
Roles .....	13
Associations .....	13
Reports .....	13
Events .....	13
Predefined EntraPass Events .....	14
EntraPass Actions .....	15
Maps .....	17
EntraPass Objects .....	18
Swipe and Show .....	23
General Operation .....	24
Manual Actions .....	24
Context (right click) Menu options .....	26

## Troubleshooting

Problem: EntraPass Server is not communicating with victor .....	27
--	----

## Appendix A

KT 400 Controller configuration with DSC PowerSeries .....	1
--	---

---

## Appendix B

Configuring EntraPass for remote victor Client operation . . . . .	1
Configuring Ports with an SSL Certificate . . . . .	2

# Introduction


## EntraPass Integration Overview

The EntraPass server integration provides advanced, seamless integration between victor and EntraPass servers allowing users to monitor and synchronize their devices from within the victor interface.

### Product Components

- **EntraPass Client:** Used to specify connection details to EntraPass server and perform synchronization actions.
- **EntraPass Objects:** Physical or logical EntraPass entities within the victor environment.
- **EntraPass Server Component:** Facilitates and maintains communication with the EntraPass unit and auto-creates Sites, Controllers, Doors, Inputs and Relay objects based on EntraPass unit properties.

Figure 2-1 System Overview



## Features

The objective of the EntraPass integration is to provide a standard, single interface between EntraPass and American Dynamic's victor Video Management product.

Supported features include:

- Viewing status and information of multiple configured EntraPass servers.
- Adding new EntraPass servers.
- Manual and Automatic synchronization of servers.
- All intrusion panels and access control objects supported by EntraPass receivers.
- Integration with victor **Roles**, **Object Association**, **Journal**, and victor Event Management.
- EntraPass object integration with victor **Maps** and the **Health Dashboard**.
- Smart Service Binding support for https.
- Synchronization of **Personnel** and personnel images.
- Adding Predefined EntraPass events and **Actions**.
- The **Swipe and Show** feature.

# Installation

---

## Minimum Requirements

### Hardware

The EntraPass integration has the same hardware requirements as victor Application Server. Therefore, if the machine can successfully run victor then it will satisfy EntraPass integration requirements.

EntraPass integration requires approximately 50MB of available Hard Disk space.

### Software

- EntraPass Server
- EntraPass/victor Integration
- victor Application Server
- victor Unified Client

## Installation

The EntraPass installer must be installed on both **victor Application Server** and all **victor Client** machines.

---

**Note**

Refer to Appendix B for information on configuring EntraPass servers for use with victor Unified Client over a secure (https) connection.

---

### Procedure 3-1 Adding EntraPass Integration to victor

---

Step	Action
<hr/>	
1	Close any currently running programs.
2	Open a web browser and navigate to <a href="http://www.americandynamics.net">http://www.americandynamics.net</a>
3	Download the appropriate version of the EntraPass Integration software driver for your version of victor.
4	Launch the EntraPass Integration Software Driver. The <b>Welcome to EntraPass Receiver Integration</b> window displays.
5	Select <b>Next</b> . The End User License Agreement (EULA) window displays.
6	Read the <b>EULA</b> .
7	Select the <b>I accept the terms in the license agreement</b> button, then select <b>Next</b> .
8	Select <b>Install</b> . The program begins to install, this may take several minutes. Once complete, the InstallShield Wizard Complete window displays.
9	Select <b>Finish</b> . After installation, a new group called <b>EntraPass</b> is available on the <b>Setup</b> tab.

---

**Note**

The install process stops all Application Server services, these services need to be restarted on **victor Application Server** machines once the install is complete.

---

---

- End -

---



## Administration Functions

- **Save and Close:** saves the current object and closes the editor.
  - **Save:** saves changes and keeps the editor open, allowing further changes to be made.
  - **Save and New:** saves the current object and opens a new editor to create a new object with default values populated.
  - **Close:** cancels changes and closes the editor without saving.
- 

## Hardware Information

Detailed hardware information is available for all configured EntraPass units. To access this information:

### Procedure 4-1 Accessing Hardware Information

---

Step	Action
------	--------

---

- 1 Select **EntraPass servers** from the **Setup** tab, then select **Show All**.
- 2 Right-click the server you wish to view information for and select **Edit**.

This information is also available by right-clicking on a receiver in the **Device List** and selecting **Edit**.

## Adding EntraPass Servers

### Procedure 4-2 Adding New EntraPass servers

---

Step	Action
------	--------

---

- 1 Select **EntraPass server** from the **Setup** tab.
- 2 Select **New** from the drop down list. **New Server** Editor displays.
- 3 Enter a name for the server in the **Name** field.

- 4 Enter a description for the server in the **Description** field.

---

**Note**

The **Enabled** checkbox is selected by default. To deactivate the server, deselect the checkbox.

---

- 5 Expand the **Details** section.
- 6 Enter the IP Address of the server in the **IP Address** field.
- 7 Enter the **Port Number** (Minimum 1 character, Maximum 5).
- 8 Enter the **UserID**, which is the ID of the operator in the EntraPass application.
- 9 Enter the **Password**, which is the password of the operator in the EntraPass application.
- 10 Enter **Event Poll Time**.
- 11 Enter **Service Protocol** information.
- 12 Enter **Autosync poll time**.
- 13 Enter **Status Poll Time**.
- 14 You can review server status in the Server status section:

**Table 4-1 Server Status**

Property	Value
Communication Status	Online
	Offline
	Unknown
Synchronization Status	Unknown
	Synchronizing
	Synchronized
	SyncFailed

- 15 Select **Save**.

---

- End -

---

## Editing EntraPass Servers

### Procedure 4-3 Edit EntraPass Servers

You can configure server connection details from within victor, using the EntraPass Server editor.

Figure 4-1 EntraPass Server editor

The screenshot shows the EntraPass Server editor interface. It has a top toolbar with icons for save, delete, and refresh. The interface is divided into three main sections: General, Details, and Status.

**General**

- Name: WIN-8BF26TN683I
- Description: WIN-8BF26TN683I
- ☒ Enabled

**Details**

- Machine Name or IP Address: WIN-8BF26TN683I
- Port Number: 8801
- Service Protocol: http (dropdown menu)
- User ID: yatish
- Password: \*\*\*\*\*
- Event Poll Time(In Seconds): 10
- Status Poll Time(In Seconds): 10

**Status**

- Communication Staus: Online
- Synchronization Staus: Synchronized

Step	Action
------	--------

- |   |   |
|---|---|
| 1 | Select <b>EntraPass server</b> from the <b>Setup</b> tab.   |
| 2 | Select <b>Show All</b> from the drop down list.   |
| 3 | Right click the server to be edited and select <b>Edit</b> .  |
| 4 | Select the General expander to edit: <ul style="list-style-type: none"> <li>• <b>Name</b> (Mandatory must be unique)</li> <li>• <b>Description</b> (Optional)</li> <li>• <b>Enabled status</b> (Default is enabled)</li> </ul>  |
| 5 | Select the <b>Details</b> expander to edit: <ul style="list-style-type: none"> <li>• <b>Machine Name or IP Address</b> (Mandatory) - This is the network address of the Server, by default it is 127.0.0.1. The following validation rules will apply to the Panel's Machine Name or IP address field:               <ul style="list-style-type: none"> <li>•The <b>Machine Name or IP Address</b> must be unique for each panel within the victor environment otherwise the message returns "<b>Machine Name or IP Address not unique</b>".</li> </ul> </li> <li>• <b>Port Number</b> (Mandatory) - The Port number of the server Min=1 character, Max=5 characters</li> <li>• <b>Service Protocol</b> (Mandatory) - The protocol used to communicate with the server</li> </ul> |

**Note**

If 'https' is selected, a dialog displays prompting the user to complete the EntraPass smart link configuration to https. For this protocol to function, a valid SSL certificate must be added to the Kantech server.

- **User ID** (Mandatory) - ID of the operator in the EntraPass application
- **Password** (Mandatory) - Password of the operator in the EntraPass application
- **Event Poll Time** (Mandatory) - Poll time to request or poll for EntraPass events
- **Status Poll Time** (Mandatory) - Poll time to request or poll for EntraPass device status
- **Autosync Poll Time** - Autosynchronize interval based on number of days entered

**Table 4-2 Server Status**

Property	Value
Communication Status	Online
	Offline
	Unknown
Synchronization Status	Unknown
	Synchronizing
	Synchronized
	SyncFailed

**6**      Select **Save**.

---

- End -

---

## victor Integration

### Roles


EntraPass objects privileges are associated with victor roles, therefore all context menu actions associated with EntraPass objects are added to existing victor roles which can be edited accordingly. For more information on **Roles**, refer to the *victor Configuration and User Guide*.

### Associations

EntraPass servers support victor's **Object Association**. **Object Association** refers to linking unrelated victor objects with the intent of enabling incident building capability. Device associations are created within the victor editor of the source object (typically right click > edit). Up to 5 device associations can be made per object.

To create Object Associations in victor:

#### Procedure 4-4 Create object associations

Step	Action
1	Navigate to the required source device on the victor <b>Device List</b> .
2	Right click the device and select <b>Edit</b> . The device editor opens.
3	Expand the <b>Associations</b> section.
4	Select  . Object selector displays.
5	Use the object selector to locate the object to be associated.
6	Select <b>OK</b> .
7	Repeat as required for up to 5 objects.
- End -	

### Reports

EntraPass objects are included in the report selection tool and support the victor **Find in Journal** feature. For more information on **Reports** and the **Find in Journal** feature, refer to the *victor Configuration and User Guide*.

### Events




Events allow you to detect, monitor and record specific activities on the system.

EntraPass alarm activity can be used to trigger events within victor, these event types are fully integrated with victors Event Management system and respect all role /user permissions.

Event configuration in victor is a 2 step process:

- 1 Event/Action Pairing
- 2 Event Setup

## Procedure 4-5 Configuring events

Step	Action
1	Select <b>Event Setup</b> from the <b>Build</b> tab.
2	Select <b>Event/Action pairing</b> . The editor opens.
3	Double click the <b>Events</b> node. Object selector displays.
4	Use the Object selector to select events as required.
5	Select  in the event node to assign actions. Repeat as required.
6	Select <b>Save</b> .
7	Select <b>Event Setup</b> from the <b>Build</b> tab.
8	Select <b>Event Setup</b> from the drop down list. The event configuration window displays.
9	Click the Devices node and use the object selector to select the required device (or drag and drop from the device list)
10	Select  in the node of the device added and use the checkboxes in the drop down list to assign alerts as required.
11	Select <b>Add Alerts</b> . Selected alerts are displayed under the Alerts node.
12	Select  in the <b>Alerts</b> node and use the object selector to assign actions.
13	Select <b>Save</b> .
- End -	

For further information on **Events**, refer to the *victor Configuration and User Guide*.

## Predefined EntraPass Events

The following predefined EntraPass events are available for doors, site controllers, and servers:

- **EntraPass Server Online**
- **EntraPass Server Offline**
- **EntraPass Site Online**
- **EntraPass Site Offline**
- **EntraPass Controller Online**
- **EntraPass Controller Offline**
- **Door Held Alarm**
- **Door Forced Alarm**

## Procedure 4-6 Viewing Predefined events

Step	Action
1	Select <b>Events</b> from the <b>Build</b> tab.


- 2 Select **Show All**. Editor opens.
- 3 All configured events including predefined EntraPass events are displayed.

## EntraPass Actions

EntraPass Actions are available for the following objects:

- **Servers**
- **Doors**
- **Relays**

### Procedure 4-7 Configuring EntraPass Action

Step	Action
1	Select <b>EntraPass Action</b> from the <b>Setup</b> tab.
2	Select <b>New</b> . The editor opens.
3	Enter <b>Name</b> and <b>Description</b> for the EntraPass Action.
4	In the <b>EntraPass Device</b> field, select  to add device. Object selector displays.
5	Select desired object and click <b>OK</b> .
6	Repeat as required.
7	Select desired action from the <b>EntraPass Device Action</b> drop down list.
8	Select <b>Save and Close</b> .
- End -	

### Procedure 4-8 Editing EntraPass Action

Step	Action
1	Select <b>EntraPass Action</b> from the <b>Setup</b> tab.
2	Select <b>Show All</b> . The editor opens.
3	Right-click the EntraPass action that you want to edit and select <b>Edit</b> .
4	Select the <b>General</b> expander to edit. <ul style="list-style-type: none"> <li>• <b>Name</b></li> <li>• <b>Description</b></li> </ul>
5	Select the <b>Action</b> expander to edit:

- **EntraPass Device**
- **EntraPass Device Action**

**6** Select **Save and Close**.

---

- End -

---





## Maps

EntraPass objects are supported on victor **Maps** and the **Find on Map** feature. Objects respect all standard victor hardware behaviors such as annunciation, alarms, right click actions and drag and drop.

To configure **Maps** in victor:

### Procedure 4-9 Configuring maps

Step	Action
1	Select <b>Maps</b> from the <b>Build</b> tab.
2	Select <b>New</b> . The editor displays.
3	Enter a <b>Name</b> and <b>Description</b> for the map.
4	Select  <b>Import a map</b> .
5	Browse to and select the required image.
6	Select <b>Open</b> .
7	Select <b>Import</b> . File imports and displays in map editor.
8	Select <b>Save</b> .
The map drawing is now imported and you can now configure victor objects on it.	
9	From the map editor, select  . Icon selector displays.
<b>Note</b> The Map editor can be accessed by selecting <b>Maps</b> from the <b>Build</b> tab, then selecting <b>Show All</b> . Right click on the map to be edited and select <b>Edit</b>	
10	Select the icon which matches the object type to be added.
11	Select <b>OK</b> .
12	Drag and drop to the required position on the map. Use resizing/positioning tools as required.
13	Right click the icon.
14	Select <b>Drop on map</b> . The Icon editor displays.
15	Select <b>Select Object</b> . The object selector displays.
16	Select the victor object to be linked to the icon and select <b>OK</b> .
17	Use the Icon editor to assign or change other attributes as required.
18	Select <b>OK</b> .

- 19 Select **Save**.

**Note**

Refer to the victor configuration manual for a detailed guide on adding and configuring maps.

- End -

## EntraPass Objects

### Procedure 4-10 View EntraPass Sites

Within the victor environment, EntraPass sites are view only.

Figure 4-2 EntraPass sites editor

The screenshot shows a window titled "EntraPass sites editor" with three tabs: General, Communication Protocol, and Status. The General tab is active, showing fields for Name (KT-400 Site), Description (KT-400 Site), and a checkbox for Enabled (checked). The Communication Protocol tab shows fields for Server Name (test server), Number of Controllers (1), IP Address (10.47.84.211), Connection Type (Secure IP(KT-400)), Port Number (18810), Baud Rate (19200), Serial Port Number (255), and Protocol (TCP). The Status tab shows a field for Communication Status (Online).

Step	Action
------	--------

- |   |  |
|---|--|
| 1 | Select <b>EntraPass Site</b> from the <b>Setup</b> tab.  |
| 2 | Select <b>Show All</b> .   |
| 3 | All configured EntraPass sites are displayed in an <b>Object List</b> . Use the expanders to view details within each section. |

- End -

## Procedure 4-11 View EntraPass Controllers

Within the victor environment, EntraPass controllers are 'view only'.

**Figure 4-3 EntraPass controller editor**

The screenshot shows the 'EntraPass controller editor' window. It has a standard Windows-style title bar with icons for save, undo, redo, and close. The main area is divided into four expandable sections: 'General', 'Communication Protocol', 'Associations', and 'Status'.  
 - **General**: Contains 'Name' (KT 400 controller), 'Description' (KT 400 controller), and an 'Enabled' checkbox which is checked.  
 - **Communication Protocol**: Contains 'Site Name' (KT-400 Site), 'Serial Number' (10069119), and 'Controller Type' (KT400).  
 - **Associations**: Contains a 'Communication Protocol' button.  
 - **Status**: Contains several status indicators: 'Communication Status' (Online), 'Tamper Alarm' (Yes), 'Hard Reset' (No), 'AC failure' (No), 'Tamper Schedule' (Yes), and 'AC Schedule' (Yes).

Step	Action
1	Select <b>EntraPass Controller</b> from the <b>Setup</b> tab.
2	Select <b>Show All</b> .
3	All configured EntraPass controllers are displayed in an Object List. Use the expanders to view details within each section.

**Table 4-3 Controller Status**

Property	Value
CommunicationStatus	Online
	Offline
Hardreset	Yes
	No
Tamperalarm	Yes
	No
AC Failure	Yes
	No
Tamper Schedule	Yes
	No
AC Schedule	Yes
	No

- End -

## Procedure 4-12 View EntraPass Doors

Within the victor environment, **EntraPass Doors** are view only.

Figure 4-4 EntraPass door editor

The screenshot shows the EntraPass door editor interface. It has a top toolbar with icons for save, delete, and other actions. The main area is divided into four sections: General, Details, Associations, and Status. The General section contains fields for Name (Controller #1 Door #1), Description (Controller #1 Door #1), and an Enabled checkbox. The Details section contains fields for Controller Name (KT 400 controller), Door Access (Entry), and Elevator Door (No). The Associations section has a Type Name field and a list of associations. The Status section contains fields for Open State (Close), Lock State (Lock), Reader Disable (No), and Armed (None).

Section	Field	Value
General	Name	Controller #1 Door #1
	Description	Controller #1 Door #1
	Enabled	<input checked="" type="checkbox"/>
Details	Controller Name	KT 400 controller
	Door Access	Entry
	Elevator Door	No
Associations	Type Name	
	Associations	
Status	Open State	Close
	Lock State	Lock
	Reader Disable	No
	Armed	None

Step	Action
------	--------

- |   |   |
|---|---|
| 1 | Select <b>EntraPass Doors</b> from the <b>Setup</b> tab.  |
| 2 | Select <b>Show All</b> .  |
| 3 | All configured <b>EntraPass Doors</b> are displayed in an <b>Object List</b> . Use the expanders to view details within each section. |

- End -

## Procedure 4-13 View EntraPass Inputs

Within the victor environment, **EntraPass Inputs** are view only.

**Figure 4-5 EntraPass Input editor**

The screenshot shows the EntraPass Input editor window with the following fields:

- General**
  - Name: Contact -> Controller #1 Input #1
  - Description: Contact -> Controller #1 Input #1
  - ☒ Enabled
- Details**
  - Controller Name: KT 400 controller
  - Active Status: Activate
  - Response Delay(centi-seconds): 50
  - Condition: Closed
  - Supervision: Normal
- Associations**
  - + -
  - Type Name:
- Status**
  - State: Tamper
  - Shunted By: None

Step	Action
------	--------

- |   |   |
|---|---|
| 1 | Select <b>EntraPass Inputs</b> from the <b>Setup</b> tab.   |
| 2 | Select <b>Show All</b> .  |
| 3 | All configured EntraPass inputs are displayed in an Object List. Use the expanders to view details within each section. |

- End -

### Note

The following **Shunted by** statuses requires the KT-400 controller to be connected with the supported intrusion panels:

1. Door Disarmed
2. Shunted on Exit
3. Shunted on Entry

## Procedure 4-14 View EntraPass Relays

Within the victor environment, **EntraPass Relays** are view only.

**Figure 4-6 EntraPass relay editor**

The screenshot displays the EntraPass relay editor interface. It features a top toolbar with icons for save, delete, and other actions. The main content area is divided into four sections: **General**, **Details**, **Associations**, and **Status**. The **General** section includes fields for Name (Controller #1 Relay #1), Description (Controller #1 Relay #1), and an Enabled checkbox. The **Details** section includes fields for Controller Name (KT-400 controller), Operation Mode (Normal), and Activation Period (5). The **Associations** section includes a Type Name field. The **Status** section includes a Status dropdown (set to ActivateOperator) and an Activate Tempo field (set to No).

Step	Action
------	--------

- |   |   |
|---|---|
| 1 | Select <b>EntraPass Relays</b> from the <b>Setup</b> tab.   |
| 2 | Select <b>Show All</b> .  |
| 3 | All configured EntraPass relays are displayed in an Object List. Use the expanders to view details within each section. |

- End -

### Procedure 4-15 View Personnel

Within the victor environment, synchronized personnel are displayed in the **Personnel** Tab.

Step	Action
4	Select <b>Personnel</b> from the <b>Setup</b> Tab.
5	Select <b>Show All</b> .
6	All synchronized personnel are displayed.
- End -	

### Swipe and Show

When a user swipes the card on the reader, the corresponding swipes are displayed in the **Swipe and Show** tab.

#### Note

For the **Swipe and Show** to function, ensure the following:

1. **Personnel** and personnel images are synchronized.
2. **Swipe and Show** tab is open.

### Procedure 4-16 Viewing Swipe and Show

Step	Action
1	Select <b>Swipe and Show</b> from the <b>Setup</b> tab.
2	Choose one of the following options: <ul style="list-style-type: none"> <li>• <b>Monitor all Doors for Admits</b></li> <li>• <b>Monitor all Doors for Rejects</b></li> <li>• <b>Monitor all Doors for Admits/Rejects.</b></li> </ul>
3	The details of the personnel with the image is displayed in the <b>Swipe and Show</b> tab.
- End -	

## General Operation

Once integrated the follow functions are available in victor Client:

### Manual Actions


#### Doors

You can **Lock, Unlock, Temporarily Unlock Doors, Arm, Disarm, Enable Readers, One Time Access** and **Disable Readers** from the **Device List, Maps**, dynamic views and activity viewer.

##### Note

To perform **Arm** or **Disarm** actions, **Doors** need to be associated with an external intrusion panel connected with a KT-400 controller.


Figure 4-7 Manual actions: Doors



#### Inputs

You can perform the following manual actions on an **Input** from **Device List, Maps**, dynamic views and activity viewer.

Figure 4-8 Manual actions: Inputs






## Relays

You can **Activate**, **Deactivate** and **Temporarily Activate Relays** from the **Device List**, **Maps**, dynamic views and activity viewer.


**Figure 4-9 Manual actions: Relays**



## Servers

You can manually synchronize Server objects, **Personnel**, and personnel Images from the **Device List**, **Maps**, dynamic views and activity viewer.

**Figure 4-10 Manual Actions: Servers**




## Context (right click) Menu options

This section details context menu options available on EntraPass objects from the **Device List**, **Maps**, dynamic views and activity viewer.

### Controllers

Right clicking controllers offers the following options:


**Figure 4-11 Context menu: Controllers**



### Sites

Right clicking sites offers the following options:

**Figure 4-12 Context menu: Sites**



## Troubleshooting

---

### Problem: EntraPass Server is not communicating with victor

#### Solution:

- 1 Validate firewall settings. Add required ports in Inbound and Outbound port list of firewall.
- 2 Ensure IP Address or System Name are correct.
- 3 Ensure that the current network configurations are able to validate the Machine Name provided in **Machine Name** or **IP Address** field of the EntraPass Server editor.
- 4 Ensure that the required services are running on EntraPass server.



# Appendix A

---

## KT 400 Controller configuration with DSC PowerSeries

### Requirements:

- EntraPass Server is installed.
- A DSC PowerSeries alarm panel and an IT-100 module.
- Door contact is connected on KT-400.
- RS-232 cable and 740-1047 adapter (p/n CBLK-IT100).
- Up-to-date KT-400 firmware.

### Hardware Setup

To connect the IT-100 to the KT-400 and the DSC PowerSeries intrusion panel, follow the steps below:

Step	Action
1	Connect the IT-100 to the alarm panel: <ul style="list-style-type: none"><li>a Power down the alarm panel</li><li>b Connect the IT-100 module to the Powerseries intrusion panel using a 4-wire KEYBUS connection. Connect the RED, BLK, YEL and GRN terminals to the KEYBUS terminals of the Powerseries panel.</li><li>c Power up the alarm panel.</li></ul>
2	To connect the IT-100 to the KT-400, refer to last page of the DSC IT-100 manual.
<b>Note</b> The IT-100 can be connected at a maximum distance of 98.4ft (30m) at 9600 baud rate from the KT-400. Refer to the DSC IT-100 manual for more information.	

---

- End -

---

## EntraPass Setup

For the EntraPass setup see **Setting up DSC integration through a KT-400 Controller** manual or contact the Kantech support team.

## Appendix B

### Configuring EntraPass for remote victor Client operation

This section describes the steps required to configure EntraPass Server for use with victor unified Client over a secure (https) connection.

#### Prerequisites


- EntraPass Server
- victor Unified Client
- Kantech SmartService and SmartLink running
- Port 8801 opened

#### Note


SmartLink and WebStation must have been previously registered in EntraPass for the SmartLink Webstation tab to be available. Refer to the EntraPass Reference manual for more information.

Step	Action
------	--------


- |   |   |
|---|---|
| 1 | Login to the EntraPass Server Workstation.                          |
| 2 | Select <b>Devices/Application</b> .                                 |
| 3 | From the <b>Application</b> drop down list, select <b>SmartLink</b> |



- 4 Click the **Web Service** tab.



- 5 Ensure that the **Use Web Service** field is checked.
- 6 Ensure that the Connection Time Out on Idle is set to the maximum, which is 59 minutes.



- End -

## Configuring Ports with an SSL Certificate

To configure a port, the tool you use depends on the operating system that is running on your machine.

Depending on the Operating system of your machine, different tools can be used. For Windows Server 2003 or Windows XP - use the HttpCfg.exe tool that is installed with Windows Server 2003.

For more information refer to Microsoft Windows Support Tools documentation.



### Prerequisites:

- Port 8801 is open.
- A valid SSL certificate on IIS.
- Administrator privileges on the server.

### Note

---

Modifying certificates stored on the computer requires administrative privileges.

---

## Getting a Certificate's Thumbprint

Step	Action
1	<p>View certificates in the MMC snap-in:</p> <ol style="list-style-type: none"> <li>Open a Command prompt window</li> <li>Type <b>mmc</b> and press <b>Enter</b>. You must have Administrator privileges to view certificates.</li> <li>On the <b>File</b> menu, click <b>Add/Remove Snap In</b>. Click <b>Add</b>.</li> <li>In the <b>Add Standalone Snap-in</b> dialog box, select <b>Certificates</b>. Click <b>Add</b>.</li> <li>In the Certificates snap-in dialog box, select <b>Computer account</b> and click <b>Next</b>. Optionally, you can select <b>My User account</b> or <b>Service account</b>. If you are not an administrator of the computer, you can manage certificates only for your user account.</li> <li>In the <b>Select Computer</b> dialog box, click <b>Finish</b>.</li> <li>In the <b>Add Standalone Snap-in</b> dialog box, click <b>Close</b>.</li> <li>On the <b>Add/Remove Snap-in</b> dialog box, click <b>OK</b>.</li> <li>In the <b>Console Root</b> window, click <b>Certificates (Local Computer)</b> to view the certificate stores for the computer.</li> <li>(Optional.) To view certificates for your account, repeat steps 3 to 6. In step 7, instead of selecting <b>Computer account</b>, click <b>My User account</b> and repeat steps h to j.</li> <li>(Optional.) On the <b>File</b> menu, click <b>Save</b> or <b>Save As</b>. Save the console file for later reuse.</li> </ol>
2	<p>Retrieving a certificate's thumbprint:</p> <ol style="list-style-type: none"> <li>Open the Microsoft Management Console (MMC) snap-in for certificates.</li> <li>In the <b>Console Root</b> window's left pane, click <b>Certificates (Local Computer)</b>.</li> <li>Click the <b>Personal</b> folder to expand it.</li> <li>Click the <b>Certificates</b> folder to expand it.</li> <li>In the list of certificates, note the <b>Intended Purposes</b> heading. Find a certificate that lists <b>Client Authentication</b> as an intended purpose. Double click the certificate.</li> <li>In the <b>Certificate</b> dialog box, click the <b>Details</b> tab.</li> <li>Scroll through the list of fields and click <b>Thumbprint</b>.</li> <li>Copy the thumbprint of the certificate into a text editor, such as Notepad.</li> <li>Remove all spaces between the hexadecimal characters. (One way to accomplish this is to use the text editor's find-and-replace feature and replace each space with a null character.)</li> <li>In Windows Server 2003 or Windows XP, use the HttpCfg.exe tool in "set" mode on the Secure Sockets Layer (SSL) store to bind the certificate to a port number. The tool uses the thumbprint to identify the certificate, as shown in the following example: <pre>httpcfg set ssl -i 0.0.0.0:8801 -h 0000000000003ed9cd0c315bbb6dc1c08da5e6</pre> </li> <li>In Windows Vista, use the Netsh.exe tool, as shown in the following example:</li> </ol>

```
netsh http add sslcert ipport=0.0.0.0:8801  
certhash=0000000000003ed9cd0c315bbb6dc1c08da5e6 appid={00112233-4455-6677-  
8899-AABBCCDDEEFF}
```

---

- End -

---

### Binding an SSL certificate to a port number and support client certificates

- In Windows Server 2003, Server 2008 or Windows XP, to support clients that authenticate with X.509 certificates at the transport layer, follow the preceding procedure but pass an additional command-line parameter to HttpCfg.exe, as shown in the following example:

```
httpcfg set ssl -i 0.0.0.0:8801 -h 0000000000003ed9cd0c315bbb6dc1c08da5e6 -f 2
```

- In Windows 7, to support clients that authenticate with X.509 certificates at the transport layer, follow the preceding procedure, but with an additional parameter, as shown in the following example:

```
netsh http add sslcert ipport=0.0.0.0:8801  
certhash=0000000000003ed9cd0c315bbb6dc1c08da5e6  
appid={00112233-4455-6677-8899-AABBCCDDEEFF} clientcertnegotiation=enable
```