



200-12-7-16

Form No. 1.

Karachi, 31<sup>th</sup> October 1916.

NOTICE UNDER SECTION 96 OF ACT III OF 1901.

To

THE CHIEF OFFICER AND CHIEF ENGINEER,  
KARACHI MUNICIPALITY.

SIR,

I beg to inform you that I intend building

Godown  
on plot No. 1

Survey Sheet No. C 1 situate in

Bunder

Street, Muchee Mianee Quarter.

As required by the rules of the Municipality, I beg to submit herewith a  
plan of the same for your approval.

I beg to remain,

Sir,

Your most obedient servant,

Edulji Dhanani

Signature of the applicant.

No. G. 12085 of 1916

MUNICIPAL CHIEF OFFICER AND  
CHIEF ENGINEER'S OFFICE,

Karachi, 31/10/16 1916

Forwarded to the Municipal Engineer for favour of disposal.

Tamangin

M. INST. C. E.

Mr Chief Officer and Chief Engineer,  
Karachi Municipality

Mr Benjamin  
Sanu to H.O.  
31/10/16



X-1-2

2

No. E. 9383 of 1916

MUNICIPAL ENGINEER'S OFFICE.

Karachi, 31st October 1916.

MEMO.

The above application is forwarded to the Municipal Health Officer for favour of report.

*Liassimali Zulung*

A. M. I. C. E.,

for Engineer,

Karachi Municipality.

MUNICIPAL HEALTH OFFICER'S REPORT.

Returned to the Engineer, Karachi Municipality, with the following remarks:—

*No objection*

*John H. (London)*

D. P. H. (London),

Health Officer,

Karachi Municipality.

Date 2-11-1916

No. E. 9383 of 1916

MUNICIPAL ENGINEER'S OFFICE.

Date 31/11/16 191

Forwarded to the Building Surveyor for report

*Clarance*

A. M. I. C. E.,

for Engineer,

Karachi Municipality.

Through

THE LAND SURVEYOR,

Karachi Municipality.



X-1-3

3

## BUILDING SURVEYOR'S REPORT.

Applicant's name

Eongue Dindaw

Whether he is the owner of the plot on which it is proposed to build

Ys

Plot under whose control

Govt.

Whether it is permanent or temporary

Permanent

The work proposed

Add additional rooms

Building Surveyor's report

Sir,

They report that the block plan  
Does not show <sup>well</sup> the surroundings of  
the plot.

Date

3/11

1916.

Building Surveyor.

Submitted through the Land Surveyor

## LAND SURVEYOR'S REPORT.

Does the plot come under Alignment

No

Area of plot

Area under Alignment

Remarks

Sir, With reference to this they report  
that if the length were 3000m <sup>or</sup> ~~or~~ it will  
block the air height of the present  
position, which is too deep. The plan is not  
properly shown.

Date

8-11

1916.

Land Surveyor.

## ORDERS OF THE ENGINEER.

Shows on ground.  
1.9/11/16

11/11

of 191 .

MUNICIPAL ENGINEER'S OFFICE

Karachi

22nd

191

Submitted to the Managing Committee with a recommendation that the plan be approved,

Franks

*J. A. L. Kirby*  
A. M. I. C. E.,

A. M. I. C. E.

Engineer,

Karachi Municipality.

Through

through

The CHIEF OFFICER & CHIEF ENGINEER.

KARACHI MUNICIPALITY.

## RESOLUTION OF THE MANAGING COMMITTEE.

Resolution No. \_\_\_\_\_ dated \_\_\_\_\_



X-2

No. E

2442

of 1917.

Municipal Office.

Karachi. 27th March 1917.

MEMO / -

With reference to his application dated 13th inst. with plans for plot No. 126, G-4 Sadar Bazar Quarter Mr: Suleman Umer is informed that the internal rooms will be devoid of air and light. The W.Cs do not comply with the bye laws. The front external walls must be packa built. The open space shown on the plan is quite inadequate for a four storied building. The plan is disapproved and herewith returned for amendment.

A. M. Inst. C. E.,

E n g i n e e r

Karachi Municipality.

9