



Heritage

KMR.CDD.ArQ.1939.01

Office Telephone Nos. 2805, 2806 &amp; 2807.

F. M. I. KURESHI

B. Sc. Engineering (Edin.)

LAND MANAGER &amp; ARCHITECT

MUNICIPAL CORPORATION,  
KARACHI.

1000-1-39.

APR 26 1939

Reference No. L. C. P.

To, Naraindas M. Gidwani, Architect,  
K a r a c h i.

Dear Sir,

With reference to your application dated 30th March 1939  
with a plan for the proposed buildings/additions and alterations on plot  
No. 17 Survey Sheet No. A.M.2 Artillery Quarter,  
I have to request you to comply with the following requirements:—

Health Officer's objections.

1. W.C. and bath are against rules.

Sub-Engineer's objections.

2. W.C. marked 'X' over the shop is against the rules.
3. Two drainage connections cannot be allowed for one plot.
4. Health Officer's objections to be complied with.

Land Manager & Architect's objections.

- Stamps*
5. It is not understood why the Architect over and over submits a plan for third floor when he knows fully well that it is not allowed.
  6. Build up area should be checked with Building Surveyor.
  7. W.C. marked 'X' would be against rules.
  8. Loft area should be ~~built~~ to 1/3rd area of shops
  9. The Architect must sign the plan.

*Ho*  
*2/5*  
The plans are returned herewith rejected.

Yours faithfully,

J.21.4/-

*On my*  
Land Manager & Architect.

F. M. I. KURESHI

B. Sc. Engineering (Edin.)

LAND MANAGER & ARCHITECT



MUNICIPAL CORPORATION,  
KARACHI.

1- JUN 1939

Reference No. L. C. P. 48/36.

To, Mr N.M. Gidwani, Architect,

For owner, KARACHI.

Dear Sir,

With reference to your application dated 5th May 1939  
with a plan for the proposed buildings/additions and alterations on plot  
No. 17 Survey Sheet No. A.M.2, Artillery Maidan Quarter,  
I have to request you to comply with the following requirements —

C.O.'s objection.

- 1 Building will be dark. ~~Plans should not be approved.~~

H.O.'s objection

- 2 Objection No.1 dated 26th April 1939 stands.

S.E.'s objections.

- 3 Only one drainage connection can be easily made  
along 40 ft. road as per originally approved plan by  
shifting the U.G. Tank.  
4 ~~Health~~ Health Officer's objection to be complied with  
first.  
5 Chief Officer's ~~obj~~ permission for W.C. marked 'X'  
on 1st floor coming over the shop may please be obtained.

L.M. & A's objections.

- 6 As regards No.5 of 26th April 1939 the Architect  
should produce the letter.  
7 No.6 - He can see the Building Surveyor on any  
working day between 3 and 4 p.m.  
8 No. 7 and 8 stand.

*RS*  
*F.C. sent letter 14/5*

The plans are returned herewith rejected.

Yours faithfully,

*Dr 31/5*

Land Manager & Architect.