

252
26/2

1-1

200-30-9-18.

From No. 1.

Karachi, 15 Feb. 1919.

NOTICE UNDER SECTION 96 OF ACT III OF 1901.

To

THE CHIEF OFFICER AND CHIEF ENGINEER,
KARACHI MUNICIPALITY.

SIR,

I beg to inform you that I intend building a house
on plot No. 2249226Survey Sheet No. A-18 situate in Sye Ellapa
Da Street, Napier Quarter.As required by the rules of the Municipality, I beg to submit herewith a
plan of the same for your approval.


I beg to remain,

Sir,

Your most obedient servant,

Address:—

Signature of the applicant.



No. G. 1916 of 1919.

MUNICIPAL CHIEF OFFICER AND

CHIEF ENGINEER'S OFFICE,

Karachi, 20 Feb. 1919.

Forwarded to the Municipal Engineer for favour of disposal.

Jethanand
M. INST. C. E.,
Chief Officer and Chief Engineer,
Karachi Municipality.Mr. Benja
20/2/19

54060



No. E 833 of 191

MUNICIPAL ENGINEER'S OFFICE,
Karachi, 20th Feb. 1919.

Memo.

The above application is forwarded to the Municipal Health Officer for
favour of report.

[Signature]

A.M.I.C.E.,
Engineer,
Karachi Municipality.

MUNICIPAL HEALTH OFFICER'S REPORT.

Returned to the Engineer, Karachi Municipality, with the following
remarks:—

*The plot is too small to
have a living room with all
sanitary conveniences on one story*

[Signature]

D.P.H. (London),
Health Officer,
Karachi Municipality.

Date 26-2-1919

No. E 833 of 191 9

MUNICIPAL ENGINEER'S OFFICE,
Karachi, 26th Feb 1919

Forwarded to the Building Surveyor for report.

[Signature]

A.M.I.C.E.,
For Engineer,
Karachi Municipality

Through

THE LAND SURVEYOR,
Karachi Municipality.

Mr. V. ... 8/2 2/2



BUILDING SURVEYOR'S REPORT.

Applicant's name Gandha Neunaj
 Whether he is the owner of the plot on which it is proposed to build Yes.
 Plot under whose control Government
 Whether it is permanent or temporary Permanent.
 The work proposed To build a house.

Building Surveyor's Report Sir, With reference to this I beg
to report that no arrangement of draining & water is shown
The plot is too small for having a shop & a house.

Date 1/3/ 1919.

J. V. V. V.
Building Surveyor.

Submitted through the Land Surveyor.

LAND SURVEYOR'S REPORT.

Does the plot come under Alignment No

Area of plot

Area under Alignment

Remarks Sir, Portion taken acquired out of plot No. 22
A 28. Napi & there was Collector's order the
convenience to be kept on the ground floor.
but nothing has been done. Request your order.
Yours truly
Nathu

Date 4-3 1919.

Land Surveyor.

ORDER OF THE ENGINEER.

Land Surveyor why is the whole of the plot not attached?
Attach it at once & see up with drawing sheet.

22 V. V. V.
4/3

Reply that the plot is too small on which
to erect a sanitary building. The plan
is disapproved.

A.M. INST. C.E.,

Engineer,

Karachi Municipality.



4

No. E. of 191 .

MUNICIPAL ENGINEER'S OFFICE,

Karachi, _____ 191 .

Submitted to the Managing Committee for information.

A.M.I.C.E.,

Engineer,

Karachi Municipality.

Through

THE CHIEF OFFICER & CHIEF ENGINEE,

Karachi Municipality.

RESOLUTION OF THE MANAGING COMMITTEE.

Resolution No. _____ dated _____

No. L.S. 1880 of 1919.

Municipal Office,

Karachi, 17th April 1919.

M E M O

Key plan

With reference to her application dated 31st ultimo with plans for the proposed building on plot No. 53 A.20 Napier Quarter Mai Lalibai widow of Liloomal is informed that the plot is too small and the sanitary conveniences on 1st floor cannot be allowed.

Rain water drain should be shown from the air-well.

The air-well should be paved.

The plan is returned herewith for amendment.

Sis

This may be filed

28/11/20

Key

For Engineer

Karachi Municipality.

18/4/19


Memo.

With reference to her appreciation
of 31st ultimo ~~re~~ with plan for the
proposed building on Plot No 53 A20
Napier R^y mai Lalitabaidlow of Libromal
is informed that the plot is too ~~small~~
and the Sanitary Conveniences on 1st
floor cannot be allowed.

Rainwater drain should be shown
from the air well.

The airwell should be paved.

The plan is returned herewith for amend-
ment.


A.M. Inst., C.E.
Engineer
Karachi Municipal

37

To,

The Chief Officer & Chief Engineer.
Karachi MunicipalityMr. Waswani for work
ComplimentNathu
9/24/19

731
3/4

5-1

200-30-9-18.

From No. 1.

Karachi, 31st March 1919.

NOTICE UNDER SECTION 96 OF ACT III OF 1901.

To

THE CHIEF OFFICER AND CHIEF ENGINEER,
KARACHI MUNICIPALITY.

SIR,

I beg to inform you that I intend building a house
on plot No. 53Survey Sheet No. A-20 situate in Quornal
Street, Mafice Quarter.As required by the rules of the Municipality, I beg to submit herewith a
plan of the same for your approval.

I beg to remain,

Sir,

Address:—

Your most obedient servant,

G. Mark F. Lali

Signature of the applicant.

No. G. 348 of 1919.

MUNICIPAL CHIEF OFFICER AND

CHIEF ENGINEER'S OFFICE,

Karachi, 31st March 1919.

Forwarded to the Municipal Engineer for favour of disposal.

J. H. M. A. M.

M. INST. C. E.,

Chief Officer and Chief Engineer,
Karachi Municipality.In Benja
sent to Ho
4
1/19
211



5-2
No. E ² 1625 of 1919.

MUNICIPAL ENGINEER'S OFFICE,
Karachi, 1st April 1919.

Memo.

The above application is forwarded to the Municipal Health Officer for favour of report.

Summers

A.M.I.C.E.,

Engineer,
Karachi Municipality.

MUNICIPAL HEALTH OFFICER'S REPORT.

Returned to the Engineer, Karachi Municipality, with the following remarks:—

Plot is too small to have a room with sanitary conveniences on each floor. There should be a sewer's passage provided to carry out open drains at the rear

No objection
30/4/19

[Signature]
D.P.H. (London),
Health Officer,
Karachi Municipality.

Date 3-4-1919.

No. E 1625 of 1919.

MUNICIPAL ENGINEER'S OFFICE,
Karachi, 3rd April 1919

Forwarded to the Building Surveyor for report.

[Signature]
A.M.I.C.E.,

Engineer,
Karachi Municipality

Through

THE LAND SURVEYOR,
Karachi Municipality.

Mr. Vernon
for report
4/4/19



BUILDING SURVEYOR'S REPORT.

Applicant's name Lalibai widow of Lalomal
 Whether she is the owner of the plot on which it is proposed to build Yes
 Plot under whose control Government
 Whether it is permanent or temporary Permanent
 The work proposed A house

Building Surveyor's Report Sir, With reference to this I beg to
 report that kitchen under staircase on ground floor
 is objectionable. The plot is too narrow to have
 Sanitary Conveniences on ground floor or floor.
 Rain water drain from air well should be shown.
 The air well to be shown paved.

Date 8/4/ 1919.

J. S. Ghosh
 Building Surveyor.

Submitted through the Land Surveyor.

LAND SURVEYOR'S REPORT.

Does the plot come under Alignment alignment has
already acquired.

Area of plot —

Area under Alignment —

Remarks Sir, With reference to this I beg to report
 if the partition wall on the 1st floor is shown
 removed - before the plan can be considered the
 WC & bath also should be removed from the
 1st floor & should be located on the ground floor of
Gonzalez

Date 8-4- 1919.

J. S. Ghosh
 Land Surveyor.

ORDER OF THE ENGINEER.

A.M. INST. C.E.,

Engineer,
 Karachi Municipality.



4

No. E. of 191

MUNICIPAL ENGINEER'S OFFICE,

Karachi, _____ 191

Submitted to the Managing Committee for information.

A.M.I.C.E.,

Engineer,

Karachi Municipality.

Through

THE CHIEF OFFICER & CHIEF ENGINEE,

Karachi Municipality.

RESOLUTION OF THE MANAGING COMMITTEE.

Resolution No. _____ dated _____

Memo. ~~Re plan~~

6/3/19

With reference to ^{their} ~~his~~ application
with plan of 20th ultimo, with plan for the
proposed house on plots No. 22 A & 22 B.

At 28 Napier Quarter, Messrs. Mulehand
Godhanda & Eulhanda Meeray are
informed that the plot is too small
which to erect a sanitary building.
The plan is disapproved.

J. Cent. L. Verby.

A.M.Inst.,

Eng.

Karachi.

This may be filed

28/11/20

12

PLAN OF PROPOSED BUILDING.

ON PLOT N^os 22A & 22B - A.28.

NAPIER Q^{TR}.

SCALE 8"=1."

M. Arzauth

B.A; L.C.E

ARCHITECT & SURVEYOR.
KARACHI.

*Mulchand Das &
Co. Karachi*

BLOCK PLAN

SCALE 20"=1"




ELEVATION.

SECTION ON A.B.



SYEE ELLAPA ROAD
M. DRAIN.
ABOUT 25 WIDE.

PLAN OF GROUND FLOOR.



PLAN OF 1ST FLOOR.