

# TOWN OF DUNDEE

## RFP# 18-05 – Road Resurfacing and Milling Services

### QUESTIONS FROM VENDORS

1. In Section 1.01 “Work by Contractor”, will the Town consider changing the requirement from 1” S-III asphalt to 1” SP 9.5 TLC (20% RCA content)?
  - a. *ANSWER: Yes. This would be an appropriate substitution*
2. The RFP requires that striping occur on all streets named, does the town want all streets striped, Dbl Yellow Center Line, with edge lines, and pavement markers?
  - a. *ANSWER: Yes. Per Section 1.01 Part 1*
3. Is the striping one coat of paint, two coats of paint, or one coat of paint/one coat of thermoplastic?
  - a. *ANSWER: Dawn Drive = Two Coats of Paint; Ridgewood & Race Road = Thermoplastic*
4. Does the Town want Stop Bars at Dawn Dr?
  - a. *ANSWER: Yes.*
5. Will the Town consider deleting Section 38 titled “Lines and Grades” as Milling and Surfacing already exists?
  - a. *ANSWER: Yes. However, the requirement to re-establish survey monumentation is retained.*
6. Will the Town consider allowing an asphalt plant to conduct their own testing instead of requiring the vendor to hire an independent laboratory to test the asphalt?
  - a. *ANSWER: No. However, core sampling should be avoided; Testing should occur by an independent laboratory at the time of asphalt laying and prior to rolling.*
7. Will the Town consider milling 1” on Ridgewood Drive and pave back 1.5” SP 12.5?
  - a. *ANSWER: Yes. In consideration of the likelihood of future development on Ridgewood AND RACE ROAD, both should be bid as 1.5” of SP 12.5*
8. Is the meeting of the Purchasing Review Committee on January 21, 2019 at 10:00 AM open to the public?
  - a. *ANSWER: Yes. All meetings of the Purchasing Review Committee are open to the public. It is up to the professional discretion of the vendors if they choose to be in the room while bids are read.*
9. Is the Town going to supply a bid bond form?
  - a. *ANSWER: The Town does not have a bid bond form. We suggest each vendor submit an industry standard type bid form.*

10. The Bid Form states "Return Date: Friday, December 7, 2018 – 4:30PM". Do we utilize this form even though the return date is incorrect?
  - a. *ANSWER: Applications submitted with the incorrect form date will be accepted by the Purchasing Review Committee without penalty. An amended version of the bid form has been added to the Town's purchasing website for applicants to use if they so wish.*
  
11. Will the Town of Dundee be providing an aerial of Location 1 – Street between Lake Marie Drive and SR 17 (approx.. 0.1) W 20+ -- no curb?
  - a. *ANSWER: Location 1 has been removed from consideration. Applicants should not include Location 1 in their bids.*
  
12. The RFP states the Ridgewood Ave is 24 linear feet wide. The road varies from approximately 18 linear feet to approximately 20 linear feet wide. Is the contractor milling and resurfacing only the existing asphalt?
  - a. *ANSWER: Contractors are expected to widen to 20' pavement in all areas and have 2' stabilized shoulders on each side.*
  
13. The RFP states that Dawn Drive is .25 miles long (1,320 linear feet). We measured the road length at approximately 417 linear feet long. Which is correct?
  - a. *ANSWER: Dawn Drive is approximately 0.08 miles long (415').*
  
14. With Regards to Race Road, does the paving limits at the north end start at the right-of-way line or the edge of pavement at SR 17?
  - a. *ANSWER: The paving limits begin at the right-of-way line.*
  
15. Monday, January 21<sup>st</sup> is Martin Luther King Jr. Day, will this affect the Purchasing Review Committee's unsealing of the bids?
  - a. *ANSWER: Yes. The Purchasing Review Committee meeting originally scheduled for Monday January 21, 2019 has been rescheduled for Friday, January 18 at 12:00 PM.*