

TOWN OF DUNDEE

RFP# 18-05 – Road Resurfacing and Milling Services

QUESTIONS FROM VENDORS – 3rd Set

1. Does the Town want the 2' stabilized shoulder sodded?
 - a. *ANSWER: All disturbed areas, including stabilized shoulders, should be restored with sod AT OR BELOW the grade of the edge of pavement so as not to impede drainage.*