CITYMULTI®

26-TON PQRY-P312TSLMU-A2

MITSUBISHI ELECTRIC
HEATING & AIR CONDITIONING

Job Name:

System Reference: Date:

208/230V MODULAR WATER-SOURCE VRF HEAT PUMP SYSTEM



ACCESSORIES

- ☐ 1.5” EPIV Valve (One Piece)* EV150S396NRXME
- ☐ Transformer 50VA (One Piece)** TR50VA015
- ☐ 1.5” Temp sensor, optional (One Piece)** ..... ZM-TW150NPT KIT
- ☐ Optical Relay for Flow Switch (One Piece)* RIBTE24B
- ☑ Twinning Kit (Required) CMY-Q200CBK
- ☑ BC Controller (Required) ..... for details see BC Controller Submittals
- ☐ Joint Kit ..... for details see Pipe Accessories Submittal

*Requires two EPIV valves
*Requires two optical relays
**Requires four transformers
**Requires four temp sensors per two EPIV valves if optional temp sensors are used.

Specifications			System
Unit Type			PQRY-P312TSLMU-A2
Cooling Capacity (Nominal)		BTU/H	312,000
Heating Capacity (Nominal)		BTU/H	350,000
Net Weight		Lbs. [kg]	940 [426]
Refrigerant Piping Diameter (From Twinning Kit to First Joint or Header)	Liquid (High Pressure)	In. [mm]	1-1/8 [28.58] Brazed
	Gas (Low Pressure)	In. [mm]	1-3/8 [34.93] Brazed
Max. Total Refrigerant Line Length		Ft.	2,460
Max. Refrigerant Line Length (Between ODU & IDU)		Ft.	541
Max. Control Wiring Length		Ft.	1,640
Indoor Unit Connectable	Total Capacity		50.0~150.0% of heatsource unit capacity
	Model/Quantity		P04~P96/2.0~50.0
Sound Power Level		dB(A)	72.5
Compressor Operating Range			9.0% to 100.0%
AHRI Ratings (Ducted/Non-ducted)	EER		11.2/12.7
	IEER		16.7/17.8
	COP		4.87/5.35
	SCHE		19.7/19.0

Specifications			Module 1	Module 2
Unit Type			PQRY-P168TLMU-A2	PQRY-P144TLMU-A2
Cooling Capacity (Nominal)		BTU/H	168,000	144,000
Heating Capacity (Nominal)		BTU/H	188,000	160,000
Operating Temperature Range	Cooling (Indoor)	°F WB [°C WB]	59~75 [15.0~ 24.0]	59~75 [15.0~ 24.0]
	Heating (Indoor)	°F DB [°C DB]	59~81 [15.0~27.0]	59~81 [15.0~27.0]
Operating Water Temperature Range[1]	Cooling/Heating	°F [°C]	50~113.0 [10~45.0]	50~113.0 [10~45.0]
External Dimensions (H x W x D)		In. [mm]	57-1/8 x 34-11/16 x 21-11/16 [1,450 x 880 x 550]	57-1/8 x 34-11/16 x 21-11/16 [1,450 x 880 x 550]
Net Weight		Lbs. [kg]	481 [218]	481 [218]
External Finish			Galvanized steel sheets	Galvanized steel sheets
Electrical Power Requirements	Voltage, Phase, Hertz, Power Tolerance		208/230, 3, 60, ±10	208/230, 3, 60, ±10
Minimum Circuit Ampacity		A	50.0/48.0	40.0/40.0
Maximum Overcurrent Protection		A	90/80	70/70
SCCR		kA	5	5
Flow Rate		G/min [gpm]	31.7	31.7
		L/min	120	120
Pressure Drop		psi	6.38	6.38
		Ft.	14.7	14.7
Operation Volume Range		G/min [gpm]	19.8~50.9	19.8~50.9
		m3/h	4.5~11.6	4.5~11.6
Refrigerant Piping Diameter (From Twinning Kit)	Liquid (High Pressure)	In. [mm]	7/8 [22.2] Brazed	7/8 [22.2] Brazed
	Gas (Low Pressure)	In. [mm]	1-1/8 [28.58] Brazed	1-1/8 [28.58] Brazed
Compressor	Type x Quantity		Inverter scroll hermetic x 1	Inverter scroll hermetic x 1
Compressor Motor Output		kW	11.0	9.5
Refrigerant	Type x Original Charge		R410A x 13.0 lbs. + 4.0oz. [6.0 kg]	R410A x 13.0 lbs. + 4.0oz. [6.0 kg]
Lubricant	Lubricant	Lubricant	MEL32	MEL32
Protection Devices	High Pressure Protection	High Pressure Protection	High pressure sensor, High pressure switch at 4.15 Mpa (601 psi)	High pressure sensor, High pressure switch at 4.15 Mpa (601 psi)
	Inverter Circuit	Inverter Circuit	Over-heat protection, Over-current protection	Over-heat protection, Over-current protection
	Compressor	Compressor	Over-heat protection	Over-heat protection


NOTES:
[1]23°F EWT (Entering water temperature) is possible with glycol.
Each individual module requires a separate electrical connection. Refer to electrical data for each individual module.

Specifications are subject to change without notice.

© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

OUTDOOR UNIT: PQRY-P312TSLMU-A2 – DIMENSIONS

Unit: mm(in)



Note 1.Connect the pipes as shown in the figure above. Refer to the table below for the pipe size.
2.Twinning pipe (High pressure) must be installed horizontally using a level vessel.
3.See the Installation Manual for the details of Twinning pipe installation.
4.Only use the Twinning pipe by Mitsubishi (optional parts).
5.Connect the heat source unit 1 with the Twinning pipe (Low pressure) (section "d" in the figure).

Twinning pipe connection size

Package unit name			PQRY-P288TSLMU-A2	PQRY-P312TSLMU-A2	PQRY-P336TSLMU-A2
Component unit name	Heat Source unit 1		PQRY-P144TLMU-A2	PQRY-P168TLMU-A2	PQRY-P168TLMU-A2
	Heat Source unit 2		PQRY-P144TLMU-A2	PQRY-P144TLMU-A2	PQRY-P168TLMU-A2
Twinning Kit(optional parts)			CMY-Q200CBK		
BC controller~Twinning pipe	High pressure	a	ø28.58(1-1/8)		
	Low pressure	b	ø34.93(1-3/8)		ø41.28(1-5/8)
Twinning pipe~ Heat source unit 1	High pressure	c	ø22.2(7/8)		
	Low pressure	d	- (Note 5)		
Twinning pipe~ Heat source unit 2	High pressure	e	ø22.2(7/8)		
	Low pressure	f	ø28.58(1-1/8)		

Specifications are subject to change without notice.

© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

MODULE 1: PQRY-P168TLMU-A2 – DIMENSIONS

Note1.Close a hole of the water piping, the refrigerant piping, the power supply, and the control wiring and unused knockout holes with the putty etc. so as not to infiltrate rain water etc.(field erection work)
Note2.At the time of product shipment, the front side piping specification serves as the local drainage connection. When connecting on the rear side, please remove the rear side plug sealing corks, and attach a front side. Ensure there is no leak after the attachment has been fitted.
Note3.Take notice of service space as Fig.A. (In case of single installation, 600mm(23-5/8) or more of back space as front space makes easier access when servicing the unit from rear side.)
Note4.If water pipes or refrigerant pipes stretch upward, required space for service and maintenance due to replacement of control box is shown in Fig.B.
Note5.Environmental condition for installation; -20~40°C(DB)(-4~104°F) as indoor installation.
Note6.In case the temperature around the heat source unit has possibility to drop under 0°C(32°F), be careful for the following point to prevent the pipe burst by the water pipe freeze-up.
•Circulate the water all the time even if the heat source unit is not in operation.
•Drain the water from inside of the heat source unit when the heat source unit will not operate for a long term.
Note7.Ensure that the drain piping is downward with a pitch of more than 1/100.
Note8.At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C(248°F).





Fig.A Fig.B


Connecting pipe specifications

Model	Diameter			
	Refrigerant pipe		Service valve	
	High pressure	Low pressure	High pressure	Low pressure
PQRY-P144TLMU-A2	ø22.2 Brazed (7/8) *1	ø28.58 Brazed (1-1/8) *1	ø25.4 (1)	ø28.58 (1-1/8)
PQRY-P168TLMU-A2				
PQRY-P192TLMU-A2				


*1.Connect by using the connecting pipes that are supplied.



Top view




Front view



Bottom view

<Accessories (Packaged in the accessory kit)>
- Refrigerant (high pressure) conn. pipe ····· 1pc.
- Refrigerant (low pressure) conn. pipe ····· 1pc.
- Water stopper ····· 1pc.
- Sealing material for water stopper ····· 1pc.
- Sealing material for field piping (high pressure, low pressure) ····· 1pc. each
- Sealing material for drain socket ····· 1pc.
- Pipe cover for low pressure ····· 1pc.
- Sealing material for base leg (two types) ····· 4pcs.each
- Sealing material for panel ····· 1pc.

Unit: mm(in)



Right side view Back view

NO.	Usage		Specifications
①	For pipes	Front through hole	140 × 77 Knockout hole (5-9/16) (3-1/16)
②		Front through hole (Uses when twinning kit (optional parts) is mounted.)	ø45 Knockout hole (1-13/16)
③	For wires	Front through hole	ø62.7 or ø34.5 Knockout hole (2-1/2) (1-3/8)
④		Front through hole	ø43.7 or ø22.2 Knockout hole (1-3/4) (7/8)
⑤	For transmission cables	Front through hole	ø34 Knockout hole (1-3/8)
⑥	Water pipe	inlet	NPT1-1/2 Screw
⑦		outlet	NPT1-1/2 Screw
⑧	Drain pipe	Rc3/4 Screw	

Specifications are subject to change without notice.
© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

MODULE 2: PQRY-P144TLMU-A2 – DIMENSIONS

Note1.Close a hole of the water piping, the refrigerant piping, the power supply, and the control wiring and unused knockout holes with the putty etc. so as not to infiltrate rain water etc.(field erection work)
Note2.At the time of product shipment, the front side piping specification serves as the local drainage connection. When connecting on the rear side, please remove the rear side plug sealing corks, and attach a front side. Ensure there is no leak after the attachment has been fitted.
Note3.Take notice of service space as Fig.A. (In case of single installation, 600mm(23-5/8) or more of back space as front space makes easier access when servicing the unit from rear side.)
Note4.If water pipes or refrigerant pipes stretch upward, required space for service and maintenance due to replacement of control box is shown in Fig.B.
Note5.Environmental condition for installation; -20~40°C(DB)(-4~104°F) as indoor installation.
Note6.In case the temperature around the heat source unit has possibility to drop under 0°C(32°F), be careful for the following point to prevent the pipe burst by the water pipe freeze-up.
•Circulate the water all the time even if the heat source unit is not in operation.
•Drain the water from inside of the heat source unit when the heat source unit will not operate for a long term.
Note7.Ensure that the drain piping is downward with a pitch of more than 1/100.
Note8.At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C(248°F).





Fig.A Fig.B


Connecting pipe specifications

Model	Diameter			
	Refrigerant pipe		Service valve	
	High pressure	Low pressure	High pressure	Low pressure
PQRY-P144TLMU-A2	ø22.2 Brazed (7/8) *1	ø28.58 Brazed (1-1/8) *1	ø25.4 (1)	ø28.58 (1-1/8)
PQRY-P168TLMU-A2				
PQRY-P192TLMU-A2				


*1.Connect by using the connecting pipes that are supplied.



Top view




Front view



Bottom view

<Accessories (Packaged in the accessory kit)>
- Refrigerant (high pressure) conn. pipe ····· 1pc.
- Refrigerant (low pressure) conn. pipe ····· 1pc.
- Water stopper ····· 1pc.
- Sealing material for water stopper ····· 1pc.
- Sealing material for field piping (high pressure, low pressure) ····· 1pc. each
- Sealing material for drain socket ····· 1pc.
- Pipe cover for low pressure ····· 1pc.
- Sealing material for base leg (two types) ····· 4pcs.each
- Sealing material for panel ····· 1pc.

Unit: mm(in)



Right side view Back view


NO.	Usage		Specifications
①	For pipes	Front through hole	140 × 77 Knockout hole (5-9/16) (3-1/16)
②		Front through hole (Uses when twinning kit (optional parts) is mounted.)	ø45 Knockout hole (1-13/16)
③	For wires	Front through hole	ø62.7 or ø34.5 Knockout hole (2-1/2) (1-3/8)
④		Front through hole	ø43.7 or ø22.2 Knockout hole (1-3/4) (7/8)
⑤	For transmission cables	Front through hole	ø34 Knockout hole (1-3/8)
⑥	Water pipe	inlet	NPT1-1/2 Screw
⑦		outlet	NPT1-1/2 Screw
⑧	Drain pipe	Rc3/4 Screw	

Specifications are subject to change without notice.
© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.


TWINNING KIT: CMY-Q200CBK – DIMENSIONS

CMY-Q200CBK


Low-pressure pipe twinning kit



<Elbow pipe(Accessory)>



<Pipe for routing through the front (Accessory)>





<Accessory>

Fixing screw	• • • 1
Insulation cover	• • • 1
Pipe cover (75mm(3) Length)	• • • 1
Pipe cover (360mm(14-3/16) Length)	• • • 1
Pipe cover (70mm(2-13/16) Length)	• • • 1
Pipe cover (130mm(5-1/8) Length)	• • • 1
Pipe cover (100mm(3-15/16) Length)	• • • 1
Pipe cover (160mm(6-5/16) Length)	• • • 1
Cable tie	• • • 2
Water stopper	• • • 1
Sealing material (Small)	• • • 1
Sealing material (Large)	• • • 1


High-pressure twinning pipe

<Deformed pipe(Accessory)>






<Pipe for routing through the front (Accessory)>



Note 1. Refer to the figure below for the installation position of the high-pressure twinning pipe.



Inclination tolerance of the high-pressure twinning pipe is ±15° relative to the ground.

2. Pipe diameter is indicated by inside diameter.

1340 Satellite Boulevard Suwanee, GA 30024
Toll Free: 800-433-4822 www.mehvac.com