CITYMULTI®

# 28-TON PQRY-P336YSLMU-A2

MITSUBISHI ELECTRIC
HEATING & AIR CONDITIONING

Job Name:

System Reference: Date:

## 460V MODULAR WATER-SOURCE VRF HEAT PUMP SYSTEM



## ACCESSORIES

- ☐ 1.5” Temp sensor, optional (One Piece)** ..... ZM-TW150NPT KIT
- ☐ Optical Relay for Flow Switch (One Piece)* ..... RIBTE24B
- ☐ 1.5” EPIV Valve (One Piece)* ..... EV150S396NRXME
- ☐ Transformer 50VA (One Piece)** ..... TR50VA015
- ☑ Twinning Kit (Required) ..... CMY-Q200CBK
- ☑ BC Controller (Required) ..... for details see BC Controller Submittals
- ☐ Joint Kit ..... for details see Pipe Accessories Submittal

*Requires two EPIV valves
*Requires two optical relays
**Requires four transformers
**Requires four temp sensors per two EPIV valves if optional temp sensors are used.

| Specifications | | | System |
|---|---|---|---|
| Unit Type | | | PQRY-P336YSLMU-A2 |
| Cooling Capacity (Nominal) | | BTU/H | 336,000 |
| Heating Capacity (Nominal) | | BTU/H | 378,000 |
| Net Weight | | Lbs. [kg] | 994 [450] |
| Refrigerant Piping Diameter (From Twinning Kit to First Joint or Header) | Liquid (High Pressure) | In. [mm] | 1-1/8 [28.58] Brazed |
| | Gas (Low Pressure) | In. [mm] | 1-5/8 [41.28] Brazed |
| Max. Total Refrigerant Line Length | | Ft. | 2,460 |
| Max. Refrigerant Line Length (Between ODU & IDU) | | Ft. | 541 |
| Max. Control Wiring Length | | Ft. | 1,640 |
| Indoor Unit Connectable | Total Capacity | | 50.0~150.0% of heatsource unit capacity |
| | Model/Quantity | | P04~P96/2.0~50.0 |
| Sound Power Level | | dB(A) | 73.0 |
| Compressor Operating Range | | | 8.0% to 100.0% |
| AHRI Ratings (Ducted/Non-ducted) | EER | | 11.1/12.2 |
| | IEER | | 16.2/16.7 |
| | COP | | 4.74/5.34 |
| | SCHE | | 19.7/19.0 |

| Specifications | | | Module 1 | Module 2 |
|---|---|---|---|---|
| Unit Type | | | PQRY-P168YLMU-A2 | PQRY-P168YLMU-A2 |
| Cooling Capacity (Nominal) | | BTU/H | 168,000 | 168,000 |
| Heating Capacity (Nominal) | | BTU/H | 188,000 | 188,000 |
| Operating Temperature Range | Cooling (Indoor) | °F WB [°C WB] | 59~75 [ 15.0~ 24.0] | 59~75 [ 15.0~ 24.0] |
| | Heating (Indoor) | °F DB [°C DB] | 59~81 [15.0~27.0] | 59~81 [15.0~27.0] |
| Operating Water Temperature Range[1] | Cooling/Heating | °F [°C] | 50~113.0 [10~45.0] | 50~113.0 [10~45.0] |
| External Dimensions (H x W x D) | | In. [mm] | 57-1/8 x 34-11/16 x 21-11/16 [1,450 x 880 x 550] | 57-1/8 x 34-11/16 x 21-11/16 [1,450 x 880 x 550] |
| Net Weight | | Lbs. [kg] | 508 [230] | 508 [230] |
| External Finish | | | Galvanized steel sheets | Galvanized steel sheets |
| Electrical Power Requirements | Voltage, Phase, Hertz, Power Tolerance | | 460, 3, 60, ±10 | 460, 3, 60, ±10 |
| Minimum Circuit Ampacity | | A | 26.0 | 26.0 |
| Maximum Overcurrent Protection | | A | 45 | 45 |
| SCCR | | kA | 5 | 5 |
| Flow Rate | | G/min [gpm] | 31.7 | 31.7 |
| | | L/min | 120 | 120 |
| Pressure Drop | | psi | 6.38 | 6.38 |
| | | Ft. | 14.7 | 14.7 |
| Operation Volume Range | | G/min [gpm] | 19.8~50.9 | 19.8~50.9 |
| | | m3/h | 4.5~11.6 | 4.5~11.6 |
| Refrigerant Piping Diameter (From Twinning Kit) | Liquid (High Pressure) | In. [mm] | 7/8 [ 22.2] Brazed | 7/8 [ 22.2] Brazed |
| | Gas (Low Pressure) | In. [mm] | 1-1/8 [28.58] Brazed | 1-1/8 [28.58] Brazed |
| Compressor | Type x Quantity | | Inverter scroll hermetic x 1 | Inverter scroll hermetic x 1 |
| Compressor Motor Output | | kW | 11.0 | 11.0 |
| Refrigerant | Type x Original Charge | | R410A x 13.0 lbs. + 4.0oz. [6.0 kg] | R410A x 13.0 lbs. + 4.0oz. [6.0 kg] |
| Lubricant | Lubricant | Lubricant | MEL32 | MEL32 |
| Protection Devices | High Pressure Protection | High Pressure Protection | High pressure sensor, High pressure switch at 4.15 Mpa (601 psi) | High pressure sensor, High pressure switch at 4.15 Mpa (601 psi) |
| | Inverter Circuit | Inverter Circuit | Over-heat protection, Over-current protection | Over-heat protection, Over-current protection |
| | Compressor | Compressor | Over-heat protection | Over-heat protection |


NOTES:
[1]23°F EWT (Entering water temperature) is possible with glycol.
Each individual module requires a separate electrical connection. Refer to electrical data for each individual module.

Specifications are subject to change without notice.

© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

# OUTDOOR UNIT: PQRY-P336YSLMU-A2 – DIMENSIONS

Unit: mm(in)




Note 1.Connect the pipes as shown in the figure above. Refer to the table below for the pipe size.
2.Twinning pipe (High pressure) must be installed horizontally using a level vessel.
3.See the Installation Manual for the details of Twinning pipe installation.
4.Only use the Twinning pipe by Mitsubishi (optional parts).
5.Connect the heat source unit 1 with the Twinning pipe (Low pressure) (section "d" in the figure).

Twinning pipe connection size

| Package unit name | | | PQRY-P288YSLMU-A2 | PQRY-P312YSLMU-A2 | PQRY-P336YSLMU-A2 |
|---|---|---|---|---|---|
| Component unit name | Heat Source unit 1 | | PQRY-P144YLMU-A2 | PQRY-P168YLMU-A2 | PQRY-P168YLMU-A2 |
| | Heat Source unit 2 | | PQRY-P144YLMU-A2 | PQRY-P144YLMU-A2 | PQRY-P168YLMU-A2 |
| Twinning Kit(optional parts) | | | CMY-Q200CBK | | |
| BC controller~Twinning pipe | High pressure | a | ø28.58(1-1/8) | | |
| | Low pressure | b | ø34.93(1-3/8) | | ø41.28(1-5/8) |
| Twinning pipe~ Heat source unit 1 | High pressure | c | ø22.2(7/8) | | |
| | Low pressure | d | - (Note 5) | | |
| Twinning pipe~ Heat source unit 2 | High pressure | e | ø22.2(7/8) | | |
| | Low pressure | f | ø28.58(1-1/8) | | |

Specifications are subject to change without notice.

© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

# MODULE 1: PQRY-P168YLMU-A2 – DIMENSIONS

Note1. Close a hole of the water piping, the refrigerant piping, the power supply, and the control wiring and unused knockout holes with the putty etc. so as not to infiltrate rain water etc.(field erection work)
Note2. At the time of product shipment, the front side piping specification serves as the local drainage connection. When connecting on the rear side, please remove the rear side plug sealing corks, and attach a front side. Ensure there is no leak after the attachment has been fitted.
Note3. Take notice of service space as Fig.A. (In case of single installation, 600mm(23-5/8) or more of back space as front space makes easier access when servicing the unit from rear side.)
Note4. If water pipes or refrigerant pipes stretch upward, required space for service and maintenance due to replacement of control box is shown in Fig.B.
Note5. Environmental condition for installation; -20~40°C(DB)(-4~104°F) as indoor installation.
Note6. In case the temperature around the heat source unit has possibility to drop under 0°C(32°F), be careful for the following point to prevent the pipe burst by the water pipe freeze-up.
•Circulate the water all the time even if the heat source unit is not in operation.
•Drain the water from inside of the heat source unit when the heat source unit will not operate for a long term.
Note7. Ensure that the drain piping is downward with a pitch of more than 1/100.
Note8. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C(248°F).






Fig.A Fig.B


Connecting pipe specifications

| Model | Diameter | | | |
|---|---|---|---|---|
| | Refrigerant pipe | | Service valve | |
| | High pressure | Low pressure | High pressure | Low pressure |
| PQRY-P144YLMU-A2 | ø22.2 Brazed (7/8) *1 | ø28.58 Brazed (1-1/8) *1 | ø25.4 (1) | ø28.58 (1-1/8) |
| PQRY-P168YLMU-A2 | | | | |
| PQRY-P192YLMU-A2 | | | | |


*1.Connect by using the connecting pipes that are supplied.




Top view





Front view





Bottom view

<Accessories (Packaged in the accessory kit)>
- Refrigerant (high pressure) conn. pipe ····· 1pc.
- Refrigerant (low pressure) conn. pipe ····· 1pc.
- Water stopper ····· 1pc.
- Sealing material for water stopper ····· 1pc.
- Sealing material for field piping (high pressure, low pressure) ····· 1pc. each
- Sealing material for drain socket ····· 1pc.
- Pipe cover for low pressure ····· 1pc.
- Sealing material for base leg (two types) ····· 4 pcs.each
- Sealing material for panel ····· 1pc.

Unit: mm(in)




Right side view




Back view

| NO. | Usage | | Specifications |
|---|---|---|---|
| ① | For pipes | Front through hole | 140 × 77 Knockout hole (5-9/16) (3-1/16) |
| ② | | Front through hole (Uses when twinning kit (optional parts) is mounted.) | ø45 Knockout hole (1-13/16) |
| ③ | For wires | Front through hole | ø62.7 or ø34.5 Knockout hole (2-1/2) (1-3/8) |
| ④ | | Front through hole | ø43.7 or ø22.2 Knockout hole (1-3/4) (7/8) |
| ⑤ | For transmission cables | Front through hole | ø34 Knockout hole (1-3/8) |
| ⑥ | Water pipe | inlet | NPT1-1/2 Screw |
| ⑦ | | outlet | NPT1-1/2 Screw |
| ⑧ | Drain pipe | Rc3/4 Screw | |

Specifications are subject to change without notice.
© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.

# MODULE 2: PQRY-P168YLMU-A2 – DIMENSIONS

Note1. Close a hole of the water piping, the refrigerant piping, the power supply, and the control wiring and unused knockout holes with the putty etc. so as not to infiltrate rain water etc.(field erection work)
Note2. At the time of product shipment, the front side piping specification serves as the local drainage connection. When connecting on the rear side, please remove the rear side plug sealing corks, and attach a front side. Ensure there is no leak after the attachment has been fitted.
Note3. Take notice of service space as Fig.A. (In case of single installation, 600mm(23-5/8) or more of back space as front space makes easier access when servicing the unit from rear side.)
Note4. If water pipes or refrigerant pipes stretch upward, required space for service and maintenance due to replacement of control box is shown in Fig.B.
Note5. Environmental condition for installation; -20~40°C(DB)(-4~104°F) as indoor installation.
Note6. In case the temperature around the heat source unit has possibility to drop under 0°C(32°F), be careful for the following point to prevent the pipe burst by the water pipe freeze-up.
•Circulate the water all the time even if the heat source unit is not in operation.
•Drain the water from inside of the heat source unit when the heat source unit will not operate for a long term.
Note7. Ensure that the drain piping is downward with a pitch of more than 1/100.
Note8. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C(248°F).






Fig.A Fig.B


Connecting pipe specifications

| Model | Diameter | | | |
|---|---|---|---|---|
| | Refrigerant pipe | | Service valve | |
| | High pressure | Low pressure | High pressure | Low pressure |
| PQRY-P144YLMU-A2 | ø22.2 Brazed (7/8) *1 | ø28.58 Brazed (1-1/8) *1 | ø25.4 (1) | ø28.58 (1-1/8) |
| PQRY-P168YLMU-A2 | | | | |
| PQRY-P192YLMU-A2 | | | | |


*1.Connect by using the connecting pipes that are supplied.




Top view





Front view





Bottom view

<Accessories (Packaged in the accessory kit)>
- Refrigerant (high pressure) conn. pipe ····· 1pc.
- Refrigerant (low pressure) conn. pipe ····· 1pc.
- Water stopper ····· 1pc.
- Sealing material for water stopper ····· 1pc.
- Sealing material for field piping (high pressure, low pressure) ····· 1pc. each
- Sealing material for drain socket ····· 1pc.
- Pipe cover for low pressure ····· 1pc.
- Sealing material for base leg (two types) ····· 4 pcs.each
- Sealing material for panel ····· 1pc.

Unit: mm(in)




Right side view




Back view


| NO. | Usage | | Specifications |
|---|---|---|---|
| ① | For pipes | Front through hole | 140 × 77 Knockout hole (5-9/16) (3-1/16) |
| ② | | Front through hole (Uses when twinning kit (optional parts) is mounted.) | ø45 Knockout hole (1-13/16) |
| ③ | For wires | Front through hole | ø62.7 or ø34.5 Knockout hole (2-1/2) (1-3/8) |
| ④ | | Front through hole | ø43.7 or ø22.2 Knockout hole (1-3/4) (7/8) |
| ⑤ | For transmission cables | Front through hole | ø34 Knockout hole (1-3/8) |
| ⑥ | Water pipe | inlet | NPT1-1/2 Screw |
| ⑦ | | outlet | NPT1-1/2 Screw |
| ⑧ | Drain pipe | Rc3/4 Screw | |

Specifications are subject to change without notice.
© 2024 Mitsubishi Electric Trane HVAC US LLC. All rights reserved.


# TWINNING KIT: CMY-Q200CBK – DIMENSIONS

## CMY-Q200CBK


Low-pressure pipe twinning kit




<Elbow pipe(Accessory)>




<Pipe for routing through the front (Accessory)>






<Accessory>

| | |
|---|---|
| Fixing screw | • • • 1 |
| Insulation cover | • • • 1 |
| Pipe cover (75mm(3) Length) | • • • 1 |
| Pipe cover (360mm(14-3/16) Length) | • • • 1 |
| Pipe cover (70mm(2-13/16) Length) | • • • 1 |
| Pipe cover (130mm(5-1/8) Length) | • • • 1 |
| Pipe cover (100mm(3-15/16) Length) | • • • 1 |
| Pipe cover (160mm(6-5/16) Length) | • • • 1 |
| Cable tie | • • • 2 |
| Water stopper | • • • 1 |
| Sealing material (Small) | • • • 1 |
| Sealing material (Large) | • • • 1 |


High-pressure twinning pipe

<Deformed pipe(Accessory)>





<Pipe for routing through the front (Accessory)>




Note 1. Refer to the figure below for the installation position of the high-pressure twinning pipe.




Inclination tolerance of the high-pressure twinning pipe is ±15° relative to the ground.

2. Pipe diameter is indicated by inside diameter.


1340 Satellite Boulevard Suwanee, GA 30024
Toll Free: 800-433-4822 www.mehvac.com