


Data Centers: How DCIM Improves Your Daily Operations



Presenters



Dereck Saunders

*Application
Engineering Manager
Inductive Automation*



Martin Matse

*Global Business Development
Manager – Data Centers
ATS Global*



Christopher Markstein

*Strategic Industry
Account Executive
Inductive Automation*

Agenda

- Intro to Inductive Automation & Ignition
- Data Center Online Demo
- Data Center Industry Pack
- How DCIM Supports Your Operations
- Audience Q&A








The Unlimited Platform for SCADA and So Much More

- **Connect, Design, Deploy Without Limits:**
 - One central hub for everything on the plant floor
 - Create any kind of industrial application
 - Web-deploy clients to desktops, industrial displays & mobile devices
- **Unlimited licensing**
- **Industrial-strength security and stability**
- **Trusted by thousands of companies worldwide**

New Inductive Automation Resources for Data Centers



Ignition Data Center Demo

Overview

EPMS Single Line

BMS Heat Map

Alarms

Trends

Architecture



Chiron Site 3

Power Usage Effectiveness

1.25

7d High
1.71
7d Low
1.29

Water Usage Effectiveness

4.65

7d High
6.1
7d Low
4.59

Carbon Usage Effectiveness

1.74

7d High
2.09
7d Low
1.57

Total Facility IT Load (kW)

1091

7d High
1186.5
7d Low
892.5

Utility A



489.9 V
9.91 kW
1199.0 A

GEN1A

Stopped

Utility B



489.9 V
9.91 kW
1197.0 A

GEN1B

Stopped

UPS1A

Status: Alarm
Charging
98.0 %

UPS2A

Status: Alarm
Charging
96.0 %

UPS1B

Status: Alarm
Charging
99.0 %

UPS2B

Status: Alarm
Charging
99.5 %

PDU1A

Normal

19.92 kW

PDU2A

Normal

22.92 kW

PDU3A

Normal

24.92 kW

PDU4A

Normal

18.92 kW



PDU5A

Warning

24.98 kW

PDU6A

Normal

15.96 kW

PDU1B

Normal

14.95 kW

PDU2B

Normal

12.97 kW



PDU3B

Warning

24.94 kW

PDU4B

Normal

24.94 kW

PDU5B

Normal


24.92 kW

PDU6B


Normal

24.95 kW


Ignition Data Center Demo - Overview



Ignition Data Center Demo - EPMS Single Line



Ignition Data Center Demo - BMS Heat Map



Ignition Data Center Demo - Alarms & Trends

Overview EPMS Single Line BMS Heat Map Alarms Trends Architecture

Alarm Status Alarm History

5 ACTIVE 0 SHELVED

FILTERS (7): Active, Unacknowledged Active, Acknowledged Cleared, Unacknowledged Priority: Low Priority: Medium Priority: High Priority: Critical Remove All





<input type="checkbox"/> Active Time	Display Path	State	Label	Name
<input type="checkbox"/> 11/10/2023 17:34:30	Exchange/DataCenter/KPI/Outdoor Dry Bulb Temperature/AlarmBelow	Active, Acknowledged	Below 0.0 Deg C/F	AlarmBelow
<input type="checkbox"/> 11/10/2023 17:34:30	Exchange/DataCenter/KPI/Outdoor Dry Bulb Temperature/AlarmAbove	Active, Acknowledged	Above 0.0 Deg C/F	AlarmAbove
<input type="checkbox"/> 12/12/2023 10:46:03	default/Exchange/DataCenter/Heatmap/Zone1/Aisle2/Sensor1/Reading:BelowLow	Active, Unacknowledged	BelowLow	BelowLow
<input type="checkbox"/> 12/12/2023 10:46:03	default/Exchange/DataCenter/Heatmap/Zone1/Aisle9/Sensor3/Reading:AboveLow	Active, Unacknowledged	AboveLow	AboveLow
<input type="checkbox"/> 12/12/2023 10:44:03	default/Exchange/DataCenter/Heatmap/Zone1/Aisle9/Sensor2/Reading:AboveLow	Active, Unacknowledged	AboveLow	AboveLow

25 rows 1

Ignition Data Center Demo - Architecture



Ignition Data Center Demo - Mobile




Try the demo for yourself at:

<https://demo.inductiveautomation.com/data/perspective/client/data-center-demo/>

Coming Soon: Ignition Data Center Industry Pack





- A collection of Ignition resources specifically for data centers
- Will be hosted on the Ignition Exchange, available for free
- Coming in Q2 2024
- Additional Industry Packs coming in the future




<https://inductiveautomation.com/exchange/>

Ignition Exchange - Pan Zoom iFrame


Call Us 1-800-266-7798 | Schedule a Demo





[Product](#) [Pricing](#) [Resources](#) [Partners](#) [Support](#) [About](#) [Download Ignition](#)

[Home](#) / [Ignition Exchange](#) / [Resource](#)




 **Maker Edition Compatible**

Pan Zoom iFrame (With Touch Support)

By: [Mike Bordyukov](#)

Pan and zoom with touch support and low gateway overhead

Type: **Project** Skill Level: **Intermediate**

 [Watch](#)  [Report](#)  [Contact the Developer](#)

[Download](#)
19 Downloads

<https://inductiveautomation.com/exchange/2586/overview>




ATS Global and Inductive Automation

How DCIM supports your operations


Martin Matse, Global BDM Datacenters

“Our trusted experts lead manufacturers in their digital transformation to achieve sustainable operational excellence”



Group Structure

Australia | China | Czechia | France | Germany | India | Indonesia | Ireland | Italy | North Macedonia
Malaysia | Mexico | Poland | Singapore | Spain | The Netherlands | Thailand | Turkey | United Kingdom | USA



35+
Years in
the Market

25+
Countries
Worldwide

1,200+
Highly Qualified
Experts

4,000+
Satisfied
Customers

DATA CENTERS

The Image of the DC & Response from Legislators



Data centers' public image

- Use too much power
- Use all renewable energy (Wind and Solar)
- Use too much land
- Use too much water
- Create hardly any jobs



Administrations respond with regulations and directives

EMEA

- Energy Efficiency Reporting Directive
- Corporate Sustainability Reporting Directive

USA

- California Title 24
- SEC Climate Risk Disclosure

APAC

- Singapore: Data Centre Energy Efficiency Scheme
- Japan: Energy Conservation Act and the act of rational use of Energy
- China: Energy Conservation Law and Energy Efficiency Labeling Program
- Australia: the National Built Environmental Rating System
- India: the Perform, Achieve and Trade of the Bureau of Energy Efficiency

Global

- EN-50600, a European standard for Data Centers that is being embraced by other countries through the world

Table 1 Standards for measurement and reporting

	Renewable energy use	Siting design and construction	GHG emissions reductions	IT efficiency	Energy mgmt / facilities efficiencies	Water mgmt	Circular economy	Core to strategy
CDP (formerly the Carbon Disclosure Project)	•	•	•	•	•	•		•
Task Force on Climate-related Financial Disclosures (TCFD)	•	•	•	•	•			•
Greenhouse Gas Protocol's corporate accounting and reporting standards and guidance documents			•					•
Future of Internet Power, Greenhouse gas emissions accounting, renewable energy purchases and zero-carbon reporting: issues and considerations for the colocation data center industry	•		•					
Global Reporting Initiative (GRI)	•		•	•	•	•	•	
EcoVadis	•		•			•		
Science Based Targets Initiative (SBTi)	•		•	•	•			
ISO 14064 International standard for GHG emissions inventories and verification			•					•
SBTi's Net-Zero Standard	•		•					2050
Carbon Trust (PAS 2060)			•					
EU Energy Efficiency Directive: Data center requirements 2024 (proposed)	•			•	•	•		

What do most directives ask?


Your Concerns



EN-50600

- PUE based on:
 - Power
 - Liquid Fuel
 - Gaseous Fuel
 - Cooling Liquid
 - $PUE = E_{DC} / E_{IT}$
- Other metrics
 - Renewable Energy Factor
 - Energy Reuse Factor
 - Cooling Efficiency Ratio
 - Carbon Usage Efficiency
 - CO2-Footprint
- Detailed reporting
- Optimization / improvement

5.2.2.3	Environmental control
DATA CENTRE MONITORING: Energy consumption and environmental measurement	
EN 50600-99-1:2021	5.1.14, 5.1.15, 5.1.16
DATA CENTRE COOLING: Airflow management and design	
EN 50600-99-1:2021	5.2.16, 5.2.17, 5.2.18
DATA CENTRE COOLING: Cooling management	
EN 50600-99-1:2021	5.1.18, 5.1.19, 5.1.20
DATA CENTRE COOLING: Temperature and humidity settings	
EN 50600-99-1:2021	5.1.21, 5.1.22, 5.1.23
DATA CENTRE COOLING: Selection of cooling system: High efficiency cooling system	
EN 50600-99-1:2021	5.1.24
DATA CENTRE MONITORING: Energy consumption and environmental measurement	
EN 50600-99-1:2021	5.1.26, 5.1.27
DATA CENTRE MONITORING: Energy consumption and environmental collection and logging	
EN 50600-99-1:2021	5.1.29, 5.1.30




EERD: Energy Efficiency Reporting Directive

Requirements

- Be based on up-to-date, traceable data on energy consumption and load profiles
- Comprise a detailed energy consumption review
- Identify energy efficiency measures to decrease energy consumption
- Identify potential cost-effective use or production of renewable energy
- Build on life cycle cost and long-term savings
- Annual in/out data traffic
- Be proportionate and sufficiently, drawing a reliable picture of overall energy performance and reliable identification of most significant improvement opportunities
- Certified E(P)MS is mandatory



Data Centers concerns




UPTIME INSTITUTE SUSTAINABILITY AND CLIMATE CHANGE SURVEY 2022

uptime
INTELLIGENCE

A survey from one of the HW vendors: sustainability driven by tech.

Ways to improve:



Performance **in detail through time**




Performance Management


- PUE = Power Usage Effectiveness
- $PUE = \text{Total Power} / \text{IT Power}$

PUE gains have stalled since 2013


Uptime Institute Report 2023



- Improvement 2007-2013, after that more or less a flatline
- Why does it flatten?
 - Most easy methods are used
 - No real idea how to improve further



A Performance Dashboard



**Now back to you and
your Data Center**



You and your Data Center


Responsible for a Data Center and you want to:

- Improve your asset utilization
 - Decrease outage risk
 - Manage your CAPEX and OPEX
- Improve your performance and reduce costs
- Want to have inside information about your energy balance
- Comply with the coming directives/legislation and mandatory reporting like:
 - The Energy Efficiency Reporting Directive (15-3-2024)

Conclusion: “we need a DCIM solution to help us”



Administration to CEO



Total power = 4100 kW

IT load = 2000+800= 2800 kW



PUE= 4100/2800 = 1.46

Local administration to the DC-CEO:

- Your PUE = 1.46
- Your permit only allows a PUE of 1.3 Max!
- You have 12 months to bring your PUE to 1.3 or lower!




CEO to Operations Manager and response



- CEO to Operations Manager: our PUE must become 1.3 in the coming month
- OM to CEO
 - “My EMS tells me: Our best partial PUE I have is 1.32 and worst 1.65”, what can I do?”
 - “We already did Cold Aisle containment and I think CRAC controls are optimized, set-up by vendor”
 - “The design PUE is 1.25, so it is up to sales!!!!”
 - “Sales should sell more, increasing load will improve my efficiency”
 - “There is nothing I can do”





Integrated system




White
Space

EPMS



BMS

CMS



DATA CENTER PERFORMANCE SCORECARD

33% ACTIVE POWER CAPACITY !



LAST 8 HOURS

SLA COMPLIANCE

SECTION 1 ✗

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 FALSE

SECTION 2 ✓

STATUS 26°C, 67%RH
RATE 1.3°C/HR
N+1 TRUE

ACTIVE COOLING CAPACITY !



SECTION 1
83% !

SECTION 2
38%

LAST 8 HOURS



-- TARGET: <80% ● SECTION 1 ● SECTION 2


27% **35%** **29%** !
TOTAL UPS CAPACITY



COMPOSITE PERFORMANCE INDEX !


UPS1 CAPACITY

LAST 8 HOURS




UPS2 CAPACITY

LAST 8 HOURS



1.46 POWER USAGE EFFECTIVENESS !

LAST 8 HOURS



-- TARGET: <1.25 ● SECTION 1: 1.25 ! ● SECTION 2: 1.62 !







5.6 ENERGY EFFICIENCY RATIO !

SECTION 1
8.0

SECTION 2
3.2 !

Powered by
Ignition!

35% 29% 
PS CAPACITY



IVENESS

EER should
be > 7.5!

-- TARGET:

$EER = IT\ Power / Cooling\ Power$

$EER1 = 2000 / 250 = 8.0$

$EER2 = 800 / 250 = 3.2$

Target EER > 7.5 for DX Cooling

35%
MIN

2

5.6 ENERGY
EFFECIENCY RATIO

SECTION 1

8.0

SECTION 2

3.2

● SECTION 2: 1.62


1.22
MIN

LAST 8 HOURS

27% 35% 29%
TOTAL UPS CAPACITY




UPS loads are too low...



COMPOSITE
PERFORMANCE

UPS1 CAPACITY


LAST 8 HOURS



... and loads are imbalanced

UPS2 CAPACITY


LAST 8 HOURS



Result:
87% UPS Efficiency

POWER

LAST 8 HOURS



EFFICIENCY

A CENTER PERFORMANCE SCORECARD

SLA COMPLIANCE

SECTION 1 ✗

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 FALSE

... leading to SLA violation

N+1 TRUE

ACTIVE COOLING CAPACITY



SECTION 1
83% !

SECTION 2
38%



COMPOSITE
PERFORMANCE
INDEX

LAST 8 HOURS

Section one cooling load exceeds n+1 utilization threshold...

83%
MAX










35%
MIN

-- TARGET: <80%

● SECTION 1

● SECTION 2


ACTION 1: Move IT from Section 1 to Section 2



ACTION 1: Move IT from Section 1 to Section 2

33% ACTIVE POWER CAPACITY 



27% **35%** **29%** 

TOTAL UPS CAPACITY

SLA COMPLIANCE


SECTION 1 

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 TRUE

SECTION 2 


STATUS 26°C, 67%RH
RATE 1.3°C/HR
N+1 TRUE



76 COMPOSITE PERFORMANCE INDEX 


UPS1 CAPACITY


LAST 8 HOURS




UPS2 CAPACITY

LAST 8 HOURS



1.31 POWER USAGE EFFECTIVENESS 

LAST 8 HOURS




ACTIVE COOLING CAPACITY



SECTION 1
61%

SECTION 2
59%

LAST 8 HOURS




8.3 ENERGY EFFICIENCY RATIO


SECTION 1
8.4

SECTION 2
8.2



ACTION 1: Move IT from Section 1 to Section 2



ACTION 1: Move IT from Section 1 to Section 2










EER above target of 7.5












Dramatic improvement in Section 2

ACTION 1: Move IT from Section 1 to Section 2



ACTION 2: Decrease UPS Capacity + Load Balancing



ACTION 2A: Decrease UPS Capacity

27% 35% 29% !

TOTAL UPS CAPACITY

Optimize capacity to
prevalent load
conditions


● PHASE A: 18% ● PHASE B: 23% ● PHASE C: 19%

UPS2 CAPACITY

LAST 8 HOURS

● PHASE A: 36% ● PHASE B: 47% ● PHASE C: 30%

Note relative full load and part
load efficiencies between models




ACTION 2B: Load Balancing



UPS1 CAPACITY

UPS2 CAPACITY

Analyze phase loading and reconfigure PDUs and IT to balance



RATE1.5°C/HRRATE1.3°C/HR




ACTION 2: Decrease UPS Capacity + Load Balancing

27%35%29%!

TOTAL UPS CAPACITY



COMPOSITE
PERFORMANCE
INDEX



LAST 8

8

ACTION 2: Decrease UPS Capacity + Load Balancing

80% 80% 80%
TOTAL UPS CAPACITY



COMPOSITE
PERFORMANCE
INDEX


LAST 8



8


UPS1 CAPACITY

LAST 8 HOURS




UPS2 CAPACITY

LAST 8 HOURS



1.25 POWER
USAGE
EFFECTIVENESS

LAST 8 HOURS



ACTION 2: Decrease UPS Capacity + Load Balancing

80% 80% 80%
TOTAL UPS CAPACITY



Loads are
balanced,
Efficiency > 94%

COMPOSITE
PERFORMANCE
INDEX



PUE is below
target (1.3)

1.25 POWER
USAGE
EFFECTIVENESS




LAST 8 HOURS

8

DATA CENTER PERFORMANCE SCORECARD

80% ACTIVE
POWER CAPACITY



SLA COMPLIANCE

SECTION 1 ✓

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 TRUE

SECTION 2 ✓

STATUS 26°C, 67%RH
RATE 1.3°C/HR
N+1 TRUE

**ACTIVE
COOLING
CAPACITY**



**SECTION 1
61%**


**SECTION 2
59%**

80% 80% 80%
TOTAL UPS CAPACITY



**COMPOSITE
PERFORMANCE
INDEX**


UPS1 CAPACITY




UPS2 CAPACITY



1.25 POWER
USAGE
EFFECTIVENESS



LAST 8 HOURS




8.3 ENERGY
EFFECIENCY RATIO

**SECTION 1
8.4**

**SECTION 2
8.2**

DATA CENTER PERFORMANCE SCORECARD

80% ACTIVE
POWER CAPACITY



SLA COMPLIANCE

SECTION 1 ✓

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 TRUE

SECTION 2 ✓

STATUS 26°C, 67%RH
RATE 1.3°C/HR
N+1 TRUE

**ACTIVE
COOLING
CAPACITY**



**SECTION 1
61%**


**SECTION 2
59%**

80% 80% 80%
TOTAL UPS CAPACITY




**COMPOSITE
PERFORMANCE
INDEX**

UPS1 CAPACITY




UPS2 CAPACITY




1.25 POWER
USAGE
EFFECTIVENESS

LAST 8 HOURS



LAST 8 HOURS



8.3 ENERGY
EFFECIENCY RATIO

**SECTION 1
8.4**

**SECTION 2
8.2**

DATA CENTER PERFORMANCE SCORECARD

80% ACTIVE
POWER CAPACITY



SLA COMPLIANCE

SECTION 1 ✓

STATUS 27°C, 65%RH
RATE 1.5°C/HR
N+1 TRUE

SECTION 2 ✓

STATUS 26°C, 67%RH
RATE 1.3°C/HR
N+1 TRUE

**ACTIVE
COOLING
CAPACITY**




SECTION 1
61%

SECTION 2
59%


80% 80% 80%
TOTAL UPS CAPACITY




**COMPOSITE
PERFORMANCE
INDEX**




UPS1 CAPACITY



UPS2 CAPACITY



1.25 POWER
USAGE
EFFECTIVENESS



8.3 ENERGY
EFFECIENCY RATIO

SECTION 1
8.4

SECTION 2
8.2

Show me the money

- Colo: size 12,000 m²
- Uses 15 MWh
- Energy purchase price \$ 0.10 / kWh
- PUE 1.46
- Yearly Energy costs \$ 13,140,000
- New PUE 1.25,
 - Old Energy consumption 15 MWh
 - New Energy consumption 12.842 MWh
- Yearly Energy costs \$ 11,250,000
- Compliancy with **your local legislation**
- Saving on energy costs **\$ 1,890,000 yearly**
- DCIM ROI **4 - 6 month**



ATS Datacenters



Martin Matse
Global BDM Datacenters
+31 653 20 42 36
Martin.matse@ats-global.com





Ready to Try Ignition for Yourself?

Download the full version for free at:
inductiveautomation.com



inductiveuniversity.com

*Ignition User Manual also available at:
docs.inductiveautomation.com*

International Distributors

Brazil	FG Automação Industrial	www.fgltda.com.br
Central America	NV Tecnologías S.A.	www.nvtecnologias.com
France	AXONE-iO	www.axone-io.com
Italy	EFA Automazione S.p.A	www.efa.it
Middle East/North Africa	Clarien Solutions	www.clarien.solutions
Norway & Sweden	Autic System AS	www.autic.no
South Africa	Element8	https://element8.co.za
Switzerland	MPI Technologies	https://mpi.ch

Contact International Distribution Manager Yegor Karnaukhov at: ykarnaukhov@inductiveautomation.com

For More Information, Please Contact:



Martin Matse

ATS Global

+31 653 20 42 36

Martin.matse@ats-global.com



Christopher Markstein

Inductive Automation

+1 727 358 5800

cmarkstein@inductiveautomation.com

Thank You

Stay connected to us on social media
& subscribe to news feeds:

