eurofins | Environment Testing

Eurofins Ayer
Laboratory Report

Galeota Associates, Inc.
Greg Galeota
150 Highland Street
Townsend, MA 01469

Date Printed:	**04/29/2026**
Job ID:	**297-1858-1**
Date Received:	**4/21/2026 8:42 AM**
Sample Collected In:	**Massachusetts**
Job Desc:	**Taraporevala, 42 Washington St Sherborn MA 01770**

Attached please find results for the analysis of the samples received on the date referenced above.

The analytical test results presented in this report meet all requirements of the associated regulatory program listed in the Certification Summary section, unless otherwise noted. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

Receipt

The sample was received on 4/21/2026 8:42 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 8.2°C.

Certification Summary

Certifications for this job are presented below. Note that not all certifications may be applicable to your report and certifications for subcontracted laboratories are available upon request. Evidence of certification for laboratories within Eurofins Environmental Testing can be found on the following website: https://www.eurofinsus.com/environment-testing/resources/certifications/

Eurofins Auburn (AUB), 155 Center Street, Building C, Auburn, ME 04210
Maine (Rad), Lab ID: SPC20, RSP50083

Eurofins Ayer (AYE), 31A Willow Rd, Ayer, MA 01432
Massachusetts, Lab ID: M-MA1118

Eurofins Derry (DER), 22 Manchester Road, Unit 2, Derry, NH 03038
Massachusetts, Lab ID: M-NH003

Action Limit Summary

Sample results for 297-1858-1 have been evaluated against the following action limits and/or Maximum Contaminant Levels:
- EPA Primary Limits: 297 - EPA Primary DW MCL
- EPA Secondary Limits: EPA Secondary DW MCL with Aluminum set at 200 ug/L
- State Limits: 297 - MA limits

Definitions regarding the evaluations presented within this report are presented below:
- EPA Primary Limits: Legally enforceable standards that apply to public water systems. Primary standards protect the public by limiting the levels of contaminants in drinking water that effect human health .
- EPA Secondary Limits: Non-enforceable guidelines regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. EPA recommends secondary standards to water systems but does not require systems to comply.
- Pass: Reported result is below the action limit and/or Maximum Contaminant Level (MCL).
- Fail: Reported result is above the action limit and/or Maximum Contaminant Level (MCL).
- Attention: No specified limit, but indicates a potential pathway for contaminants to enter the system that may warrant investigation.
- No Limit: No action limit or maximum contaminant level available.

Jennifer Woodall

Authorized By: Jen Woodall, Project Management Assistant I
Phone: (978)391-4428

Method 524.2 - Volatile Organic Compounds (GC/MS)
Volatile compounds have been detected above the RL for the following sample: Kitchen Sink (297-1858-1). Since a field reagent blank/trip blank was not submitted, any potential contamination from the sampling/transport process cannot be assessed.

Method 200.7 - Metals (ICP)
Potassium ICV and CCV high, sample results above reporting limit may be biased high. Results below the reporting limit are not affected. Data has been qualified and reported.

Kitchen Sink (297-1858-1)

Analysis Related Notes
DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with predetermined confidence level.
ND: Non-detected at the reporting limit (or MDL or EDL if shown).
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
Analytes not considered to be certified under the certifications associated with this report will have an asterisk next to their names.
Data qualifier flags provide additional information in regards to the receipt, analysis or quality control of a sample. If any such flags are associated with the results of this report, they will be listed below along with their definitions.

J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.
^+	Continuing Calibration Verification (CCV) is outside acceptance limits, high biased.
^1+	Initial Calibration Verification (ICV) is outside acceptance limits, high biased.

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: Kitchen Sink
SAMPLE ID #: 297-1858-1
CLIENT JOB #: Galeota Associates, Inc
OTHER SAMPLE INFO: 42 Washington St Sherborn MA
SAMPLED BY: Greg A. Galeota, President
COLLECTION DATE/TIME: 04/20/26 17:03

Test Description (SM 4500 NH3 D)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Ammonia*	<0.10	mg/L				0.10	1	No Limit	MR - AYE		04/27/26 10:20

Test Description (SM 4500 Cl G)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Free residual chlorine	<0.22	mg/L		HF		0.22	1	No Limit	AH - AYE		04/21/26 18:48

Test Description (SM 4500 H+ B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
pH at 25 Degrees C	7.42	SU	✓	HF		0.01	1	6.5 - 8.5	AH - AYE		04/21/26 14:34

Test Description (SM7500_Rn_B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Radon	154	pCi/L	✓			100	1	10000	TT - AUB		04/23/26 04:29

Test Description (SM 2120B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Color, Apparent*	<5.00	Apparent CU	✓			5.00	1	15	AH - AYE		04/21/26 13:28

Test Description (SM 2150B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Odor*	<1.00	T.O.N.	✓			1.00	1	3	AH - AYE		04/21/26 10:59

Test Description (SM 2320B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Alkalinity	125	mg/L				5.00	1	No Limit	AH - AYE		04/21/26 19:10

Test Description (SM 2340B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Hardness as calcium carbonate*	169	mg/L				1.00	1	No Limit	PF - AYE		04/29/26 13:16

Test Description (SM 2510B)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Specific Conductance (25C)*	358	umhos/cm				10.0	1	No Limit	AH - AYE		04/21/26 14:34

Test Description (EPA 524)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Xylenes, Total	<0.50	ug/L	✓		0.50	0.50	1	10000	DD - DER		04/22/26 19:15

Jennifer Woodall

Authorized By: Jen Woodall, Project Management Assistant I
Phone: (978)391-4428

Job ID: 297-1858-1

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: Kitchen Sink
SAMPLE ID #: 297-1858-1
CLIENT JOB #: Galeota Associates, Inc
OTHER SAMPLE INFO: 42 Washington St Sherborn MA
SAMPLED BY: Greg A. Galeota, President
COLLECTION DATE/TIME: 04/20/26 17:03

Test Description (EPA 180.1)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Turbidity	0.55	NTU				0.50	1	No Limit	AH - AYE		04/21/26 13:28

Test Description (EPA 200.7)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Calcium	50.6	mg/L				1.00	1	No Limit	KW - AYE	04/22/26 12:07	04/24/26 14:17
Copper	0.034	mg/L	✓			0.010	1	1	KW - AYE	04/22/26 12:07	04/24/26 14:17
Iron	<0.010	mg/L	✓			0.010	1	0.3	KW - AYE	04/22/26 12:07	04/24/26 14:17
Magnesium*	10.3	mg/L				1.00	1	No Limit	KW - AYE	04/22/26 12:07	04/24/26 14:17
Manganese	0.035	mg/L	✓			0.010	1	0.05	KW - AYE	04/22/26 12:07	04/24/26 14:17
Potassium*	11.8	mg/L		^+ ^1+		5.00	1	No Limit	KW - AYE	04/22/26 12:07	04/24/26 14:17
Sodium	9.02	mg/L	✓			1.00	1	20	KW - AYE	04/22/26 12:07	04/24/26 14:17

Test Description (EPA 200.8)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Arsenic	<0.0010	mg/L	✓			0.0010	1	0.01	JP - DER	04/22/26 07:31	04/23/26 02:43
Lead	<0.0010	mg/L	✓			0.0010	1	0.01	JP - DER	04/22/26 07:31	04/23/26 02:43

Test Description (EPA 300.0)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Chloride	22.7	mg/L	✓			2.00	1	250	AH - AYE		04/21/26 17:28
Fluoride	<0.20	mg/L	✓			0.20	1	2	AH - AYE		04/21/26 17:28
Nitrate as N	1.44	mg/L	✓			0.050	1	10	AH - AYE		04/21/26 17:28
Nitrite as N	<0.050	mg/L	✓			0.050	1	1	AH - AYE		04/21/26 17:28
Sulfate	10.6	mg/L	✓			2.00	1	250	AH - AYE		04/21/26 17:28

Test Description (EPA-DW 524.2)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
1,1,1,2-Tetrachloroethane*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,1,1-Trichloroethane	<0.13	ug/L	✓		0.13	0.50	1	200	KV - DER		04/22/26 19:15
1,1,2,2-Tetrachloroethane*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,1,2-Trichloroethane	<0.15	ug/L	✓		0.15	0.50	1	5	KV - DER		04/22/26 19:15
1,1-Dichlorethylene	<0.16	ug/L	✓		0.16	0.50	1	7	KV - DER		04/22/26 19:15
1,1-Dichloroethane*	0.42	ug/L		J	0.18	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,1-Dichloropropylene*	<0.12	ug/L			0.12	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,2,3-Trichlorobenzene*	<0.29	ug/L			0.29	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,2,3-Trichloropropane	<0.19	ug/L			0.19	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,2,4-Trichlorobenzene	<0.28	ug/L	✓		0.28	0.50	1	70	KV - DER		04/22/26 19:15
1,2,4-Trimethylbenzene*	<0.23	ug/L			0.23	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,2-Dibromo-3-Chloropropane*	<0.27	ug/L	✓		0.27	0.50	1	0.2	KV - DER		04/22/26 19:15

Jennifer Woodall

Job ID: 297-1858-1

Authorized By: Jen Woodall, Project Management Assistant I
Phone: (978)391-4428

Legend
Passes
Fails EPA Primary
Fails EPA Secondary
Fails State Guideline
Attention

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: Kitchen Sink
SAMPLE ID #: 297-1858-1
CLIENT JOB #: Galeota Associates, Inc
OTHER SAMPLE INFO: 42 Washington St Sherborn MA
SAMPLED BY: Greg A. Galeota, President
COLLECTION DATE/TIME: 04/20/26 17:03

Test Description (EPA-DW 524.2)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
1,2-Dibromoethane*	<0.15	ug/L	✓		0.15	0.50	1	0.05	KV - DER		04/22/26 19:15
1,2-Dichlorobenzene	<0.14	ug/L	✓		0.14	0.50	1	600	KV - DER		04/22/26 19:15
1,2-Dichloroethane	0.35	ug/L	✓	J	0.17	0.50	1	5	KV - DER		04/22/26 19:15
1,2-Dichloropropane	<0.16	ug/L	✓		0.16	0.50	1	5	KV - DER		04/22/26 19:15
1,3,5-Trimethylbenzene*	<0.21	ug/L			0.21	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,3-Dichlorobenzene*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,3-Dichloropropane*	<0.14	ug/L			0.14	0.50	1	No Limit	KV - DER		04/22/26 19:15
1,4-Dichlorobenzene	<0.36	ug/L	✓		0.36	0.50	1	5	KV - DER		04/22/26 19:15
2,2-Dichloropropane*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15
2-Butanone*	<0.50	ug/L			0.50	10	1	No Limit	KV - DER		04/22/26 19:15
2-Chlorotoluene*	<0.11	ug/L			0.11	0.50	1	No Limit	KV - DER		04/22/26 19:15
2-Hexanone*	<0.26	ug/L			0.26	10	1	No Limit	KV - DER		04/22/26 19:15
4-Chlorotoluene*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15
4-Isopropyltoluene*	<0.25	ug/L			0.25	0.50	1	No Limit	KV - DER		04/22/26 19:15
4-Methyl-2-pentanone (MIBK)*	<0.24	ug/L			0.24	10	1	No Limit	KV - DER		04/22/26 19:15
Acetone*	<3.3	ug/L			3.3	10	1	No Limit	KV - DER		04/22/26 19:15
Benzene	<0.13	ug/L	✓		0.13	0.50	1	5	KV - DER		04/22/26 19:15
Bromobenzene*	<0.11	ug/L			0.11	0.50	1	No Limit	KV - DER		04/22/26 19:15
Bromochloromethane*	<0.21	ug/L			0.21	0.50	1	No Limit	KV - DER		04/22/26 19:15
Bromodichloromethane	<0.14	ug/L	✓		0.14	0.50	1	80	KV - DER		04/22/26 19:15
Bromoform	<0.21	ug/L	✓		0.21	0.50	1	80	KV - DER		04/22/26 19:15
Bromomethane*	<0.28	ug/L			0.28	0.50	1	No Limit	KV - DER		04/22/26 19:15
Carbon disulfide*	<0.37	ug/L			0.37	0.50	1	No Limit	KV - DER		04/22/26 19:15
Carbon tetrachloride	<0.19	ug/L	✓		0.19	0.50	1	5	KV - DER		04/22/26 19:15
Chlorobenzene	<0.12	ug/L	✓		0.12	0.50	1	100	KV - DER		04/22/26 19:15
Chloroethane*	<0.25	ug/L			0.25	0.50	1	No Limit	KV - DER		04/22/26 19:15
Chloroform	3.1	ug/L	✓		0.17	0.50	1	80	KV - DER		04/22/26 19:15
Chloromethane*	<0.21	ug/L			0.21	0.50	1	No Limit	KV - DER		04/22/26 19:15
cis-1,2-Dichloroethylene	<0.19	ug/L	✓		0.19	0.50	1	70	KV - DER		04/22/26 19:15
cis-1,3-Dichloropropylene*	<0.12	ug/L			0.12	0.50	1	No Limit	KV - DER		04/22/26 19:15
Dibromochloromethane	<0.14	ug/L	✓		0.14	0.50	1	80	KV - DER		04/22/26 19:15
Dibromomethane*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
Dichlorodifluoromethane*	<0.20	ug/L			0.20	0.50	1	No Limit	KV - DER		04/22/26 19:15
Diethyl ether*	<0.19	ug/L			0.19	0.50	1	No Limit	KV - DER		04/22/26 19:15
Diisopropyl ether (DIPE)*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15
Ethyl tert-Butyl Ether (ETBE)*	<0.15	ug/L			0.15	0.50	1	No Limit	KV - DER		04/22/26 19:15
Ethylbenzene	<0.15	ug/L	✓		0.15	0.50	1	700	KV - DER		04/22/26 19:15
Hexachlorobutadiene*	<0.18	ug/L			0.18	0.50	1	No Limit	KV - DER		04/22/26 19:15
Isopropylbenzene*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15

Jennifer Woodall

Job ID: 297-1858-1

Authorized By: Jen Woodall, Project Management Assistant I
Phone: (978)391-4428

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▼
Fails State Guideline	✕
Attention	⚠

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

CLIENT SAMPLE ID: Kitchen Sink
SAMPLE ID #: 297-1858-1
CLIENT JOB #: Galeota Associates, Inc
OTHER SAMPLE INFO: 42 Washington St Sherborn MA
SAMPLED BY: Greg A. Galeota, President
COLLECTION DATE/TIME: 04/20/26 17:03

Test Description (EPA-DW 524.2)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Methyl tert-butyl ether (MTBE)	<0.31	ug/L	✓		0.31	0.50	1	70	KV - DER		04/22/26 19:15
Methylene Chloride	<0.40	ug/L	✓		0.40	0.50	1	5	KV - DER		04/22/26 19:15
m-Xylene & p-Xylene*	<0.30	ug/L			0.30	1.0	1	No Limit	KV - DER		04/22/26 19:15
Naphthalene*	<0.21	ug/L	✓		0.21	0.50	1	100	KV - DER		04/22/26 19:15
n-Butylbenzene*	<0.22	ug/L			0.22	0.50	1	No Limit	KV - DER		04/22/26 19:15
Nitrobenzene*	<0.89	ug/L			0.89	10	1	No Limit	KV - DER		04/22/26 19:15
N-Propylbenzene*	<0.18	ug/L			0.18	0.50	1	No Limit	KV - DER		04/22/26 19:15
o-Xylene*	<0.17	ug/L			0.17	0.50	1	No Limit	KV - DER		04/22/26 19:15
sec-Butylbenzene*	<0.20	ug/L			0.20	0.50	1	No Limit	KV - DER		04/22/26 19:15
Styrene	<0.20	ug/L	✓		0.20	0.50	1	100	KV - DER		04/22/26 19:15
tert-Amyl Methyl Ether (TAME)*	<0.11	ug/L			0.11	0.50	1	No Limit	KV - DER		04/22/26 19:15
tert-Butyl alcohol (TBA)*	<1.6	ug/L			1.6	10	1	No Limit	KV - DER		04/22/26 19:15
tert-Butylbenzene*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
Tetrachloroethylene	<0.17	ug/L	✓		0.17	0.50	1	5	KV - DER		04/22/26 19:15
Tetrahydrofuran*	<1.6	ug/L			1.6	10	1	No Limit	KV - DER		04/22/26 19:15
Toluene	<0.11	ug/L	✓		0.11	0.50	1	1000	KV - DER		04/22/26 19:15
trans-1,2-Dichloroethylene	<0.18	ug/L	✓		0.18	0.50	1	100	KV - DER		04/22/26 19:15
trans-1,3-Dichloropropylene*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
Trichloroethylene	<0.16	ug/L	✓		0.16	0.50	1	5	KV - DER		04/22/26 19:15
Trichlorofluoromethane*	<0.16	ug/L			0.16	0.50	1	No Limit	KV - DER		04/22/26 19:15
Trihalomethanes, Total	3.1	ug/L	✓		0.50	0.50	1	80	DD - DER		04/22/26 19:15
Vinyl chloride	<0.17	ug/L	✓		0.17	0.50	1	2	KV - DER		04/22/26 19:15

Surrogate (EPA-DW 524.2)	*Results*	*Units*	*Pass/ Fail*	*DQ Flag*	*DF*	*Limit*	*Analyst /Lab*	*Date & Time Prepared*	*Date & Time Analyzed*
1,2-Dichlorobenzene-d4	*97*	*%*	✓		*1*	*70 - 130*	*KV - DER*		*04/22/26 19:15*
4-Bromofluorobenzene	*93*	*%*	✓		*1*	*70 - 130*	*KV - DER*		*04/22/26 19:15*

Test Description (Lab SOP Sediment)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Sediment*	Absent	NONE					1	No Limit	AH - AYE		04/21/26 10:59

MEDIA TYPE: Colilert-18

Test Description (SM 9223B 22nd ED)	Results	Units	Pass/ Fail	DQ Flag	MDL	RL	DF	Limit	Analyst /Lab	Date & Time Prepared	Date & Time Analyzed
Coliform, Total*	Absent	/100mL	✓			1	1	Present	KW - AYE	04/21/26 13:45	04/22/26 09:47
Escherichia coli*	Absent	/100mL	✓			1	1	Present	KW - AYE	04/21/26 13:45	04/22/26 09:47

Job ID: 297-1858-1

Authorized By: Jen Woodall, Project Management Assistant I
Phone: (978)391-4428

eurofins | Drinking Water and Wastewater Northeast, LLC

Environment Testing

v Road
01432
391-4428

297-1858 COC

Chain of Custody for Commercial Clients:

Your company name: Galeota Associates, Inc.

SAMPLE INFORMATION - please print clearly

Project or Customer Name:	Taraporevala
Street Address:	42 Washington St
Town and State:	Sherborn, MA 01770
Date Sampled:	4/21/2026
Time Sampled:	5:03 pm
Sample Taken At: (i.e Kitchen Sink, Well Head...)	Kitchen Sink.
Sampled by (Name):	Greg A. Galeota, President

Test(s) to be Performed:

Comprehensive (Comprehensive w/VOC's) (Radon Water)

(if not sure ask an analyst)

Email Results: agaleota@aol.com

Lab Use Only:	
Receipt Temperature:	8.2°C Ice: (Y) or N
Date 4/21/26	Time 8:42
Received at Lab by:	

Eurofins Ayer
31A Willow Rd
Ayer, MA 01432
Phone: 978-391-4428

Chain of Custody Record

eurofins | Environment Testing

Client Information (Sub Contract Lab)	Sampler: N/A	Lab PM: Woodall, Jen	Carrier Tracking No(s): N/A	COC No: 297-223.1
Client Contact: Shipping/Receiving	Phone: N/A	E-Mail: Jen.Woodall@et.eurofinsus.com	State of Origin: Massachusetts	Page: Page 1 of 1
Company: Eurofins Drinking Water and Wastewater N		Accreditations Required (See note): State - Maine (Rad); State - Massachusetts		Job #: 297-1858-1
Address: 22 Manchester Road, Unit 2,	Due Date Requested: 4/28/2026			
City: Derry	TAT Requested (days): N/A			
State, Zip: NH, 03038				
Phone: 603-432-3044(Tel)	PO #: N/A			
Email: N/A	WO #: N/A			
Project Name: Taraporevala, 42 Washington St Sherborn MA 01770	Project #: 29701157			
Site: N/A	SSOW#: N/A			

Analysis Requested

Preservation Codes: -

Other: N/A

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	624.2_Pres_PRECFull List	624.2_TTHM_SumTotal Trihalomethanes	Total_XYL_624Total Xylenes	Total Number of containers	Special Instructions/Note:
			Preservation Code:								
Kitchen Sink (297-1858-1)	4/20/26	17:03 Eastern	G	Drinking Wate			X	X	X	2	

Note: Since laboratory accreditations are subject to change, Eurofins Drinking Water and Wastewater Northeast, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Drinking Water and Wastewater Northeast, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Drinking Water and Wastewater Northeast, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Drinking Water and Wastewater Northeast, LLC.

Possible Hazard Identification	Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
Unconfirmed	☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months
Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 1	Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
[signature] 4/21/26	18:50				
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:
		5.9C Tr AT

Eurofins Ayer
31A Willow Rd
Ayer, MA 01432
Phone: 978-391-4428

Chain of Custody Record

eurofins | Environment Testing

Client Information (Sub Contract Lab)	Sampler: N/A	Lab PM: Woodall, Jen	Carrier Tracking No(s): N/A	COC No: 297-224.1
Client Contact: Shipping/Receiving	Phone: N/A	E-Mail: Jen.Woodall@et.eurofinsus.com	State of Origin: Massachusetts	Page: Page 1 of 1
Company: Eurofins Drinking Water and Wastewater N		Accreditations Required (See note): State - Maine (Rad); State - Massachusetts		Job #: 297-1858-1
Address: 22 Manchester Road, Unit 2,	Due Date Requested: 4/28/2026			Preservation Codes: -
City: Derry	TAT Requested (days): N/A			
State, Zip: NH, 03038				
Phone: 603-432-3044(Tel)	PO #: N/A			
Email: N/A	WO #: N/A			
Project Name: Taraporevala, 42 Washington St Sherborn MA 01770	Project #: 29701157			
Site: N/A	SSOW#: N/A			Other: N/A

Analysis Requested

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	200.8_SDWA/200_DW_TurbLead and Arsenic	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
Kitchen Sink (297-1858-1)	4/20/26	17:03 Eastern	G	Drinking Wate			X	1	

Note: Since laboratory accreditations are subject to change, Eurofins Drinking Water and Wastewater Northeast, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Drinking Water and Wastewater Northeast, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Drinking Water and Wastewater Northeast, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Drinking Water and Wastewater Northeast, LLC.

Possible Hazard Identification Unconfirmed	*Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)* ☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months
Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 1	Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time: 4/21/26	Company	Received by:	Date/Time:	Company 26APR 22 8:45AM
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: ∆ Yes ∆ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks: 15.1