

Ceraclad Sealant Guidance

Ceraclad does not supply, warranty, or approve the sealant used with metal joiner bars at panel joints and abutments.

The sealant selected shall comply with the following performance specification:

- ASTM Specification C 920, Type S, Grade NS, Class 50, or class 100/50, Use NT, M, G, A and O

Install the sealant in accordance with the manufacturer's instructions.

It is recommended to perform a field pull test according to the sealant manufacturer's instructions to ensure a proper adhesive bond.

Please contact technical@ceraclad.com for additional questions, or call 425.305.7520.