

Unisex Restroom 2

Signage	Id	Name	Status
	216.8	Sign with ADA symbol	N/A
	703.2	Raised characters	N/A
	703.3	Braille	N/A
	703.4.2	Located at latch side of door	N/A
	703.4.1	Mounting height 48-60"	N/A

Restroom Entrance	Id	Name	Status
	404.2.3	Door opening width: 32" min. when open 90 degrees	true
	404.2.4	18" on pull side of door plus 60" clear	true
	404.2.7-a	Accessible handles operated by closed fist	true
	404.2.7-b	Handle height 34"-48"	true
	404.2.5	Threshold 1/2" Max Height. 1/4" + 1/4" beveled	true
	303.3	3/4" threshold present, is it beveled on both sides with slope no greater than 1:2	No threshold present
404.2.6	Vestibule: 48" min. plus width of doors	N/A	

Inside Restroom	Id	Name	Status
	603.2.1, 304.3	Clear floor space: 60" diameter circle	false
	604.2	Toilet centerline from wall: 16"-18"	N/A
	604.3.1	Toilet clear floor space: 60" from side wall and 56" from rear wall	N/A
	604.4	Height of toilet seat: 17"-19"	N/A
	604.6a	Height of flush control: 15"-48"	N/A
	604.6b	Flush control located on open side of toilet	N/A
	604.5.1	Side wall grab bar: 42" L, 12" max. from wall	true
	609.4a	Side wall grab bar: 33"-36" H to top	true
	604.5.2	Rear wall grab bar: 36" L, 12" & 24" center line toilet	N/A
	609.4b	Rear wall grab bar: 33"-36" H to top	N/A
	604.7a	TP dispenser: 7"-9" from front of toilet to center line	N/A
	604.7b	Height of TP dispenser: 15"-48"	N/A
	604.7c	TP dispenser not located behind grab bar	N/A
	606.2	Sink clear floor space: 30" W x 48" D	N/A
	606.3	Height of sink rim: 34" max.	N/A
	306.6.6	Knee clearance: 27" H min. x 8" D min.	N/A
	606.5	Pipe protection below sink	N/A
	606.4	Faucet handles: operable by closed fist	N/A
	603.3a	Bottom of mirror: 40" H max. if over sink	N/A
	603.3b	Bottom of mirror: 35" H max. if not over sink	N/A
308.2.2	Soap dispenser: 44" H max. if above sink	N/A	
308.2	Soap dispenser: 48" H max. not above sink	N/A	
308.2.2, 308.2a	Paper towel dispenser: (same as soap)	N/A	
308.2.2, 308.2b	Electric hand dryer: (same as soap)	true	

Toilet Compartments (Stalls)	Id	Name	Status
	604.8.1.2a	Door opening width: 32" min. when open 90 degrees	N/A
	604.8.1.2b	18" on pull side of door	N/A
	604.8.1.2c	Is stall door self-closing	N/A
	309.4	Door lock: operable by closed fist	N/A
	404.2.7c	Height of door lock: 34"-48"	N/A
	604.8.1.1a	Stall width: 60" min.	N/A
	604.8.1.1b	Stall depth: 56" min. wall hung toilet	N/A
	604.8.1.1c	Stall depth: 59" min. floor mounted toilet	N/A
	604.6c	Height of flush control: 15"-48"	N/A
604.8.1.1d	Stall has door swing if door swings in	N/A	

Unisex Restroom 1

Signage	Id	Name	Status
	216.8	Sign with ADA symbol	N/A
	703.2	Raised characters	N/A
	703.3	Braille	N/A
	703.4.2	Located at latch side of door	N/A
	703.4.1	Mounting height 48-60"	N/A

Restroom Entrance	Id	Name	Status
	404.2.3	Door opening width: 32" min. when open 90 degrees	true
	404.2.4	18" on pull side of door plus 60" clear	true
	404.2.7-a	Accessible handles operated by closed fist	true
	404.2.7-b	Handle height 34"-48"	true
	404.2.5	Threshold 1/2" Max Height. 1/4" + 1/4" beveled	true
	303.3	3/4" threshold present, is it beveled on both sides with slope no greater than 1:2	No threshold present
404.2.6	Vestibule: 48" min. plus width of doors	N/A	

Inside Restroom	Id	Name	Status
	603.2.1, 304.3	Clear floor space: 60" diameter circle	true
	604.2	Toilet centerline from wall: 16"-18"	true
	604.3.1	Toilet clear floor space: 60" from side wall and 56" from rear wall	false
	604.4	Height of toilet seat: 17"-19"	true
	604.6a	Height of flush control: 15"-48"	true
	604.6b	Flush control located on open side of toilet	true
	604.5.1	Side wall grab bar: 42" L, 12" max. from wall	true
	609.4a	Side wall grab bar: 33"-36" H to top	true
	604.5.2	Rear wall grab bar: 36" L, 12" & 24" center line toilet	N/A
	609.4b	Rear wall grab bar: 33"-36" H to top	N/A
	604.7a	TP dispenser: 7"-9" from front of toilet to center line	N/A
	604.7b	Height of TP dispenser: 15"-48"	N/A
	604.7c	TP dispenser not located behind grab bar	N/A
	606.2	Sink clear floor space: 30" W x 48" D	true
	606.3	Height of sink rim: 34" max.	true
	306.6.6	Knee clearance: 27" H min. x 8" D min.	true
	606.5	Pipe protection below sink	false
	606.4	Faucet handles: operable by closed fist	true
	603.3a	Bottom of mirror: 40" H max. if over sink	false
603.3b	Bottom of mirror: 35" H max. if not over sink	N/A	
308.2.2	Soap dispenser: 44" H max. if above sink	N/A	
308.2	Soap dispenser: 48" H max. not above sink	N/A	
308.2.2, 308.2a	Paper towel dispenser: (same as soap)	true	
308.2.2, 308.2b	Electric hand dryer: (same as soap)	true	

Toilet Compartments (Stalls)	Id	Name	Status
	604.8.1.2a	Door opening width: 32" min. when open 90 degrees	N/A
	604.8.1.2b	18" on pull side of door	N/A
	604.8.1.2c	Is stall door self-closing	N/A
	309.4	Door lock: operable by closed fist	N/A
	404.2.7c	Height of door lock: 34"-48"	N/A
	604.8.1.1a	Stall width: 60" min.	N/A
	604.8.1.1b	Stall depth: 56" min. wall hung toilet	N/A
	604.8.1.1c	Stall depth: 59" min. floor mounted toilet	N/A
	604.6c	Height of flush control: 15"-48"	N/A
	604.8.1.1d	Stall has door swing if door swings in	N/A