Restroom 1

	Id	Name	Status
Signage	216.8	Sign with ADA symbol	true
	703.2	Raised characters	true
	703.3	Braille	true
	703.4.2	Located at latch side of door	true
	703.4.1	Bottom of lettering is between 48-60" from the ground	true

	Id	Name	Status
Restroom Entrance	404.2.3	Door opening width: 32" min. when open 90 degrees	true
	404.2.4	18" on pull side of door plus 60" clear	true
	404.2.7-a	Accessible handles operated by closed fist	true
	404.2.7-b	Handle height 34"-48"	true
	404.2.5	Threshold 1/2" Max Height. 1/4" + 1/4" beveled	No threshold present
	303.3	3/4" max height threshold present, and is beveled on both sides with slope no greater than 1:2	No threshold present
	404.2.6	Vestibule: 48" min. plus width of doors	N/A

	Id	Name	Status
Inside Restroom	603.2.1, 304.3	Clear floor space: 60" diameter circle	false
	604.2	Toilet centerline from wall: 16"-18"	true
	604.3.1	Toilet clear floor space: 60" from side wall and 56" from rear wall	true
	604.4	Height of toilet seat: 17"-19"	true
	604.6a	Height of flush control: 15"-48"	true
	604.6b	Flush control located on open side of toilet	true
	604.5.1	Side wall grab bar: 42" L, 12" max. from wall	true
	609.4a	Side wall grab bar: 33"-36" H to top	true
	604.5.2	Rear wall grab bar: 36" L, 12" & 24" center line toilet	true
	609.4b	Rear wall grab bar: 33"-36" H to top	true
	604.7a	TP dispenser: 7"-9" from front of toilet to center line	true
	604.7b	Height of TP dispenser: 15"-48"	true
	604.7c	TP dispenser not located behind grab bar	true
	606.2	Sink clear floor space: 30" W x 48" D	true
	606.3	Height of sink rim: 34" max.	true
	306.6.6	Knee clearance: 27" H min. x 8" D min.	false
	606.5	Pipe protection below sink	true
	606.4	Faucet handles: operable by closed fist	true
	603.3a	Bottom of mirror: 40" H max. if over sink	N/A
	603.3b	Bottom of mirror: 35" H max. if not over sink	N/A
	308.2.2	Soap dispenser: 44" H max. if above sink	N/A
	308.2	Soap dispenser: 48" H max. not above sink	N/A
	308.2.2, 308.2a	Paper towel dispenser: (same as soap)	N/A
	308.2.2, 308.2b	Electric hand dryer: (same as soap)	N/A

© 2026 ID Plans | All rights rese

	Id	Name	Status
Toilet Compartments (Stalls)	604.8.1.2a	Door opening width: 32" min. when open 90 degrees	N/A
	604.8.1.2b	18" on pull side of door	N/A
	604.8.1.2c	Is stall door self-closing	N/A
	309.4	Door lock: operable by closed fist	N/A
	404.2.7c	Height of door lock: 34"-48"	N/A
	604.8.1.1a	Stall width: 60" min.	N/A
	604.8.1.1b	Stall depth - wall hung toilet: 56" min. and door swing does not impede	N/A
	604.8.1.1c	Stall depth - floor mounted toilet: 59" min. and door swing does not impede	N/A

Restroom 2

	Id	Name	Status
Signage	216.8	Sign with ADA symbol	true
	703.2	Raised characters	true
	703.3	Braille	true
	703.4.2	Located at latch side of door	true
	703.4.1	Bottom of lettering is between 48-60" from the ground	true

	Id	Name	Status
Restroom Entrance	404.2.3	Door opening width: 32" min. when open 90 degrees	true
	404.2.4	18" on pull side of door plus 60" clear	true
	404.2.7-a	Accessible handles operated by closed fist	true
	404.2.7-b	Handle height 34"-48"	true
	404.2.5	Threshold 1/2" Max Height. 1/4" + 1/4" beveled	No threshold present
	303.3	3/4" max height threshold present, and is beveled on both sides with slope no greater than 1:2	No threshold present
	404.2.6	Vestibule: 48" min. plus width of doors	N/A

© 2026 ID Plans | All rights rese

	Id	Name	Status
Inside Restroom	603.2.1, 304.3	Clear floor space: 60" diameter circle	false
	604.2	Toilet centerline from wall: 16"-18"	true
	604.3.1	Toilet clear floor space: 60" from side wall and 56" from rear wall	true
	604.4	Height of toilet seat: 17"-19"	true
	604.6a	Height of flush control: 15"-48"	true
	604.6b	Flush control located on open side of toilet	true
	604.5.1	Side wall grab bar: 42" L, 12" max. from wall	true
	609.4a	Side wall grab bar: 33"-36" H to top	true
	604.5.2	Rear wall grab bar: 36" L, 12" & 24" center line toilet	true
	609.4b	Rear wall grab bar: 33"-36" H to top	true
	604.7a	TP dispenser: 7"-9" from front of toilet to center line	true
	604.7b	Height of TP dispenser: 15"-48"	true
	604.7c	TP dispenser not located behind grab bar	true
	606.2	Sink clear floor space: 30" W x 48" D	true
	606.3	Height of sink rim: 34" max.	true
	306.6.6	Knee clearance: 27" H min. x 8" D min.	false
	606.5	Pipe protection below sink	true
	606.4	Faucet handles: operable by closed fist	true
	603.3a	Bottom of mirror: 40" H max. if over sink	N/A
	603.3b	Bottom of mirror: 35" H max. if not over sink	N/A
	308.2.2	Soap dispenser: 44" H max. if above sink	N/A
	308.2	Soap dispenser: 48" H max. not above sink	N/A
	308.2.2, 308.2a	Paper towel dispenser: (same as soap)	N/A
	308.2.2, 308.2b	Electric hand dryer: (same as soap)	N/A

© 2026 ID Plans | All rights rese

	Id	Name	Status
Toilet Compartments (Stalls)	604.8.1.2a	Door opening width: 32" min. when open 90 degrees	N/A
	604.8.1.2b	18" on pull side of door	N/A
	604.8.1.2c	Is stall door self-closing	N/A
	309.4	Door lock: operable by closed fist	N/A
	404.2.7c	Height of door lock: 34"-48"	N/A
	604.8.1.1a	Stall width: 60" min.	N/A
	604.8.1.1b	Stall depth - wall hung toilet: 56" min. and door swing does not impede	N/A
	604.8.1.1c	Stall depth - floor mounted toilet: 59" min. and door swing does not impede	N/A

© 2026 ID Plans | All rights rese