



HUB TESTING LABORATORY, INC.

Environmental Testing and Consulting Service

Certified Woman-owned Business Enterprise (WBE)

May 17, 2016

95 Beaver Street
Waltham, MA 02453

Report For: City of Somerville-DPW
Attn: Walter Whitney
Superintendent of Buildings & Grounds
1 Franey Road
Somerville, MA 02145

(781) 893-8330
FAX (781) 893-4414
www.hubtesting.net

Hub ID: 26198

Project ID: Dr. Albert F. Argenziano School at Lincoln Park
290 Washington Street

Date Collected: May 11, 2016

Scope: Twelve (12) samples of water were collected by Hub Testing Laboratory at the above noted project address. It was requested that the samples be analyzed for lead and copper. The samples were collected from kitchen sinks and water fountains through the school. Sinks and fountains were flushed the previous evening and sampled as a first draw sample in the morning before being occupied.

Methodology: Lead was analyzed using SM 3113B. Copper was analyzed using EPA 200.7.

Results:


Hub ID	Location	Lead (mg/L)	Copper (mg/L)	Standard/Limit
26198-A1	1 st Floor, Kitchen	0.004	0.14	Copper – 1.3 mg/L Lead - 0.015 mg/L
26198-A2	1 st Floor, Kitchen	0.005	0.11	
26198-A3	1 st Floor, Kitchen	0.002	0.14	
26198-A4	1 st Floor, Kitchen	ND	0.14	
26198-A5	1 st Floor, Near to the stage and café, high	ND	0.12	
26198-A6	1 st Floor, Near to the stage and café, low	ND	0.12	
26198-A7	1 st Floor, Inside the gym, high	ND	0.12	
26198-A8	1 st Floor, Inside the gym, low	ND	0.1	
26198-A9	2 nd Floor, Near to row 211-216, high	ND	0.17	
26198-A10	2 nd Floor, Near to row 211-216, low	ND	0.14	
26198-A11	3 rd Floor, Near to the music row 312-316, high	ND	0.091	
26198-A12	3 rd Floor, Near to the music row 312-316, low	ND	0.091	

Lab Certification #: MA1118

ND – None Detected

MCL – Maximum Contaminant Level established by the EPA – it is the maximum permissible level of a contaminant in water that is delivered to any consumer of a public water system.

Comments: The MCL for Lead in drinking water is 0.015mg/L and the MCL from Copper is 1.3 mg/L. All of the samples submitted are below the acceptable recommended measurements for primary characteristics for drinking water as proposed by the Environmental Protection Agency and/or Massachusetts Drinking Water Standards.

A handwritten signature in cursive script, appearing to read "Susan Boyle".

Susan Boyle, President
Hub Testing Laboratory