July 6, 2010

Re: Clearance Testing
130 Fashion Avenue
Connelly Springs, NC 28612

Dear

I made a site visit to the property on Friday, July 2, 2010. At that time, I conducted a visual assessment and determined that the exterior stabilization and painting had been performed, and any paint chips from the work had been properly removed.

The door casings on sides A & B of the porch have been replaced with new pre-hung exterior doors. The deteriorated paint on the crawl space vent has been stabilized.

There was no evidence of paint chips on the porch or on the ground at the vent.

This property has passed the clearance requirements.

If I can be of further assistance, please contact me.

Sincerely,