

CIVIL LEGEND			
	BEEHIVE INLET		POST
	BUSH		POWER POLE
	CURB INLET		SIGN
	COMBINATION POLE		SANITARY MANHOLE
	DELINEATOR		STAND PIPE
	DRAINAGE MANHOLE		STUMP
	ELECTRIC HANDHOLE		TELEPHONE HANDHOLE
	ELECTRIC METER BOX		TELEPHONE POLE
	FIRE HYDRANT		TELEPHONE PEDESTAL
	GAS MARKER SIGN		TREE
	GAS VALVE		VENT
	GUY WIRE		WELL
	INLET		WATER METER
	LIGHT POLE		WATER MANHOLE
	MAILBOX		WATER VALVE

**LIGHTING NOTES:**  
 - Mounting Height = 30'  
 - Light Loss Factor = 0.90  
 - Footcandle Values Calculated @ Grade  
 - Reflectance Values - 80/50/20 (office spaces)

(warehouse areas) 50/30/20  
**N.1** STUBBED INTO WAREHOUSE & TERMINATED INTO 4" SQUARE J-BOX FOR FUTURE USE  
**N.2** CAPPED BELOW GRADE FOR FUTURE USE


Symbol	Qty	Label	Arrangement	Lum. Lumens	LLF	Lum. Watts	Description
	20	X-WM4	WALL MOUNT	37815	0.900	317.8	SLM-LED-36L-SIL-FT-50-70CRI
	1	X-SS	SINGLE	35784	0.900	317.8	SLM-LED-36L-SIL-5W-50-70CRI

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Left Car Parking & Drives	Illuminance	Fc	1.78	4.4	0.0	N.A.	N.A.
Property Line	Illuminance	Fc	0.03	0.5	0.0	N.A.	N.A.
Right Car Parking & Drives	Illuminance	Fc	1.89	4.9	0.0	N.A.	N.A.
Trailer Paved Areas & Drives	Illuminance	Fc	0.69	5.3	0.0	N.A.	N.A.
60' Out Bottom Dock	Illuminance	Fc	1.88	4.9	0.1	18.80	49.00
60' Out Top Dock	Illuminance	Fc	1.88	5.3	0.1	18.80	53.00

**SITE PHOTOMETRICS**  
 NOT TO SCALE



**CURRAN ARCHITECTURE**  
 5719 LAWTON LOOP E. DR. SUITE 212  
 INDIANAPOLIS, IN 46216  
 O :: 317.288.0681  
 F :: 317.288.0753



**Edwards Electrical & Mechanical**  
 2350 North Shadeland Avenue  
 Indianapolis, IN 46219-1736  
 Phone: (317) 543-3460  
 Fax: (317) 543-3476  
 Indianapolis - Cincinnati - Columbus, OH  
 DRAWN BY: KVAUGHN  
 CHECKED BY: LSHEETZ

**APM 17**  
 PLAINFIELD, IN 46168  
 20032