



Symbol	Qty	Label	Arrangement	LLF	Description	Arr. Watts	Total Watts
○	48	D2	SINGLE	0.950	SPECTRUM C0606GV-15L-30K-DRIVE-TSG-SO-SM-EMCR-FINISH	10	480
□	6	H4	SINGLE	0.950	LUMCA PL70-EHD14 M1 CP2401- 48LED05-40K-L4 @14'AFG	80.01	480.06
△	12	WP4	SINGLE	0.900	TRACELITE WLZ4-4-3K-FINISH @14'AFG	41.0529	492.6348
▽	6	H5	SINGLE	0.950	LUMCA PL70-EHD14 M1 CP2401- 36LED07-40K-H5S @14'AFG	81.2	487.2
○	3	H3	SINGLE	0.950	LUMCA PL70-EHD14 M1 CP2401- 54LED05-40K-L3 @14'AFG	88.3	264.9
□	2	WP3-EM	SINGLE	0.950	TRACELITE WLZ4-4-3K-FINISH-BB @14'AFG	40.9964	81.9928
□	2	S1	SINGLE	0.950	OPETEC 0LFLS-20-VOLT-30-5X5-MOUNT-FINISH-UV	20	40

**NOTES:**  
 -Contact Techlite for pricing. (317) 578-2626  
 -All readings taken at grade  
 -Buildings included as blocking entities  
 -Fixture Symbols are not to scale  
 -This drawing shows suggested fixtures and mounting locations based on the information provided.  
 -Techlite assumes no responsibility for variation of light levels that result from changes in project parameters not reported at the time of design.

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
CalcPls_1	ILLUMINANCE	Fc	1.85	17.1	0.0	N.A.	N.A.
PROPERTY	ILLUMINANCE	Fc	0.53	6.0	0.0	N.A.	N.A.
PARKING EAST	ILLUMINANCE	Fc	1.96	15.6	0.2	9.80	78.00
PARKING SOUTH	ILLUMINANCE	Fc	1.29	2.7	0.3	4.30	9.00
PARKING WEST	ILLUMINANCE	Fc	2.13	17.1	0.1	21.30	171.00

#	Date	Comments

Drawn By: SLB  
 Checked By: DM  
 Date: 7/15/2021  
 Scale: 1"=20'

Site Photometry  
 Stanley Terrace