PIPE ROLLS & SADDLES



Fig. 171: Pipe Roll

Single Pipe Roll

Size Range: 1" through 30"

Material: Cast iron roll and sockets, steel roll rod

Finish: Plain, Zinc Plated (Hot-Dip Galvanized optional) or Resilient Coated

Service: For suspension of pipe from two rods where longitudinal expansion and contraction may occur.

Approvals: Complies with Federal Specification A-A-1192A (Type 41), WW-H-171-E (Type 42),

ANSI/MSS SP-69 and MSS SP-58 (Type 41).

Adjustment: Adjustable socket permits vertical adjustment at the roll. **Maximum Temperature:** 400° F at roller, 300° F at resilient coated roller.

How to size:

- (1) If the roll is to support non-insulated pipe, select the size directly from nominal pipe size (column 1) in table below.
- (2) If used with pipe covering protection saddle, see Figure 160 to Figure 166A for size of pipe roll.

Features:

- Provides for vertical adjustment; nut at bottom of hanger rod fits into the socket preventing loosening or turning due to vibration.
- Pipe roll is designed for two point surface contact with pipe or saddle.

Features: Advantages of pipe rollers with a protective resilient coated covering.

- Non conductive pipe rollers prevent the passing of current from pipeline to structure.
- Corrosion resistant for protection against severe weather conditions, moderate corrosive
 conditions such as marine atmospheres and weather resistant to ultra-violet radiation.
- Low coefficient of friction between pipe and resilient coated pipe roller.

Ordering:

- Specify pipe roll size.
- Order should include figure number, name and finish in all cases. Hanger rods and nuts to be ordered separately.
- Be certain to order oversized rolls when insulation and protection saddles makes this necessary.

FIG. 171: DIMENSIONS (IN) • LOADS (LBS) • WEIGHT (LBS)															
Pipe Size	Max O.D. Covering	Rod Size A	Max Load	Weight	G	В	C	D	E	F	Н	J			
1	2	3/8	600	0.45	41//8	3	11/2	1	3/4	3/8	11/16	9/16			
11/4	21/2			0.48	41/2	3%	11//8	1 ½16			11/4				
1 ½	23/4			0.51	43/4	35/8	21//8	1 ½			13//8				
2	31/4			0.57	5 ¹ / ₄	4½	2 5// ₈	1 3⁄16			1 5%				
21/2	3¾	1/ ₂	660	1.00	61/4	4 ⁷ / ₈	31//8	1%	7/8		1 ¹⁵ / ₁₆	11/16			
3	41/2		1/2	700	1.10	67//8	51/2	33/4	1 ⁷ / ₁₆	/8	1/2	21/4	/16		
3½	5				1.40	71/2	61//8	41/4	1%	1		29/16	3/4		
4	5½		56 750	1.70	81/4	67//8	43/4	13/4	'		2 ¹³ / ₁₆				
5	7		7/8	78	78	7/8		2.60	911/16	8 ¹ / ₁₆	5 ¹³ / ₁₆	2	1½	5/8	3 ⁷ / ₁₆
6	81/4	3/4	1,070	4.50	11 ⁷ ⁄ ₁₆	9%16	67//8	2 5⁄16	11/4	3/4	4	1			
8	10½	74	74	1,350	7.20	14 ½16	11 ¹⁵ / ₁₆	87//8	2 ¹³ / ₁₆	1½	7/8	5½	1 ½		
10	123/4	7/8	1,730	9.50	16 3⁄16	14 ½16	11	3%	13/4	/8	63//8	1 /8			
12	143/4		2,400	15.90	17 ¹⁵ ⁄ ₁₆	15 ¹³ / ₁₆	12 ¹ / ₂	37//8	2	1	7 ⁷ / ₁₆	11/4			
14	16 ¹ / ₄	1 1 1 1/4	3,130	24.30	201//8	17¾	14 ¹ / ₄	4 5%	2 ½	1½	83//8	13//8			
16	18		1 [3,970	31.90	221/8	19¾	16½	5	2 5// ₈		97/16	11/2		
18	201/4		4,200	35.50	24½	21 ⁷ / ₈	18½	5 ⁷ / ₁₆	23/4	11/4	10½	1 /2			
20	221/2		4,550	47.00	271/4	241/4	201/4	6	3		115//8	15%			
24	26½	11/2	6,160	76.30	32½	28 ⁷ / ₈	241/4	73/16	35//8	11/2	14	13/4			
30	32½		7,290	129.90	39	35½	301/4	815/16	41/2	13/4	17 ⁷ / ₁₆	27/16			

DI/CI ROLL SIZING					
DI/CI Pipe Size	Fig. 171 Roller Size				
3	4				
4	5				
6	6				
8	8				
10	10				
12	14				
14	16				
16	18				
18	20				
20	24				
24	30				
30	No Recom.				

PROJECT INFORMATION	APPROVAL STAMP
Project:	☐ Approved
Address:	☐ Approved as noted
Contractor:	☐ Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	

•					
e ro	oll.		୍ଦ		
g	→ A		+		1
			<u> </u>		H
2. 2		D	E	F	
		1_	C		J