



# INFORMATION

Note: This document contains addenda information that is supplemental to that found in the LEED Interpretations and Addenda database, found on <http://www.usgbc.org>.

Addenda Number	Post Date	Rating System	Category	Credit ID	Ref Guide	Issue Type	Page	Location	Supplemental Document
100001072	11/1/2011	New Construction v2009 Schools v2009 Core & Shell v2009 Retail, New Construction v2009 Healthcare v2009	Water Efficiency	WEp1: Water Use Reduction	Green Building Design and Construction, 2009 edition  Green Building Design and Construction, 2009 Edition, updated June 2010  Retail Supplement to Green Building Design and Construction, 2009 edition  Healthcare Supplement to Green Building Design and Construction, 2009 edition	Non-grammatical	BD+C RG: 165, Retail-NC RG supp: 39, HC RG supp: 75, Retail NC RS: 24, HC RS: 31	NC, SCHOOLS & CS box	Revised table

**ISSUE:** Replace the section's first table with the following

Commercial Fixtures, Fittings, and Appliances	Current Baseline (Imperial Units)
Commercial toilets	1.6 gallons per flush (gpf)* Except blow-out fixtures: 3.5 (gpf)
Commercial urinals	1.0 (gpf)
Commercial lavatory (restroom) faucets	2.2 gallons per minute (gpm) at 60 pounds per square inch (psi), private applications only (hotel or motel guest rooms, hospital patient rooms) 0.5 (gpm) at 60 (psi)** all others except private applications 0.25 gallons per cycle for metering faucets
Showerheads	2.5 (gpm) at 80 (psi) per shower stall ****
For projects with commercial pre-rinse spray valves, the flow rate must comply with the ASME A112.18.1 standard of 1.6 gpm or less.	