



INFORMATION

Note: This document contains addenda information that is supplemental to that found in the LEED Interpretations and Addenda database, found on <http://www.usgbc.org>.

Addenda Number	Post Date	Rating System	Category	Credit ID	Ref Guide	Issue Type	Page	Location	Supplemental Document
		New Construction v2009 Schools v2009 Core & Shell v2009 Retail, New Construction v2009							
100001074	11/1/2011	Healthcare v2009	Water Efficiency	WEc3: Water Use Reduction	N/A	Non-grammatical	NC RS: 30, CS RS: 30, Schools RS: 36	Requirements	Revised table

ISSUE: Replace the section's first table with the following

Commercial Fixtures, Fittings, and Appliances	Current Baseline (Imperial Units)	Current Baseline (Metric units)
Commercial toilets	1.6 gallons per flush (gpf)* Except blow-out fixtures: 3.5 (gpf)	6 liters per flush (lpf) Except blow-out fixtures: 13 lpf
Commercial urinals	1.0 (gpf)	4 lpf
Commercial lavatory (restroom) faucets	2.2 gallons per minute (gpm) at 60 pounds per square inch (psi), private applications only (hotel or motel guest rooms, hospital patient rooms) 0.5 (gpm) at 60 (psi)** all others except private applications 0.25 gallons per cycle for metering faucets	8.5 liters per minute (lpm) at 4 bar (58 psi), private applications only (hotel or motel guest rooms, hospital patient rooms) 2.0 lpm at 4 bar (58 psi), all others except private applications 1 liter per cycle for metering faucets
Showerheads	2.5 (gpm) at 80 (psi) per shower stall ****	9.5 lpm at 5 bar (58 psi)

For projects with commercial pre-rinse spray valves, the flow rate must comply with the ASME A112.18.1 standard of 1.6 gpm or less.