



INFORMATION

Note: This document contains addenda information that is supplemental to that found in the LEED Interpretations and Addenda database, found on <http://www.usgbc.org>.

Addendum Details:

Addenda Number	Post Date	Rating System	Category	Credit ID	Ref Guide	Issue Type	Page	Location	Supplemental Document
100000364	11/02/2009		Energy and Atmosphere	EAc4: Enhanced Refrigerant Management/Ozone Depletion	BD+C, 2009	Non-grammatical	311	Second paragraph	New text
ISSUE: Beginning in the second line of the paragraph beginning with “Refrigerant leakage rate (Lr)...,” remove the text below.									

Supplemental Document:

Text
<p>Applicants may use alternate values for Lr and Mr, provided their alternative values are approved by USGBC. If their alternative values have not yet been reviewed by USGBC, information demonstrating and documenting their alternative values may be considered for approval. Documentation provided for review must include, at a minimum, the following:</p> <ul style="list-style-type: none">▪ Manufacturers’ test data for refrigerant leakage rates (percent per year)▪ Refrigerant leak detection equipment in the room where the equipment is located▪ Preventive maintenance program for minimizing equipment refrigerant leakage▪ Program for recovering and recycling refrigerant at the end of equipment life <p>Projects may not claim zero leakage over the life of the HVAC&R equipment.</p>