



Addendum Details:

Addenda Number	Post Date	Rating System	Category	Credit ID	Ref Guide	Issue Type	Page	Location
100000891	5/9/2011	New Construction v2009 , Schools v2009 , Retail, New Construction v2009 , Commercial Interiors v2009, Retail, Commercial Interiors v2009	Indoor Environmental Quality	IEQc3.2: Construction IAQ Management Plan-Before Occupancy	Green Building Design and Construction, 2009 edition , Green Building Operations and Maintenance, 2009 edition , Green Interior Design and Construction, 2009 edition , Retail Supplement to Green Interior Design and Construction, 2009 edition , Retail Supplement to Green Building Design and Construction, 2009 edition	Non-grammatical	NC RS:64-65, Schools RS: 67, BD+C RG: 461-462; CI RS: 44-45, ID+C RG: 323-324; Retail-CI RS:41-42, CI Retail RG:107-108 Retail-NC RS:58-59, NC Retail RG:119-120	Table

ISSUE: Replace table with below

Supplemental Document:

Contaminant	Maximum Concentration	EPA Compendium method	ISO method
Formaldehyde	27 parts per billion	IP-6	ISO 16000-3
Particulates (PM10)	50 micrograms per cubic meter	IP-10	ISO 7708
Total volatile organic compounds (TVOCs)	500 micrograms per cubic meter	IP-1	ISO 16000-6
4-Phenylcyclohexene (4-PCH)*	6.5 micrograms per cubic meter	IP-1	ISO 16000-6
Carbon monoxide (CO)	9 part per million and no greater than 2 parts per million above outdoor levels	IP-3	ISO 4224
*This test is required only if carpets and fabrics with styrene butadiene rubber (SBR) latex backing are installed as part of the base building systems.			