



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

11 April 2025

Damian

Central CA Conference - Camp Wawona

P.O.Box 2055

Wawona, CA 95389

RE: CA2203051-Distribution

Enclosed are the results for sample(s) received on 08-Apr-25 16:00 by Precision Enviro-Tech. The sample(s) were analyzed according to instructions in accompanying chain-of-custody, utilizing EPA or other ELAP approved methodologies and . Results are summarized on the following pages.

Note: Total Coliform and E.Coli Test in Drinking Water using Coli-ert (P/A) or by Quanti-Tray testing method. The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1 (for Quanti-Tray method) to meet drinking water requirements. All other testing parameter results must be below **MCL** to meet drinking water requirements. (**MCL-Maximum contaminant level** is the highest concentration of chemicals permitted in drinking water systems)

Thank you for the opportunity to service the needs of your company.

Sincerely,

Jonathan H. V. Le

Technical Manager



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

CERTIFICATE OF ANALYSIS

Central CA Conference - Camp Wawona

P.O.Box 2055

Wawona, CA 95389

Project Number: Distribution

Project Name: CA2203051

Project Manager: Damian

Work Order No.:

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Restroom by Kitchen	2504150-01	Water	08-Apr-25 09:37	08-Apr-25 16:00
Alder	2504150-02	Water	08-Apr-25 09:51	08-Apr-25 16:00



Central CA Conference - Camp Wawona
P.O.Box 2055
Wawona, CA 95389

Project Number: Distribution
Project Name: CA2203051
Project Manager: Damian

Work Order No.:

Conventional Chemistry Parameters by APHA/EPA Methods

Analyte	Reporting								Notes
	Result	Limit	Units	Dilution	Batch	Analyzed	Method	MCL	
Restroom by Kitchen (2504150-01) Water Sampled: 08-Apr-25 09:37 Received: 08-Apr-25 16:00									
Color	ND	1.00	Color Units	1	AD50832	08-Apr-25	SM 2120 B	15	
Threshold Odor Number	1	1	T.O.N.	"	AD50832	"	SM 2150 B	3	
Turbidity	0.151	0.02	NTU	"	AD50831	08-Apr-25	SM 2130 B	5	
Alder (2504150-02) Water Sampled: 08-Apr-25 09:51 Received: 08-Apr-25 16:00									
Color	ND	1.00	Color Units	1	AD50832	08-Apr-25	SM 2120 B	15	
Threshold Odor Number	1	1	T.O.N.	"	AD50832	"	SM 2150 B	3	
Turbidity	0.291	0.02	NTU	"	AD50831	08-Apr-25	SM 2130 B	5	



Central CA Conference - Camp Wawona
P.O.Box 2055
Wawona, CA 95389

Project Number: Distribution
Project Name: CA2203051
Project Manager: Damian

Work Order No.:

Microbiological Parameters by APHA Standard Methods

Analyte	Result	Reporting		Dilution	Batch	Analyzed	Method	MCL	Notes
		Limit	Units						

Restroom by Kitchen (2504150-01) Water Sampled: 08-Apr-25 09:37 Received: 08-Apr-25 16:00

Residual Chlorine	ND	0.0200	mg/L	1	AD50831	08-Apr-25	Hach (10ml Vial & Reagent)		
Total Coliforms	ABSENT	1	A/P/100mL	"	AD50836	08-Apr-25	SM 9223 B		
E. Coli	ABSENT	1	"	"	AD50836	"	"		

Alder (2504150-02) Water Sampled: 08-Apr-25 09:51 Received: 08-Apr-25 16:00

Residual Chlorine	ND	0.0200	mg/L	1	AD50831	08-Apr-25	Hach (10ml Vial & Reagent)		
Total Coliforms	ABSENT	1	A/P/100mL	"	AD50836	08-Apr-25	SM 9223 B		
E. Coli	ABSENT	1	"	"	AD50836	"	"		



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

CERTIFICATE OF ANALYSIS

Central CA Conference - Camp Wawona

P.O.Box 2055

Wawona, CA 95389

Project Number: Distribution

Project Name: CA2203051

Project Manager: Damian

Work Order No.:

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	RPD	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-----	-------

Notes and Definitions

Item	Definition
------	------------

Dry Sample results reported on a dry weight basis.

ND Analyte NOT DETECTED at or below the reporting limit.

mg/L = milligrams per Liter = ppm

G- Grab Sample

ug/L = micrograms per Liter = ppb

C-Composite Sample

Comp-Grab- Composite of 4 Grab Sample during 24hrs Grab period and composite into 1 sample prior analysis .

DLR = Detection Limit for Purpose of Reporting.

Exceptional sample matrices or interferences may result in higher detection limits.

MCL- Maximum contaminant level (MCL) is the highest concentration of chemicals permitted in drinking water systems

RPD Relative Percent Difference

%REC Percent Recovery

Source Sample that was matrix spiked or duplicated.

MMO-MUG-P/A - Total Coliform and E.Coli Test in Drinking Water by MMO-MUG, using Standard Method 22nd Edition.

The State Board of Health requires that bacteriological results must be 'ABSENCE' or less than 1.1 (for MTF method) to meet drinking water requirements.

PRECISION ENVIRO-TECH
Field Office
18843 Fir Drive
Twain Harte, CA 95383

Work Order No.

250450

Page 6 of 6