

CITY OF COURTENAY
BUILDING INSPECTOR'S REPORT

Type of Inspection: Occupancy
Permit No. 6121 Time 9:30
Street Address 4646 Northland
Owner Matten
Building Inspector J. New Date Apr 27/94

unit A+B req. flashing at
garage door.

Security screws (2 per hinge
req'd at front & garage/hse.
door. (A+B)
leak under upstairs bathroom
sink. (Unit A.)

Approved for occupancy
and final when above
completed.