

# Property Owners Reminded of Sprinkler Head Recall

*Observer 8/6/98*

The Winter Park Fire Department and Maitland Fire/Rescue and Building Fire Loss Management divisions are reminding property owners and building managers of a program to help insure the safety of their facilities.

As had been previously announced through the news media, a problem and subsequent voluntary recall and a remediation program has been instituted by the Central Sprinkler Company in regard to their Omega style sprinkler heads. These particular heads have had their performance questioned by the Consumer Product Safety Commission. The

sprinkler heads are being recalled due to a problem with their EPDM O-ring. They were manufactured prior to June 6, 1996.

It is recommended that property owners or building managers who suspect they may have Omega style heads in their buildings have the system checked by competent, trained individuals or companies familiar with this product. If any of the suspect heads are found, contact the Central Sprinkler Company, Omega Customer Service Department at (800) 638-1531 to determine the necessary procedure for replacement.