

ARAMCO APPROVAL FOR ENCAPSULATION

BIO HAZARDS - Exiting Asbestos and Lead based paints

Please plan to visit Juaymah Pier Warehouse to provide us with official quotation for supply and apply of Rust Grip as asbestos encapsulation method. EPD has accepted the Rust Grip provided that the contractor will guarantee the shelf life for the application to last 50 years under normal occupational and environmental conditions.

Regards,

Nabeel Faleh

TSU Project Engineer

Tel.(+966 3) 678-6081

Fax.(+966 3) 673-3143

ENVIRONMENTAL COMPLIANCE DIVISION
Environmental Protection Department
Building 9156, Rm. 128-A, Dhahran Heights, Dhahran
☎ 876-0321 📠 876-0330

May 30, 2009

ECD- 082/09

**Asbestos Abatement –
Juaymah Pier Warehouse**

Jarallah A Sudairy, **Supt Terminal Engineering**
R-N-2046, Floor 2, East Wing,
Ras Tanura North Admin. Bldg.
Ras Tanura

Further to our letter ECD-058/09, dated April 12, 2009, EPD specialists met with the contractor and applicator of Rust Grip Encapsulation Technology to discuss potential limitations applicable to the use of this technology at Juaymah Pier Warehouse.

The contractor agreed to guarantee the shelf life for the application to last 50 years under normal occupational and environmental conditions. With this assurance, EPD has no objection to the application of encapsulation technology at Juaymah Pier Warehouse; and hence it is a business decision for Terminal Department to make, provided periodic visual assessments are done to ensure the condition of the encapsulated materials do not deteriorate.

Should you have any questions or need clarification, please direct them to Joe Ngao, on 876-0329.



K. M. AL-TURKI, General Supervisor
Environmental Compliance Division

JON/KMT
cc: EPD Manager
Letter book