

INSULATION TEST CERTIFICATE	Nr.:	94630
	Date:	07/05/2025

Pag. 1 de 1.

1. GENERAL TEST DATA	
Requester:	Tramontina Garibaldi S.A. Ind. Met.
Test date:	07/05/2025
Place:	Tramontina Garibaldi S.A. Test Laboratory, located at Tramontina Street, 600 – Garibaldi – RS
Environmental Condition:	Temperature from 18 °C to 28 °C and 45% to 75% relative humidity
Test method:	Before the test, the sample is conditioned as described in IEC 60900:2018, sections 5.5.2.2 or 5.5.2.3. After the conditioning period, the sample is submitted to voltage of 10 kV r.m.s (60 Hz) for 3 minutes, in accordance with item 5.5.3 – Dielectric Test of Insulated Hand Tools, of the aforementioned standard.

2. TESTED ITEM IDENTIFICATION	
Manufacturer:	Tramontina Garibaldi S.A. Ind. Met.
Description of tested item:	1/2" IEC 60900 6 Point Socket 30mm
Reference:	44335/030
Manufacturing order number:	1047021
Sample:	The tested samples come from the industrial process of the aforementioned manufacturing order.

3. STANDARD IDENTIFICATION	
Equipment:	High Voltage Source
Identification Number:	100/013
Traceability:	Calibrated by LABELO Laboratory, recognized by Cgcre/Inmetro CAL 0024, Calibration Certificate No. E0009/2020, according to PL015.

4. TEST RESULT IN ACCORDANCE TO IEC 60900:2018 STANDARD	
Batch representative sample	RESULT
44335/030	Approved

NOTES:

- a) This tool underwent insulation testing, and even after long storage periods, it is suitable for use.
After the first application, annual recertification is necessary.
- b) The results shown herein are related exclusively to the tested tool, within the specified conditions.
They cannot be extended to any lot, even for similar products.
- c) This document may only be reproduced in full. Partial reproduction requires written approval from the laboratory.



Eng. José Carlos Rizzolli
Authorized Signer