

|                                    |              |                   |
|------------------------------------|--------------|-------------------|
| <b>INSULATION TEST CERTIFICATE</b> | <b>Nr.:</b>  | <b>87530</b>      |
|                                    | <b>Date:</b> | <b>05/09/2024</b> |

Pag. 1 de 1.

#### 1. GENERAL TEST DATA

|                                 |                                                                                                                                                                                                                                                                                                                          |
|---------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Requester:</b>               | Tramontina Garibaldi S.A. Ind. Met.                                                                                                                                                                                                                                                                                      |
| <b>Test date:</b>               | 05/09/2024                                                                                                                                                                                                                                                                                                               |
| <b>Place:</b>                   | Tramontina Garibaldi S.A. Test Laboratory, located at Tramontina Street, 600 – Garibaldi – RS                                                                                                                                                                                                                            |
| <b>Environmental Condition:</b> | Temperature from 18 °C to 28 °C and 45% to 75% relative humidity                                                                                                                                                                                                                                                         |
| <b>Test method:</b>             | Before the test, the sample is conditioned as described in IEC 60900:2018, sections 5.5.2.2 or 5.5.2.3. After the conditioning period, the sample is submitted to voltage of 10 kV r.m.s (60 Hz) for 3 minutes, in accordance with item 5.5.3 – Dielectric Test of Insulated Hand Tools, of the aforementioned standard. |

#### 2. TESTED ITEM IDENTIFICATION

|                                    |                                                                                                |
|------------------------------------|------------------------------------------------------------------------------------------------|
| <b>Manufacturer:</b>               | Tramontina Garibaldi S.A. Ind. Met.                                                            |
| <b>Description of tested item:</b> | 1/2" IEC 60900 6 Point Socket 13mm                                                             |
| <b>Reference:</b>                  | 44335/013                                                                                      |
| <b>Manufacturing order number:</b> | 258156                                                                                         |
| <b>Sample:</b>                     | The tested samples come from the industrial process of the aforementioned manufacturing order. |

#### 3. STANDARD IDENTIFICATION

|                               |                                                                                                                                    |
|-------------------------------|------------------------------------------------------------------------------------------------------------------------------------|
| <b>Equipment:</b>             | High Voltage Source                                                                                                                |
| <b>Identification Number:</b> | 100/013                                                                                                                            |
| <b>Traceability:</b>          | Calibrated by LABELO Laboratory, recognized by Cgcre/Inmetro CAL 0024, Calibration Certificate No. E0009/2020, according to PL015. |

#### 4. TEST RESULT IN ACCORDANCE TO IEC 60900:2018 STANDARD

| Batch representative sample | RESULT          |
|-----------------------------|-----------------|
| <b>44335/013</b>            | <b>Approved</b> |

#### NOTES:

- This tool underwent insulation testing, and even after long storage periods, it is suitable for use.  
After the first application, annual recertification is necessary.
- The results shown herein are related exclusively to the tested tool, within the specified conditions.  
They cannot be extended to any lot, even for similar products.
- This document may only be reproduced in full. Partial reproduction requires written approval from the laboratory.



Eng. José Carlos Rizzolli  
Authorized Signer