



3/4" Spherical Solids Handling Manual & Automatic

Submersible Effluent Pumps

^arnes

DISCHARGE1½" NPT, Female, Vertical LIQUID TEMPERATURE 104°F (40°C) Continuous MOTOR HOUSING Cast Iron BODY & STRAINER Thermoplastic side. Balanced, ISO G6.3 Material Cast Iron SHAFT Stainless Steel O-RINGS Buna-N HARDWARE 300 Series Stainless Steel PAINT Air Dry Enamel SEAL: Design Single Mechanical, Type 21 Material Silicon Carbide/Silicon Carbide/Buna-N Hardware -300 Series Stainless CORD ENTRY 20 ft. (6m) Quick connect cord with plug and pressure gromment for sealing and strain relief UPPER BEARING......Single Row, Ball, Oil Lubricated LOWER BEARING...... Single Row, Ball, Oil Lubricated MOTOR: Design Oil Filled Insulation...... Class B SINGLE PHASE...... Permanent Split Capacitor (PSC). Includes thermal overload protection in motor LEVEL CONTROL EP72X None EP72AX...... Wide angle, Mechanical, 20 ft. (6m) cord

with Plggy-Back plug
EP72VFXVertical float, PVC, snap action, 20 ft. (6m) cord
with Plggy-Back plug

EP72AX...... 18" (457mm)

EP72X & EP72VXF 12" (305mm)

(I) R


CSA 108 UL 778 LR16567

DESCRIPTION:

Series: EP72X

PUMP IS DESIGNED FOR HANDLING SEWAGE EFFLUENT IN TYPICAL SEPTIC TANK/EFFLUENT APPLICATIONS

3/4HP, 3450RPM, 60Hz



Testing is performed with water specific gravity of 1.0 @ 68°F (20°C), other fluids may vary performance



A Crane Co. Company

MINUMUM SUMP DIA:

PUMPS & SYSTEMS

SECTION C PAGE 3 DATE 11/04


USA: (937) 778-8947 • Canada: (905) 457-6223 • International: (937) 615-3598


Series EP72X

3/4" Spherical Solids Handling Manual & Automatic



Submersible Effluent Pumps





MODEL NO	PART NO	НР	VOLT/PH	Hz	RPM (Nom)	NEMA START CODE	FULL LOAD AMPS	CORD LENGTH	CORD SIZE	CORD TYPE
EP72X	119331	3/4	240/1	60	3450	А	4.3	20 ft. (6m)	16/3	SJTOW
EP72AX	119413	3/4	240/1	60	3450	А	4.3	20 ft. (6m)	16/3	SJTOW
EP72VFX	119414	3/4	240/1	60	3450	Α	4.3	20 ft. (6m)	16/3	SJTOW

IMPORTANT!

- 1.) PUMP MAY BE OPERATED "DRY" FOR EXTENDED PERIODS WITHOUT DAMAGE TO MOTOR AND/OR SEALS.
- 2.) INSTALLATIONS SUCH AS DECORATIVE FOUNTAINS OR WATER FEATURES PROVIDED FOR VISUAL ENJOYMENT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE ANSI/NFPA 70 AND/OR THE AUTHORITY HAVING JURISDICTION. THIS PUMP IS NOT INTENDED FOR USE IN SWIMMING POOLS, RECREATIONAL WATER PARKS, OR INSTALLATIONS IN WHICH HUMAN CONTACT WITH PUMPED MEDIA IS A COMMON OCCURRENCE.

SECTION C PAGE 4 DATE 3/14

