




This box runs the magnet lock that is on the front door to our office. It is hooked up through our telephone system. The magnet lock is activated by pushing a button on our telephones. We have had an electrician check everything and we have had our telephone guy come out and check everything. This is what we know....

This is the power cord plugged into the wall.

With a voltage meter check it is getting power here.

This is the cord leading to our telephone system. The telephone system extension has been checked, it has a dial tone at the extension and it is working fine.

When you press the door lock button on the phone this clicks on and off but nothing happens with the magnet at the door.

* So it was determined that there is no power and/or voltage going to #9 & #10 on the green board!

Those two that are numbered #9 & #10 were checked with a voltage meter and read 0.