

Installation Instructions

1. Cut threshold to the required size
2. Notch around door frame, if desired.
3. Attach threshold with fasteners provided.
4. For moisture control, caulk around base of threshold.



Fire Rating

UL10C Positive Pressure Tested Gasketing Material for Fire Doors.

UL10B Gasketing Materials for Fire Doors.

Intended for Application to Classified Steel fire doors rated up to 3 hours and Wood type fire doors up to 1-1/2 hours.