

PRODUCT DETAIL: FIRE EXTINGUISHER BRACKET MB810A



Overall Width Including Strap Mounting Angle: 9"

Overall Depth Including Strap: 8"

Back Bracket Base Width: 7-1/4 x 13 1/2 x 2-1/2" Deep

Mounting Holes: 2 located 1-1/2" From Top and 1-1/2" From Sides. 2 located 6-1/2" From Top and 1-1/2" from Sides. 2 located 12" From Top and 1-1/2" From Sides.

Bracket Tension Adjusting: 3" Carriage Bolt is attached by 2 Nuts Through Welded Angle Piece located 5-1/4" from top and Extending 1 1/2" from Side of Back Bracket Base.

Center Strap: located 5-1/2" from Top of Bracket. 1" high

Back Supporting Straps: 1" x 7" 2 Rubber Pads on Each 1" from Each Edge. Positioned 1/2", 5" & 9-1/4" from Bracket top

Bottom Plate: 7" x 7" (mitered corners) 4 Holes located 1-1/2" From Sides & 1-1/2" From Back or Front.. 1 Centered 3-1/2" from All Edges.



JL INDUSTRIES

ACTIVAR
INC.

www.activarcpg.com

Construction Products Group

PRODUCT DETAIL: FIRE EXTINGUISHER BRACKET MB810A

HEADQUARTERS & CUSTOMER SERVICE: 4450 WEST 78TH ST CIRCLE, BLOOMINGTON, MN 55435-5416 PH: 800-554-6077 FAX: 952-835-2218 EMAIL: SALES@JLINDUSTRIES.COM WWW.ACTIVARCPG.COM
ACPG SOUTHEAST (THOMAS ENTERPRISES): FT MEERS, FL ACPG WEST COAST (SAMSON): COMMERCE, CA WAREHOUSES: DALLAS TX, LANCASTER PA, ATLANTA GA, CHICAGO, IL, SEATTLE WA 5/11/12