



National Guard
Products, Inc.

Perimeter Seals

Do not install this product to impede the opening or closing of the door. It is recommended to check the adjustment of the door seal periodically to insure the door assembly closes and latches properly, whether or not equipped with a closing device.

Installation
Instructions

- 1. Measure and cut gasketing material to the exact length required for the opening.
- 2. Mark hole locations with a punch or other marking tool.
- 3. Drill pilot holes for each screw using a 3/32" drill bit.
- 4. Place gasketing against the face of the door with the gasketing material slightly compressed.
- 5. Install with screws provided, working from one end to the other.

APPLICATION WARNING:
DO NOT DRILL THROUGH NEOPRENE.



Positive Pressure Tested Gasketing Materials for Fire Doors, Intended for application to/with Classified Hollow Metal and Steel Covered Composite Type Fire Doors rated up to and including 3 hours and Wood Covered Composite and Wood Core Fire Doors rate up to and including 1 ½ hours.28H7
Also Classified in accordance with Uniform Building Code standard 7-2 Fire Tests of Door Assemblies (1997).