Phone: 800-647-7874 Fax: 800-255-7874

www.ngp.com


## 5050C-21'


Installation Instructions

# **Self Adhesive Silicone Seal**

## UL Tested and Classified for Fire and Smoke Doors

- \* Seals against smoke, fire, air, sound and weather
- \* Unaffected by sunlight, ozone and ultraviolet rays
- \* Excellent compression; door latches easily





- 3. Measure and pre-cut pieces to fit the head and jambs.
- 4. Remove protective backing I to 2 feet at a time.
- 5. Position on frame where illustrated, allowing approximately 1/16" between seal and frame for clearance when compressed.
- 6. Adhere by pressing firmly (approx. 15 lbs. pressure required) straight down along entire length of gasketing. Do not remove and relocate.

**WARNING**: Do not rub along length from one end toward other end during installation as gasket will stretch and not adhere properly.

7. Make sure the seal does not impede proper closing and latching of the door.











**NGP-EDGE.** Sealing System (Category G) for use on category B wood type fire doors rated up to 20 minutes, single swing up to 4'0" x 8'0" and pairs up to 8'0" x 8'0"




POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS. INTENDED FOR APPLICATION TO STEEL TYPE FIRE DOORS, RATED UP TO 3 HOURS AND WOOD TYPE FIRE DOORS, RATED UP TO 1 1/2 HOURS.




GASKETING MATERIALS FOR FIRE DOORS L

Smoke & draft control gasketing (Category H) tested to UL 1784; meets requirements of NFPA 105, IBC for use on "S" label doors.



### Made in USA



#### STORAGE AND SHELF LIFE

The adhesive on this seal has a shelf life of one year stored at 75°F and 50% relative humidity or less