



9600 / 9605 / 9675 Smoke Control Astragal



National
Guard
Products
Inc.

1-800-
647-7874



Installation

Instructions

1. Remove brush from metal retainer.
2. Cut brush to length, using the cutting section of pliers or diagonal cutters. If bristles are not secure, use a drop of adhesive to secure the brush.
3. Cut the metal retainer to length.
4. Replace brush in metal retainer.
5. Position on door as shown above.
6. Mark screw holes.
7. Drill pilot holes with a 7/64" bit.
8. Install with screws provided.
9. Slightly peen the bottom end of each retainer to secure the brush from moving.
10. Adjust astragal so it does not impede proper closing and latching of the doors.

Instrucciones de instalación:

1. Remueva el cepillo del retenedor de metal.
2. Corte el cepillo al largo adecuado, usando la parte cortante del alicate o las tenazas. Si las cerdas no están lo suficientemente pegadas, use un poco de pegamento para asegurarlas al cepillo.
3. Corte el retenedor de metal al largo adecuado.
4. Vuelva a poner el cepillo en el retenedor de metal.
5. Coloque en la puerta según se muestra arriba.
6. Marque los agujeros para los tornillos.
7. Taladre los agujeros de guía con una broca de 7/64".
8. Instale con los tornillos suministrados.
9. Martille levemente el extremo inferior de cada retenedor para asegurar el cepillo en posición y evitar que se mueva.
10. Ajuste el astrágalo de modo que no impida cerrar y correr el pasador a las puertas debidamente.



UL10C Positive Pressure
Tested Gasketing Material
for Fire Doors. Also
Classified in accordance
with UBC7-2 (1997).



UL10B Gasketing
Material for Fire
Doors.

Intended for Application to
Classified Steel fire doors rated up
to 3 hours and Wood type fire
doors up to 1 1/2 hours.