

National Guard Products Inc.

1-800-
647-7874



Adjustable Perimeter Seals

Installation Instructions

1. Set adjustment to mid range , so it can be adjusted equally in or out.
2. Cut to length.
3. With door closed, position seal, mark screw holes.
4. Drill pilot holes for screws using a #36 drill bit.
5. Install with screws provided, working from one end to the other. **DO NOT OVERTIGHTEN, OR ADJUSTMENT ABILITY MAY BE EFFECTED.**
6. Adjust seal so gasket is slightly compressed against door, but does not impede proper closing or latching.



UL10C Positive
Pressure Tested
Gasketing Material for
Fire Doors. Also Classified in accordance with UBC 7-2 (1997).



UL10B Gasketing
Material for Fire
Doors.

Intended for Application to Classified
Steel fire doors rated up to 3 hours
and Wood type fire doors up to 1 1/2
hours.

Smoke and Draft Control gasketing
(Category H) meets requirements of
UBC 7-2 (1997) part 2, NFPA 105,
IBC and UL1784. Intended for
application to 'S' label doors.

**105N & 305N are NOT classified
for use on fire rated doors. 141P
is UL10B Classified only.** 4/07