

Gap Solution for Excessive Fire Door Bottom Undercut/Clearance — 90 Minute

UL Certified Solution for Fire doors with Excessive Door Bottom Clearances up to 1-1/2"

NGP-Edge® Intumescent Door Shoe

Patent Pending

9590



90 minute rated UL10B and UL10C wood or hollow metal fire doors

Certified for use on doors with Concealed Vertical Rod Exit Devices or Automatic Flush Bolts, refer to Installation Instructions.

Restricts the passage of smoke

Non-Handed

Product consists of:

- #304 Brushed Stainless Steel Neoprene Sweep - pull side
- #304 Brushed Stainless Steel Intumescent Shoe - push side
- #304 Brushed Stainless Steel End Caps

Available in 36", 48" lengths

End caps furnished standard

#6 x 3/4" Stainless Steel SMS furnished

Brushed stainless steel
neoprene is black

