

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7315-0328:0189

Page 1 of 1

**CATEGORY:** 7315 -- POWER UNITS

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Models PSN-106, PSN-64, PSB-10 Notification Appliance Circuit (NAC) Power Supply Units.  
Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Input 120/240 VAC 50/60Hz  
Output 24VDC @ 10A

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the unit must provide battery backup suitable for at least 24 hours.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as power supply units for use with separately listed compatible fire alarm control units and notification appliances. Authority having jurisdiction should be consulted prior to installation. The unit can be programmed to generate the three-pulse temporal fire alarm evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 edition.

01-27-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGAN**, Program Coordinator  
Fire Engineering Division