


FIG.1 - Correct! Moving Tip Detects Leak



Reverse direction to pinpoint leak.



FIG.2 - Incorrect! Hovering on Leak



Initial change detected.


No change. No BEEP

FIG.3 - Contaminated Environment



1 Triggers on entry. Adjusts to environment. 2 Detects change.

FIG.4 - Strong Leak / Sensor Overload



Alarm triggers until refrigerant clears.