


FIG. 59
DRIVE SCREW



Material: Carbon steel.
Finish: Plain.
Service: Designed for fastening attachments to wood beams.
Ordering: Specify size and figure number.

SIZE A	LENGTH	WGT EACH (lbs)
12	1½	0.014
14	1½	0.016
16	2	0.025


FIG. 60G
1/4" BEAM CLAMP



Material: Malleable iron.
Finish: Electro-galvanized
Service: Designed to attach 1/4" hanger rod from metal beams, channel or angle iron.
Ordering: Specify figure number and finish.

ROD SIZE A	SET SCREW	B	C	D	WGT EACH (lbs)	MAX REC LOAD (lbs) TOP	MAX REC LOAD (lbs) BOTTOM
1/4-20	1/4-20	5/8	1 9/16	15/16	0.18	250	100

FIG. 61
TOP BEAM CLAMP



Material: Ductile iron body with hardened steel set screw.
Finish: Plain or electro-galvanized.
Service: Designed to attach hanger rod to the top flange of a beam or bar.
Approvals: U.L. - U.L.C. listed 3/8 and 1/2 (1/2 for 4" IPS max). FM approved for 3/8 only. Complies with Federal Specification A-A-1192A (Type# 19) and Manufacturers' Standardization Society MSS SP-58 and SP-69 (Type# 19).
Ordering: Specify rod size, figure number and finish.
Notes: See MSS SP-69 for proper set screw torque recommendations.
Order 61D for domestic



ROD SIZE A	SET SCREW	B	C	D	E	F	MAX PIPE SIZE	WGT EACH (lbs)	MAX REC LOAD (lbs)
3/8-16	3/8-16	1 3/8	2	1 1/2	1	7/8	4	0.55	400
1/2-13	3/8-16	1 3/8	2	1 1/2	1	7/8	4	0.56	500
5/8-11	3/8-16	1 7/8	2 3/8	5/8	1 3/8	1 1/4	5	0.66	850
3/4-10	3/8-16	1 7/8	2 3/8	5/8	1 3/8	1 1/4	6	0.83	900