



## Ventilation Fans

### FV-07VBA1A+FV-07VBB1 Ventilation Fan

#### **Architectural Specifications:**

Ventilation fan shall be ceiling mount, ENERGY STAR rated with built in airflow selector. Select from 70/90 CFM with no more than 0.7/1.5 sones as certified by the Home Ventilating Institute (HVI) at 0.1 w.g; with no less than 56/75 CFM and no more than 1.3/1.5 sones at 0.25 w.g. and 34/56 CFM at 0.375 w.g. (sones N/A at 0.375" w.g.). Power Consumption shall be no greater than 20.0 watts at 0.1 w.g 0.25 w.g. and 0.375 w.g. at the 70 CFM setting and 24.0 watts at 0.1 w.g., 0.25 w.g. and 0.375 w.g. at the 90CFM setting. ENERGY STAR® rated with efficiency of no less than 3.5 /3.8 CFM/watt at 0.1 w.g. and 2.8/3.1CFM/watt at 0.25 w.g. and 1.7/2.3 CFM/watt at 0.375 w.g. The motor shall be totally enclosed, four pole condenser type engineered to run continuously. This fan meets designed airflow requirements and provides Ventilation Verification Assurance: ≥ 50 CFM Installed Performance. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Fan shall be UL and cUL listed for ceiling installation and tub/shower enclosure when used with a GFCI protected circuit. Fan can be used to comply with ASHRAE 62.2, LEED, ENERGY STAR, IAP, EarthCraft, California Title-24 and WA Ventilation Code.