




Part No.	Reference No.	Quantity	Description
75008463	2		REFRIGERATION
75006103	3		FAN
75008646	7		MODEL NUMBER DESCRIPTION, DIGITS 1-17
75008647	7		MODEL NUMBER DESCRIPTION, DIGITS 18-31
75008648	7		MODEL NUMBER NOTES
OPTIONS	8		OPTIONAL FIELD INSTALLED ACCESSORIES

75008463

REV
A

This diagram illustrates the exploded view of a portable electronic device, showing the internal components and their assembly points. The components are labeled as follows:

- 1: Base plate or chassis.
- 2: HPCO (High Power Control Output) component.
- 3: LPCO (Low Power Control Output) component.
- 4: A small cylindrical component, likely a capacitor or filter.
- 5: A small cylindrical component, likely a capacitor or filter.
- 6: A small cylindrical component, likely a capacitor or filter.
- 7: A small cylindrical component, likely a capacitor or filter.
- 8: A small cylindrical component, likely a capacitor or filter.
- 9: A small cylindrical component, likely a capacitor or filter.
- 10: A large rectangular component, likely a power supply or battery.
- 11: A large rectangular component, likely a power supply or battery.

The diagram shows the internal components (1-9) and the power supply/battery components (10, 11) in an exploded view, indicating their relative positions and assembly points within the device.


Part No.	Reference No.	Quantity	Description
BRK03027	*	1	BRACKET; FILTER SPACER, 41.00 LG, .50 X .50
BRK03028	*	2	BRACKET; FILTER RETAINER, 38.70 LG, .97 X .97
BRK03029	*	1	BRACKET; FILTER STOP, 29.60 LG, 2.5 X 2.6 X 2.5
BRK03274	*	2	BRACKET; BASE SUPPORT MOUNT, 10.3 LENGTH (FORKLIFT BRACKET)
CNL01178	*	1	CHANNEL; INDOOR COIL SUPPORT, 42 INCH LENGTH
HTR03436	*	1	HEATER; CRANKCASE 6.5 DIA, 40W, 575V, 45 INCH LEADS (32W AT 460V)
KIT08039	*	1	KIT; GROMMETS. COMPRESSOR MOUNTING. (CONSISTS OF 4), 0.44 ID X 1.63 OD NEOPRENE RUBBER-BLACK 45-55 DUROMETER
NUT00355	*	4	NUT; HEX, LOCK, 5/16IN.-18
NUT00890	*	4	NUT; PALLET, 5/16-18 UNC 2B THD.
PLT04187	*	1	PLATE; COMPRESSOR MOUNTING, 17.0 X 11.0
SET00819	*	2	SEAT; SADDLE MOUNT ASSEMBLY
STM00803	*	2	STEM; SADDLE MOUNT, VALVE CORE, BRASS, .344 DIA X 1.29 SCHRAEDER TYPE FITTING (TO INCLUDE 5 PIECES)
WIR03227	*	1	WIRE; PLUG, 30 IN LENGTH, FOR 230/60/3 OR 460/60/3 OR 575/60/3 SCROLL COMPRESSOR (RD,BL,BK WIRES)
WIR04406	*	1	WIRE; HARNESS, LOW PRESSURE SWITCH, 42 IN LENGTH, BLUE WIRES, CIR 1
COM08743	1	1	COMPRESSOR; SCROLL, SPA032B4BPZ, 2.5 TON, 460/60/3, R410A, .50 ID DISCHARGE, .75 ID SUCTION
SWT03398	2	1	SWITCH; HIGH PRESSURE, BRAZED, OPENS AT 650 PSIG, CLOSSES AT 550 PSIG, 36 INCH WHITE LEADS
SWT03173	3	1	SWITCH; LOW PRESSURE CUTOUT, 250 OPEN, ACTUATION PRESSURE 41 +/- 4, RESET PRESSURE 25 +/- 4
DHY01287	4	1	FILTER DRIER; LIQUID LINE, 5/16 ODM INLET X 5/16 ODF OUTLET
TUB12008	6	1	TUBE; ASSEMBLY, INDOOR TXV
VAL08786	7	1	VALVE; TXV, 3 TON, 5/16 ODM X 1/2 ODF, 83 PSIG SH SETPOINT, R410A
TUB11743	8	1	TUBE; ASSEMBLY, INDOOR DISTRIBUTOR, 9 OUTLETS
COL13563	10	1	COIL; INDOOR, FLAT FIN (TXV NOT INCLUDED)

Fan

75006103

REV
A

Typical illustration. Unit may not appear exactly as shown.



Part No.	Reference No.	Quantity	Description
SCR01996	*	4	SCREW; #10-32 THREAD FORMING, IND 5/16 HEX FLG WASHER HEAD, .438/.408 LENGTH, W/GERNIBS TAPTITE II (4 PER BAG)
GRL01332	1	1	GRILLE; FAN, 26.65 MTG HOLE DIAMETER
MOT10332	2	1	MOTOR; OD FAN, 1/5 HP, 460/60/1, 1115 RPM, CCW LEAD END, 48 FRAME, SLEEVE BEARINGS, 3 MFD CPT AT 370V
FAN03042	3	1	FAN; 2 BLADE, 22 IN DIA, 24 DEG PITCH, CCW, 1/2 BORE

Model Number Notes

75008648

REV
B

Packaged Cooling THC036E,THC048E/F,THC060E/F

- ① Microchannel Condensor Coils are standard on THC048F & THC060F models.
- ② Manual outside air damper will ship factory supplied within the unit, but must be field installed.
- ③ Economizer with Barometric Relief is for downflow configured units only. Order Economizer without Barometric Relief for horizontal configuration. Barometric Relief for horizontal configured units must be ordered as field installed accessory.
- ④ Not available with electromechanical controls
- ⑤ Multispeed direct drive is standard on single phase. Belt drive is standard on dehumidification units.
- ⑥ Belt Drive is optional on 3 phase units.
- ⑦ Epoxy coil and epoxy with hailguard options are not available for units with microchannel condenser coil.
- ⑧ Through the base electric required when ordering disconnect/circuit breaker options.
- ⑨ Requires use of Disconnect or Circuit Breaker.
- ⑩ Standard metering devices are TXVs.
- ⑪ Dehumidification option not available for standard efficiency models.
- ⑫ Requires selection of 2" Pleated Filters (option B or C) for Digit 16
- ⑬ Crankcase Heater & High Pressure Control are standard on all units.
- ⑭ Froststat cannot be field installed in electromechanical units.
- ⑮ Not available with high temperature duct sensor accessory.
- ⑯ Return Air Smoke Detector cannot be ordered with Novar Controls.
- ⑰ The return air smoke detector may not fit up or work properly on the Precedent units when used in conjunction with 3rd party accessories such as bolt on heat wheels, economizers and power exhaust. Do not order the return air smoke detectors when using this type of accessory.
- ⑱ These options are standard when ordering Novar Controls.
- ⑲ This option is used when ordering Novar Controls.
- ⑳ Novar Sensor utilized with Digit 21=(4) Novar 3051 Controls without Zone Sensor.
- ㉑ Demand Control Ventilation Option includes wiring only. The CO₂ sensor is a field-installed only option.
- ㉒ Demand Control Ventilation Option not available with electromechanical controls.

Model Number	Description	75008647	REV D
Packaged Cooling THC036E,THC048E/F,THC060E/F Digits 18 through 31			
DIGIT 18 – Through the Base Provisions		DIGIT 25 – Monitoring Controls	
0 = No Through the Base Provisions		0 = No Monitoring Controls ⑱	
A = Through the Base Electric ⑧		1 = Clogged Filter Switch ⑱	
DIGIT 19 – Disconnect/Circuit Breaker		2 = Fan Failure Switch ⑱	
0 = No Disconnect/No Circuit Breaker		3 = Discharge Air Sensing Tube ⑱	
1 = Unit Mounted Non–Fused Disconnect ⑧		4 = Clogged Filter Switch and Fan Failure Switch ⑱	
2 = Unit Mounted Circuit Breaker ⑧		5 = Clogged Filter Switch and Discharge Air Sensing Tube ⑱	
DIGIT 20 = Convenience Outlet		6 = Fan Failure Switch and Discharge Air Sensing Tube ⑱	
0 = No Convenience Outlet		7 = Clogged Filter, Fan Fail Switch and Discharge Air Sensing Tube ⑱	
A = Unpowered Convenience Outlet		8 = Novar 2024 Return Air Sensor ⑲	
B = Powered Convenience Outlet ⑨		9 = Novar 3051 Zone Sensor ⑳	
DIGIT 21 – Communications Options ④		A = Condensate Drain Pan Overflow Switch	
0 = No Communications Interface		B = Clogged Filter Switch ⑱ and Condensate Drain Pan Overflow Switch	
1 = Trane Communications Interface		C = Fan Failure Switch ⑱ and Condensate Drain Pan Overflow Switch	
2 = LonTalk® Communications Interface		D = Discharge Air Sensing ⑱ and Condensate Drain Pan Overflow Switch	
3 = Novar 2024 Controls		E = Clogged Filter Switch ⑱, Fan Failure Switch ⑱ and Condensate Drain Pan Overflow Switch	
4 = Novar 3051 Controls without Zone Sensor		F = Clogged Filter Switch ⑱, Discharge Air Sensing Tube ⑱, and Condensate Drain Pan Overflow Switch	
5 = Novar 3051 Controls Interface with DCV		G = Fan Failure Switch ⑱, Discharge Air Sensing Tube ⑱, and Condensate Drain Pan Overflow Switch	
6 = BACnet™ Communications Interface		H = Clogged Filter Switch ⑱, Fan Failure Switch ⑱, Discharge Air Sensing Tube ⑱, and Condensate Drain Pan Overflow Switch	
7 = Wireless Building Automation Control Network Communications Interface		DIGIT 26 – System Monitoring Controls	
DIGIT 22 – Refrigeration System Option		0 = No Monitoring Controls	
0 = Standard Refrigeration System ⑩		1 = Demand Control Ventilation (CO ₂) ⑳ ㉑	
1 = Dehumidification Option ⑪ ⑫		DIGIT 27 – Unit Hardware Enhancements	
DIGIT 23 – Refrigeration Controls		0 = No Enhancements	
0 = No Refrigeration Control ⑬		1 = Stainless Steel Drain Pan	
1 = Froststat ⑭		DIGIT 31 – Advanced Unit Controls	
DIGIT 24 – Smoke Detector ⑮		0 = Standard Unit Controls	
0 = No Smoke Detector		1 = Human Interface	
A = Return Air Smoke Detector ⑯ ⑰			
B = Supply Air Smoke Detector			
C = Supply and Return Air Smoke Detectors ⑯ ⑰			
D = Plenum Smoke Detector			
See Model Number Notes graphic for explanation of Notes ① to ㉒			

Model Number Description 75008646
 Packaged Cooling THC036E,THC048E/F,THC060E/F
 Digits 1 through 17

REV
C

DIGIT 1 – Unit Function

T = DX Cooling

DIGIT 2 – Efficiency

H = High Efficiency

DIGIT 3 – Airflow

C = Convertible

DIGIT 4,5,6 – Nominal Gross Cooling Capacity (MBh)

036 = 3 Ton

048 = 4 Ton

060 = 6 Ton

DIGIT 7 – Major Design Sequence

E = R-410A Refrigerant

F = Microchannel Type Condenser Coils ①

DIGIT 8 – Voltage Selection

1 = 208–230/60/1

3 = 208–230/60/3

4 = 460/60/3

DIGIT 9 – Unit Controls

E = Electromechanical

R = ReliaTel™ Micro-processor

DIGITS 10 – Heating Capacity

0 = No Electric Heater

A = 5 kw (1 phase)

B = 6 kw (3 phase)

D = 10 kw (1 phase)

E = 12 kw (3 phase)

F = 14 kw (1 phase)

G = 18 kw (1 & 3 phase)

J = 23 kw (3 phase)

DIGIT 11 – Minor Design Sequence

A = First Sequence

DIGITS 12,13 – Service Sequence

** = Factory Assigned

DIGITS 14 – Fresh Air Selection

0 = No Fresh Air

A = Manual Outside Air Damper 0–50% ②

B = Motorized Outside Air Damper 0–50%

C = Economizer, Dry Bulb 0–100%

without Barometric Relief ③

D = Economizer, Dry Bulb 0–100%

with Barometric Relief ③

E = Economizer, Reference Enthalpy 0–100% without Barometric Relief ③ ④

F = Economizer, Reference Enthalpy 0–100% with Barometric Relief ③ ④

G = Economizer, Comparative Enthalpy 0–100% without Barometric Relief ③ ④

H = Economizer, Comparative Enthalpy 0–100% with Barometric Relief ③ ④

K = Low Leak Economizer with Barometric Relief

M = Low Leak Economizer with Reference Enthalpy with Barometric Relief

P = Low Leak Economizer with Comparative Enthalpy with Barometric Relief

DIGIT 15 – Supply Fan/Drive Type/Motor

0 = Standard Drive ⑤

2 = Optional Belt Drive Motor ⑥

DIGIT 16 – Hinged Service Access/Filters

0 = Standard Panels/Standard Filters

A = Hinged Access Panels/Standard Filters

B = Standard Panels/2" MERV 8 Filters

C = Hinged Access Panels/2" MERV 8 Filters

D = Standard Panels/2" MERV 13 Filters

E = Hinged Access Panels/2" MERV 13 Filters

DIGIT 17 – Condenser Coil Protection

0 = Standard Coil

1 = Standard Coil with Hail Guard

2 = Black Epoxy Pre-Coated Condenser Coil ⑦

3 = Black Epoxy Pre-Coated Condenser Coil with Hail Guard ⑦

4 = CompleteCoat™ Condenser Coil

5 = CompleteCoat™ Condenser Coil with Hail Guard

See Model Number Notes graphic for explanation of Notes ① to ②②

Parts List Number :THCUP6

Model Number :THC036E4E0A0000

Part No.	Reference No.	Quantity	Description
BAS01908	*	1	BASE; THERMOSTAT, 18-32V, 50/60 HZ, GAS AND ELECTRIC, 2 STAGE HEAT AND 2 STAGE COOLING (BAYBASE006AA)
BAS01910	*	1	BASE; THERMOSTAT 18-32V, 50/60HZ, GAS AND ELECTRIC, 1 STAGE HEAT AND 1 STAGE COOLING (BAYBASE008AA)
BAYPWRX071A	*	1	POWER EXHAUST, 460V, FOR 3-5 TON T/W/YSC, D/TW/YHC, T/YZC
CRB00175	*	1	CURB; ROOFCURB (BAYCURB042AB)
DMP02175	*	1	DAMPER; 0-50% MANUAL OUTSIDE AIR DAMPER (BAYDMPR053BA)
DMP02842	*	1	DAMPER; 0-50% MOTORIZED OUTSIDE AIR DAMPER, ELECTROMECHANICAL (BAYDMPR052A)
ECN00107	*	1	ECONOMIZER; ELECTROMECHANICAL, 0-100% DRY BULB (BAYECON086A)
GRD01610	*	1	GUARD; HAIL GUARD ACCESSORY (BAYGARD037BB)
HTR06207	*	1	HEATER; ACCESSORY, 380/415/480/3, 3.8/4.5/6.0 KW (BAYHTRE406AA)
HTR06208	*	1	HEATER; ACCESSORY, 380/415/480/3, 7.5/9.0/12.0 KW (BAYHTRE412AA)
HTR06209	*	1	HEATER; ACCESSORY, 380/415/480/3, 10.9/13.0/17.4 KW (BAYHTRE418AA)
KIT06658	*	1	KIT; ENTHALPY CONTROL (BAYENTH001AB)
THT02424	*	1	THERMOSTAT; 1 HEAT (GAS/ELEC) 1 COOL (TCONT200ANN11AAA) NON-PROGRAMMABLE.
TMR00140	*	1	TIMER; ANTISHORT CYCLE (BAYASCT001)