


General Assembly

75009334

REV
A

Typical illustration. Unit may not appear exactly as shown.



* The Heat and Air Handling sections will appear in the Parts List if ordered with the unit.

View is determined by facing Appearance Nameplate

Parts List Number :THCUP7

Model Number :THC102E3R0A0000


Part No.	Reference No.	Quantity	Description
75009291	2		BLOWER
75006103	3		FAN
75009397	5		REFRIGERATION
75009416	9		MODEL NUMBER DESCRIPTION, DIGITS 1-16
75009422	9		MODEL NUMBER DESCRIPTION, DIGITS 17-31
75009423	9		MODEL NUMBER NOTES
NGRAPHIC	10		OPTIONAL FIELD INSTALLED ACCESSORIES

BLOWER

75009291

REV
B

TYPICAL ILLUSTRATION




Part No.	Reference No.	Quantity	Description
SCR01421	*	6	SCREW; M10 X 25
SCR01557	*	16	SCREW; SHEET METAL 0.25-14 X 0.62, HEX HEAD, SLATE GRAY COLOR
SCR01623	*	8	SCREW; SHEET METAL, 10-16 UNC X 1/2, HIGH TORQUE, INDENT HEX-WASHER HEAD
WAS00622	*	6	WASHER;10MM ID X 18.1 OD
WIR05194	*	1	WIRE; HARNESS, INDOOR FAN MOTOR (1Z,2S,3S,GND,37B,39B,40B,41B,45B,108C,158E)
FAN04214	1	1	FAN; INDOOR FAN/BLOWER ASSEMBLY, DIRECT DRIVE, 200-240V, AC, 50/60HZ, 3 PHASE
BRK03923	2	1	BRACKET; PLENUM BOTTOM ANGLE; 19.71 X 2.13 X 4.50
PLT04558	3	1	PLATE; PLENUM FRONT WITH ORIFICE, 24.60 X 24.00
BRK03921	4	1	BRACKET; PLENUM TOP FRONT ANGLE, 19.75 X 9.00
BRK03922	5	1	BRACKET; PLENUM TOP REAR ANGLE, 19.75 X 9.00
BRK03923	6	1	BRACKET; PLENUM BOTTOM ANGLE; 19.71 X 2.13 X 4.50
PLT04559	7	1	PLATE; PLENUM MOTOR MOUNTING, 24.31 X 24.00

Fan

75006103

REV
A

Typical illustration. Unit may not appear exactly as shown.




Part No.	Reference No.	Quantity	Description
BRK00688	*	2	BRACKET; CONNECTING, HEAT SINK
NUT00009	*	1	NUT; .25-20, HEX LOCK
RNG01005	*	2	RING; EXTRUDED FIN, HEAT SINK, 3.00 WIDE, UNRESTRAINED DIM IS 7.20/6.61
SCR01996	*	4	SCREW; #10-32 THREAD FORMING, IND 5/16 HEX FLG WASHER HEAD, .438/.408 LENGTH, W/GERNIBS TAPTITE II (4 PER BAG)
WAS00041	*	1	WASHER; FLAT, PLAIN, #12 .25 ID X .56 OD, .065 THK, CARBON STL-PLD
WAS00670	*	1	WASHER; .26 ID X .49 OD
GRL01664	1	1	GRILLE; OUTDOOR FAN, 35 INCH MTG DIA
MOT13448	2	1	MOTOR; 3/4 HP, 208-230/60/3, 1100 RPM, 48 FRAME, BALL BEARINGS, MAX FLA 2.7, MAX LRA 9.8
FAN04206	3	1	FAN; 2 BLADE, 30.36 IN DIA, 18 DEG PITCH, CW, 5/8 BORE

Refrigeration

75009397

REV
A

Typical illustration. Unit may not appear exactly as shown.



Part No.	Reference No.	Quantity	Description
BRK03274	*	4	BRACKET; BASE SUPPORT MOUNT, 10.3 LENGTH (FORKLIFT BRACKET)
CAP00072	*	5	CAP; VALVE, SEAL, .25 FFL
CNL01752	*	1	CHANNEL; MOUNTING PLATE SUPPORT, COMPRESSOR, 39.24 X 2.09 X 17.0
COR00006	*	2	CORE; VALVE PORT, .79 LENGTH, .206-36 UNS 2A THD
HTR03908	*	1	HEATER; CRANKCASE, 40W, 230V, 6.5 DIA, 70 IN LEAD LENGTHS
HTR10245	*	1	HEATER; CRANKCASE, 70W, 230V, 18AWG W/2 LEADS - ONE IS 65" LG W/ 1/4 INSUL FEMALE QC - ONE IS 65" LG W/ 1/4 UNINSUL FEMALE QC
KIT08039	*	2	KIT; GROMMETS. COMPRESSOR MOUNTING. (CONSISTS OF 4), 0.44 ID X 1.63 OD NEOPRENE RUBBER-BLACK 45-55 DUROMETER
NUT00355	*	8	NUT; HEX, LOCK, 5/16IN.-18
NUT00890	*	8	NUT; PALLET, 5/16-18 UNC 2B THD.
PLU01049	*	1	PLUG; SCROLL COMPRESSOR HARNESS, CKT1, 12GA, 4A-RD, 6C-BL, 3C-BK, 62 IN LENGTH
SET00819	*	4	SEAT; SADDLE MOUNT ASSEMBLY
STM00803	*	4	STEM; SADDLE MOUNT, VALVE CORE, BRASS, .344 DIA X 1.29 SCHRAEDER TYPE FITTING (TO INCLUDE 5 PIECES)
SWT03173	*	2	SWITCH; LOW PRESSURE CUTOUT, 250 OPEN, ACTUATION PRESSURE 41 +/- 4, RESET PRESSURE 25 +/- 4
SWT03402	*	1	SWITCH; HIGH PRESSURE, BRAZED, OPENS AT 650 PSIG, CLOSSES AT 550 PSIG, 61 INCH WHITE LEADS
SWT03403	*	1	SWITCH; HIGH PRESSURE, BRAZED, OPENS AT 650 PSIG, CLOSSES AT 550 PSIG, 61 INCH ORANGE LEADS
THT02760	*	1	THERMOSTAT; WITH CLIP, .5/.625 TUBE, 72" BLACK WIRES, SPST, 230F OPEN, 180F CLOSE
THT02761	*	1	THERMOSTAT; WITH CLIP, .5/.625 TUBE, 72" RED WIRES, SPST, 230F OPEN, 180F CLOSE
VAL01483	*	2	VALVE; BODY, .44-20 THD X .25 ODS, STRAIGHT, BRASS, LESS CORE
WIR03439	*	1	WIRE; HARNESS, COMPRESSOR, 14 AWG, CC2, 62 IN LENGTH (3 WIRE-RK,BL,BK)
WIR04406	*	1	WIRE; HARNESS, LOW PRESSURE SWITCH, 42 IN LENGTH, BLUE WIRES, CIR 1
WIR04407	*	1	WIRE; HARNESS, LOW PRESSURE SWITCH, 55 IN LENGTH, YELLOW WIRES, CIR 2
COM08758	2	1	COMPRESSOR; SCROLL, SPA050A3BPZ, 4.25 TON, 200-230/60/3, R410A, .50 ID DISCHARGE, .75 ID SUCTION
PLT04552	3	1	PLATE; COMPRESSOR MOUNTING, 38.14 X 18.69
COM08742	4	1	COMPRESSOR; SCROLL, SPA032B3BPZ, 2.5 TON, 200-230/60/3, R410A, .50 ID DISCHARGE, .75 ID SUCTION
DHY01287	5	2	FILTER DRIER; LIQUID LINE, 5/16 ODM INLET X 5/16 ODF OUTLET
PAN03005	6	1	PAN; DRAIN, BLACK POLYCARBONATE, 62.5 X 4.0
DST00950	8	1	DISTRIBUTOR; ASSEMBLY, INDOOR, 13 OUTLETS, #4 NOZZLE
TUB12539	8	1	TUBE; ASSEMBLY, EXPANSION VALVE
VAL09599	8	1	VALVE; EXPANSION; 5 TON, 3/8 ODF IN X 1/2 ODF OUT, NON-ADJUSTABLE, R410A, 126 PSIG
DST00949	9	1	DISTRIBUTOR; ASSEMBLY, INDOOR, 9 OUTLETS, #2.5 NOZZLE
TUB12540	9	1	TUBE; ASSEMBLY, EXPANSION VALVE
VAL09592	9	1	VALVE; EXPANSION; 3 TON, 3/8 ODF IN X 1/2 ODF OUT, NON-ADJUSTABLE, R410A, 128.7 PSIG
COL16361	10	1	COIL; INDOOR. INCLUDES THE DISTRIBUTORS, NOT THE TXVS

Model Nomenclature

Packaged Cooling

Digits 18 through 31

75009422

REV D

DIGIT 18 – Through the Base Provisions

0 = No Through the Base Provisions

A = Through the Base Electric ⑪

DIGIT 19 – Disconnect/Circuit Breaker

0 = No Disconnect/No Circuit Breaker

1 = Unit Mounted Non-Fused Disconnect ⑪

2 = Unit Mounted Circuit Breaker ⑪

DIGIT 20 = Convenience Outlet

0 = No Convenience Outlet

A = Unpowered Convenience Outlet

B = Powered Convenience Outlet ⑫

DIGIT 21 – Communications Options ④

0 = No Communications Interface

1 = Trane Communications Interface

2 = LonTalk® Communications Interface

3 = Novar 2024 Controls ⑬

4 = Novar 3051 Controls without Zone Sensor ⑬

5 = Novar 3051 Controls Interface with DCV ⑬

6 = BACnet™ Communications Interface

7 = Wireless Building Automation Control Network Communications Interface

DIGIT 22 – Refrigeration System Option

0 = Standard Refrigeration System ⑭

1 = Dehumidification Option ⑮

DIGIT 23 – Refrigeration Controls

0 = No Refrigeration Control ⑯

1 = Froststat ⑰ ⑱

2 = Crankcase Heater ⑲

3 = Froststat ⑰ ⑱ and Crankcase Heater ⑲

DIGIT 24 – Smoke Detector ⑳

0 = No Smoke Detector

A = Return Air Smoke Detector ㉑ ㉒

B = Supply Air Smoke Detector

C = Supply and Return Air Smoke Detectors ㉑ ㉒

D = Plenum Smoke Detector

DIGIT 25 – Monitoring Controls

0 = No Monitoring Controls ㉓

1 = Clogged Filter Switch ㉓

2 = Fan Failure Switch ㉓

3 = Discharge Air Sensing Tube ㉓

4 = Clogged Filter Switch and Fan Failure Switch ㉓

5 = Clogged Filter Switch and Discharge Air Sensing Tube ㉓

6 = Fan Failure Switch and Discharge Air Sensing Tube ㉓

7 = Clogged Filter, Fan Fail Switch and Discharge Air Sensing Tube ㉓

8 = Novar 2024 Return Air Sensor ⑭ ㉔

9 = Novar 3051 Zone Sensor ⑭ ㉕

A = Condensate Drain Pan Overflow Switch

B = Clogged Filter Switch ㉓ and Condensate Drain Pan Overflow Switch

C = Fan Failure Switch ㉓ and Condensate Drain Pan Overflow Switch

D = Discharge Air Sensing ㉓ and Condensate Drain Pan Overflow Switch

E = Clogged Filter Switch ㉓, Fan Failure Switch ㉓ and Condensate Drain Pan Overflow Switch

F = Clogged Filter Switch ㉓, Discharge Air Sensing Tube ㉓, and Condensate Drain Pan Overflow Switch

G = Fan Failure Switch ㉓, Discharge Air Sensing Tube ㉓, and Condensate Drain Pan Overflow Switch

H = Clogged Filter Switch ㉓, Fan Failure Switch ㉓, Discharge Air Sensing Tube ㉓, and Condensate Drain Pan Overflow Switch

DIGIT 26 – System Monitoring Controls

0 = No Monitoring Controls

1 = Demand Control Ventilation (CO₂) ㉖ ㉗

DIGIT 27 – Unit Hardware Enhancements

0 = No Enhancements

1 = Stainless Steel Drain Pan

DIGIT 31 – Advanced Unit Controls

0 = Standard Unit Controls

1 = Human Interface

See Model Number Notes graphic for explanation of Notes ① to ㉗

Model Number Description		75009416	REV C
Packaged Cooling Digits 1 through 17			
DIGIT 1 – Unit Function T = DX Cooling		DIGITS 14 – Fresh Air Selection 0 = No Fresh Air A = Manual Outside Air Damper 0–50% ② B = Motorized Outside Air Damper 0–50% ③ C = Economizer, Dry Bulb 0–100% without Barometric Relief ⑤ D = Economizer, Dry Bulb 0–100% with Barometric Relief ⑤ E = Economizer, Reference Enthalpy 0–100% without Barometric Relief ④ ⑤ F = Economizer, Reference Enthalpy 0–100% with Barometric Relief ④ ⑤ G = Economizer, Comparative Enthalpy 0–100% without Barometric Relief ④ ⑤ H = Economizer, Comparative Enthalpy 0–100% with Barometric Relief ④ ⑤ K = Low Leak Economizer with Barometric Relief M = Low Leak Economizer with Reference Enthalpy with Barometric Relief P = Low Leak Economizer with Comparative Enthalpy with Barometric Relief	
DIGIT 2 – Efficiency H = High Efficiency		DIGIT 15 – Supply Fan/Drive Type/Motor 0 = Standard Drive ⑥ 1 = Oversize Motor 6 = Single Zone VAV ⑦ ⑧ 7 = Multi-Speed Indoor Fan ⑨ E = VAV Supply Air Temperature Control Standard Motor ⑧	
DIGIT 3 – Airflow C = Convertible		DIGIT 16 – Hinged Service Access 0 = Standard Panels/Standard Filters A = Hinged Access Panels/Standard Filters B = Standard Panels/2" MERV Filters C = Hinged Access Panels/2" MERV Filters D = Standard Panels/2" MERV 13 Filters E = Hinged Access Panels/2" MERV 13 Filters	
DIGIT 4,5,6 – Nominal Gross Cooling Capacity (MBh) 072 = 6 Ton 074 = 6 Ton (Title 24 compliant) 092 = 7.5 Ton 102 = 8.5 Ton 120 = 10 Ton		DIGIT 17 – Condenser Coil Protection 0 = Standard Coil 1 = Standard Coil with Hail Guard 2 = Black Epoxy Pre-Coated Condenser Coil ⑩ 3 = Black Epoxy Pre-Coated Condenser Coil with Hail Guard ⑩ 4 = CompleteCoat™ Condenser Coil 5 = CompleteCoat™ Condenser Coil with Hail Guard	
DIGIT 7 – Major Design Sequence E = R-410A Refrigerant F = Microchannel Type Condenser Coils Coils ①			
DIGIT 8 –Unit Voltage 3 = 208–230/60/3 4 = 460/60/3			
DIGIT 9 – Unit Controls E = Electromechanical R = ReliaTel™ Microprocessor			
DIGITS 10 – Heating Capacity 0 = No Electric Heater C = 9 kW G = 18 kW K = 27 kW N = 36 kW P = 54 kW			
DIGIT 11 – Minor Design Sequence A = First Sequence			
DIGITS 12,13 – Service Sequence ** = First Sequence			
See <u>Model Number Notes</u> graphic for explanation of Notes ① to ②⑦			

Model Number Notes	75009423	REV C
THC Packaged Cooling		
① Optional on THC072, Standard on THC074F to THC120F. ② Manual outside air damper will ship factory supplied within the unit, but must be field installed. ③ Motorized Outside Air Damper is not available on Multi-Speed or SZVAV (Single Zone Variable Air Volume) products. ④ Not available with electromechanical controls ⑤ Economizer with Barometric Relief is for downflow configured units only. Order Economizer without Barometric Relief for horizontal configuration. Barometric Relief for horizontal configured units must be ordered as field installed accessory. ⑥ THC072E,072F – Belt Drive Standard, 15=1 Optional. THC074F,092E,092F,102E,102F,120E,120F – Ultra High Efficiency Direct Drive Plenum Fan is standard. ⑦ Single Zone VAV is only available on THC074–THC120 units with ReliaTel Controls. ⑧ Discharge Air Sensing is also standard equipment on units with Single Zone and Supply Air Temperature Control VAV. ⑨ Multi-speed indoor fan available only on THC074–THC120 units with ReliaTel Controls. ⑩ Epoxy coil and epoxy with hailguard options are not available for units with microchannel condenser coil. ⑪ Through the base electric required when ordering disconnect/circuit breaker options. ⑫ Requires use of Disconnect or Circuit Breaker. ⑬ Novar is not available with SZVAV products. ⑭ Standard metering devices are TXVs. ⑮ Requires selection of 2" Pleated Filters (16=B or C) ⑯ Froststat cannot be field installed in electromechanical units. ⑰ High Pressure Control is standard on all units. ⑱ Froststat standard on Multi-Speed and SZVAV (Single Zone Variable Air Volume). ⑲ Crankcase heaters are standard. ⑳ Not available with high temperature duct sensor accessory. ㉑ Return Air Smoke Detector cannot be ordered with Novar Controls. ㉒ The return air smoke detector may not fit up or work properly on the Precedent units when used in conjunction with 3rd party accessories such as bolt on heat wheels, economizers and power exhaust. Do not order the return air smoke detectors when using this type of accessory. ㉓ These options are standard when ordering Novar Controls. ㉔ This option is used when ordering Novar Controls. ㉕ Novar Sensor utilized with Digit 21=(4) Novar 3051 Controls without Zone Sensor. ㉖ Demand Control Ventilation Option includes wiring only. The CO₂ sensor is a field-installed only option. ㉗ Demand Control Ventilation Option not available with electromechanical controls.		

Parts List Number :THCUP7

Model Number :THC102E3R0A0000

Part No.	Reference No.	Quantity	Description
BAYCURB044A	*	1	ROOF CURB
BAYGARD070A	*	1	GUARD; HAIL GUARD (BAYGARD070AA)
BAYHTRD309A	*	1	ELECTRIC HEATER; 208/230-240/60/3, 9KW
BAYHTRD318A	*	1	ELECTRIC HEATER; 208/230-240/60/3, 18KW
BAYHTRD327A	*	1	ELECTRIC HEATER; 208/230-240/60/3, 9/18KW
BAYHTRD336A	*	1	ELECTRIC HEATER; 208/230-240/60/3, 18/18KW
BAYLSMW001A	*	1	POWER EXHAUST LIMIT SWITCH
BAYQACB111A	*	1	QUICK ADAPTER ROOF CURB
BAYQACB112A	*	1	QUICK ADAPTER ROOF CURB
BAYQACB113A	*	1	QUICK ADAPTER ROOF CURB
BAYRTEM001A	*	1	RELIA TEL ECONOMIZER LOGIC MODULE
BAYTUBE403A	*	1	DISCHARGE AIR SENSING; ELECTRIC HEAT
BRD03177	*	1	RELIA TEL COMMUNICATION INTERFACE; COMM3 & 4 PACKAGE UNITS (BAYICSI003AD) RTCI - FIELD KIT
CNT04875	*	1	CONTROL; EVAPORATOR DEFROST KIT (FROSTAT) (BAYLOAM020BB). (OPTIONS BOARD KIT09433-BAYABRD001CA MUST BE INSTALLED IN THE UNIT FOR THIS ACCESSORY TO OPERATE).
DMP02176	*	1	DAMPER; 0-50% MANUAL OUTSIDE AIR DAMPER (BAYDMPR056BA)
DMP02840	*	1	DAMPER; BAROMETRIC RELIEF (BAYBARM011AB)
DMP02957	*	1	DAMPER; RELIA TEL, 0-50 PERCENT MOTORIZED OUTSIDE AIR DAMPER (BAYDMPR054A)
ECN00123	*	1	ECONOMIZER; RELIA TEL, 0-100% DRY BULB (BAYECON087A)
KIT09433	*	1	KIT; ACCESSORY, OPTIONS BOARD (BAYABRD001CA)
KIT09500	*	1	LCIR W/ SHORT HARNESS 3-10 TON PACKAGE UNITS (HARNESS = WIR03458) LCI-R SHORT KIT
KIT13704	*	1	KIT; FAN FAILURE SWITCH (BAYDFPS004AB). (OPTIONS BOARD KIT09433-BAYABRD001CA MUST BE INSTALLED IN THE UNIT FOR THIS ACCESSORY TO OPERATE).
KIT13711	*	1	KIT; VENTILATION OVERRIDE (BAYVNOR001BB) (OPTIONS BOARD KIT09433-BAYABRD001CA MUST BE INSTALLED IN THE UNIT FOR THIS ACCESSORY TO OPERATE).
KIT15159	*	1	KIT; CO2 SENSING (BAYCO2K001B)
KIT15160	*	1	KIT; CO2 DEMAND-CONTROLLED VENTILATION DUCT SENSOR (BAYCO2K003B)
KIT15161	*	1	KIT; REFERENCE ENTHALPY (BAYENTH005A)
KIT15162	*	1	KIT; COMPARATIVE ENTHALPY (BAYENTH006B)
KIT15163	*	1	KIT; POWER EXHAUST, 208/230V (BAYPWRX026A)
PLT02562	*	1	PLATE, SENSOR MOUNTING (BAYMTPL004AA)
PLT03127	*	1	PLATE; COMBINED MOUNTING PLATE AND ADAPTER PLATE (BAYMTPL003BA)
SEN00278	*	1	SENSOR; THERMISTOR PROBE, -40 DEG C TO 65 DEG, STRIPPED LEADS (BAYSENS016AA)
SEN00408	*	1	SENSOR; ZONE STAT, LEVEL 2, NON-HEAT PUMP (BAYSENS008BB), DUAL SETPOINT MANUAL OR AUTO CHANGEOVER
SEN00410	*	1	SENSOR; ZONE STAT ASSEMBLY (BAYSENS006BA), SINGLE SETPOINT MANUAL CHANGEOVER
SEN00413	*	1	SENSOR; ZONE STAT ASSEMBLY (BAYSENS010BB), DUAL SETPOINT MANUAL OR AUTO CHANGEOVER WITH SYSTEM FUNCTION LIGHTS
SEN00435	*	1	SENSOR; ZONE LEVEL 4 (BAYSENS017BB) REMOTE ROOM SENSOR
SEN00495	*	1	SENSOR; ZONE LEVEL 4 (BAYSENS013CA) ROOM SENSOR W/ OVERRIDE AND CANCEL BUTTONS
SEN00496	*	1	SENSOR; ZONE LEVEL 4 (TRANE). (BAYSENS014CA) ROOM SENSOR W/ TEMP. ADJUSTMENT WITH OVERRIDE AND CANCEL BUTTONS
SEN01120	*	1	SENSOR; REMOTE ZONE, DUAL THERMISTOR (BAYSENS032AA)
SEN01127	*	1	SENSOR; REMOTE WALL (BAYSENS033AA)
SEN01128	*	1	SENSOR; TEMPERATURE (BAYSENS034AA), RETURN AIR REMOTE TEMPERATURE SENSOR
SEN01130	*	1	SENSOR; DIGITAL ZONE (BAYSENS035AB), DIGITAL DISPLAY ZONE SENSOR

Parts List Number :THCUP7

Model Number :THC102E3R0A0000

Part No.	Reference No.	Quantity	Description
SEN01195	*	1	SENSOR; HUMIDITY ZONE, WALL MOUNTED, TRANE (BAYSENS036A)
SEN01196	*	1	SENSOR; HUMIDITY ZONE, DUCT MOUNTED, TRANE (BAYSENS037A)
SEN01289	*	1	SENSOR; PROGRAMMABLE ZONE, CONSTANT VOLUME/HEAT PUMP (BAYSENS019CA)
SEN01447	*	1	SENSOR; ZONE, ROOM SENSOR W/TEMP. ADJUSTMENT WITH OVERRIDE AND CANCEL BUTTONS, 10K, DIAL, OCCUPIED (BAYSENS074AA)
SEN01448	*	1	SENSOR; ZONE, REMOTE ROOM SENSOR, 10K (BAYSENS077AA)
SEN01450	*	1	SENSOR; ZONE, ROOM SENSOR W/ OVERRIDE AND CANCEL BUTTONS, 10K, OCCUPIED (BAYSENS073AA)
SEN01513	*	1	SENSOR; ZONE; DUAL SETPOINT MANUAL OR AUTO CHANGOVER, TWO SET FAN SYSTEM (BAYSENS108AA)
SEN01515	*	1	SENSOR;ZONE SINGLE SETPOINT MANUAL CHANGOVER, SET FAN SYSTEM, COOL/OFF/HEAT (BAYSENS106A)
SEN01522	*	1	SENSOR; ZONE, DUAL SETPOINT MANUAL OR AUTO CHANGOVER W/SYSTEM FUNCTION LIGHTS TWO SET FAN SYSTEM, LED (BAYSENS110A)
SEN01577	*	1	SENSOR; PROGRAMMABLE ZONE, AUTOMATIC OR MANUAL CHANGOVER W/ SYSTEM LIGHTS TRANE (BAYSENS119AA)
THT00839	*	1	THERMOSTAT; REMOTE POTENTIOMETER, 60-90 DEG F (BAYSTAT023AA)
THT02239	*	1	THERMOSTAT; HIGH TEMPERATURE (BAYFRST001AA)
TOL00099	*	1	TOOL; RESISTANCE DECADE BOX