

SPECIFICATION SUBMITTAL SHEET



APPLICATION

Ideal for use where lead-free* valves are required. Designed for installation on potable water lines to protect against backsiphonage of contaminated water into the potable water supply. Assembly shall provide protection where a potential health hazard exists.

Model 35XLCH (1/2") Model 35XLVCH (1/4") Model 35XL (3/4" - 2")

FEATURES

- Sizes: 1/4" 1/2" 3/4" 1"
 1 1/4" 1 1/2" 2"

Maximum working water pressure 125 PSI
Maximum working water temperature 180°F

OPTIONS

(Suffixes can be combined)

- CH - with rough chrome plate finish (1/2" only)
- VCH - with vertical inlet and outlet with rough chrome finish (1/4" only)

ACCESSORIES


- SXL - Lead-Free Bronze Wye Strainer

STANDARDS COMPLIANCE


- ASSE® Listed 1001
- CSA® Certified
- IAPMO® Listed
- IAPMO® Listed - California Lead Plumbing Law*
*(0.25% max. weighted average lead content)

MATERIALS


Main valve body Lead-Free* Cast Brass
Elastomers Silicone (FDA approved)
Buna Nitrile (FDA approved)
Polymers ULTEM™, NSF Listed (1/4"-1/2")
Polypropylene (3/4"-2")



35XL (1/2")



35XLVCH (1/4")




35XL (3/4" - 2")

DIMENSIONS (do not include pkg.)


MODEL SIZE		DIMENSIONS (approximate)						WEIGHT	
		A		B		C			
in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kg
1/4 VCH	8	3/4	19	2 3/8	60	N/A	N/A	1	0.5
1/2	15	1 5/16	33	2 1/2	64	1 1/4	32	2	0.9
3/4	20	1 1/2	38	2 15/16	75	1 1/2	38	2	0.9
1	25	1 5/8	41	2 5/16	51	1 1/2	38	2	0.9
1 1/4	32	2	51	4 1/2	114	2	51	3	1.4
1 1/2	40	2 1/4	57	4 7/8	124	2 1/16	52	4	1.8
2	50	2 3/4	70	5 9/16	141	2 1/2	64	6	2.7

FLOW CHARACTERISTICS

MODEL 35XL 1/4" & 1/2"(STANDARD & METRIC)




MODEL 35XL 3/4", 1", 1 1/4" 1 1/2" & 2"(STANDARD & METRIC)




TYPICAL INSTALLATION

Local codes shall govern installation requirements. To be installed in accordance with the manufacturer's instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the assembly shall be mounted at a minimum of 6" (150mm) above the highest point of discharge with sufficient side clearance for maintenance. Because the Model 35 is not to be used under continuous pressure never place a shut-off or check valve downstream of the device. The installation shall be made so that no part of the unit can be submerged.



MODEL 35XL INSTALLATION



MODEL 35XL INSTALLATION

SPECIFICATIONS

The Atmospheric Vacuum Breaker shall be ANSI 3rd party certified to comply with states' lead plumbing law 0.25% maximum weighted average lead content requirement, ASSE® Listed 1001. The main body shall be low lead brass (1/4"-2"). All internal polymers shall be NSF® Listed ULTEM™ or Polypropylene and the seat disc elastomers shall be Silicone. The device shall be accessible for maintenance without removing the device from the service line. The installation shall not be in a concealed or inaccessible location, or where the venting of water from the device, during normal functioning, may be deemed objectionable. The Atmospheric Vacuum Breaker shall be a WILKINS Model 35XL or Model 35XLVCH.

WILKINS a Zurn company, 1747 Commerce Way, Paso Robles, CA 93446 Phone: 805-238-7100 Fax: 805-238-5766

In Canada: ZURN INDUSTRIES LIMITED, 3544 Nashua Dr., Mississauga, Ontario L4V 1L2 Phone: 905-405-8272 Fax: 905-405-1292

Product Support Help Line: 877-BACKFLOW (877-222-5356) • Website: <http://www.zurn.com>