



MIDWAY ISD
INDEPENDENT SCHOOL DISTRICT
Randel Beaver Superintendent

PUBLIC NOTICE

Midway ISD/Public Water System #0390020 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during the month of January 2017. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

The required triggered source samples have been submitted each month since then and the water system has proved to be free of any coliform contamination.

If you have any questions regarding this violation, you may contact Randel Beaver, Superintendent of Midway ISD. The phone number is listed above.