

Water Testing Results**BUTLER CREEK****Action Level is 0.015 mg/L**

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Left kitchen sink faucet	21850601-001KF	1/28/2017	0.0014
Right kitchen sink faucet	21850601-002KF	1/28/2017	0.0013
kitchen Hand Washing Sink	21850601-003SF	1/28/2017	0.002
Cafeteria Water Cooler	21850601-004WC	1/28/2017	None Detected
Drinking Fountain near room #403	21850601-005DF	1/28/2017	0.0003
Sink Faucet near room #403	21850601-006CF	1/28/2017	0.0016
Sink in Computer Lab	21850601-007SF	1/28/2017	0.0002
Sink Faucet near room #405	21850601-008CF	1/28/2017	0.0014
Drinking Fountain near room #405	21850601-009DF	1/28/2017	0.0005
Sink Faucet In 400 Hall Right side Staff Restroom	21850601-010BF	1/28/2017	0.0017
Sink Faucet in 400 Hall Left side Staff Restroom	21850601-011BF	1/28/2017	0.0053
Sink Faucet near room #406	21850601-012Cf	1/28/2017	0.0009
Drinking Fountain near room #406	21850601-013DW	1/28/2017	0.0003
Drinking Fountain near Room #404	21850601-014DW	1/28/2017	0.0014
Sink Faucet near room #404	21850601-015CF	1/28/2017	0.0017
Library Sink Faucet	21850601-016SF	1/28/2017	0.003
Sink Faucet near room #304	21850601-017CF	1/28/2017	0.0011
Drinking Fountain near room #304	21850601-018DW	1/28/2017	0.0002
Sink Faucet near room #306	21850601-019CF	1/28/2017	0.0013
Drinking Fountain near room #306	21850601-020DW	1/28/2017	0.0004
Sink Faucet in 300 Hall Right side Staff Restroom	21850601-020BF	1/28/2017	0.0069
Sink Faucet in 300 Hall Left side Staff Restroom	21850601-021BF	1/28/2017	0.0024
Sink Faucet near room #305	21850601-022CF	1/28/2017	0.0012
Drinking Fountain near room #305	21850601-023DW	1/28/2017	0.0002
Sink Faucet near room #303	21850601-024CF	1/28/2017	0.0027
Drinking Fountain near room #303	21850601-025DW	1/28/2017	0.0004
Staff Room Kitchen Sink Faucet	21850601-026KF	1/28/2017	0.0025
Staff room Restroom Women's Sink Faucet	21850601-027BF	1/28/2017	0.0011

Staff room Restroom Men's Sink Faucet	21850601-028BF	1/28/2017	0.0007
Sink Faucet in Family Center	21850601-029SF	1/28/2017	0.0008
Drinking Fountain by room #204	21850601-030DW	1/28/2017	0.0004
Sink Faucet by room #204	21850601-031CF	1/28/2017	0.0024
Drinking Fountain by room #206	21850601-032DW	1/28/2017	0.0003
Sink Faucet by room #206	21850601-033CF	1/28/2017	0.0004
Sink Faucet in 200 Hall Right side Staff Restroom	21850601-034BF	1/28/2017	0.004
Sink Faucet in 200 Hall Left side Staff Restroom	21850601-035BF	1/28/2017	0.0031
Sink Faucet by room #205	21850601-036CF	1/28/2017	0.0017
Drinking Fountain by room #205	21850601-037DW	1/28/2017	0.0005
Sink Faucet by room #203	21850601-038Cf	1/28/2017	0.0005
Drinking Fountain by room #203	21850601-039DW	1/28/2017	0.0005
Sink Faucet in Room #203	21850601-040CF	1/28/2017	0.0025
Drinking Fountain in room #203	21850601-041DW	1/28/2017	0.0011
Sink Faucet in room # 205	21850601-042CF	1/28/2017	0.0008
Drinking Fountain in room #205	21850601-043DW	1/28/2017	0.0009
Office Sink Faucet by Copier	21850601-044SF	1/28/2017	0.0015
Nurses office Sink Faucet	21850601-044SF	1/28/2017	0.0016
Main Office restroom Sink Faucet	21850601-045BF	1/28/2017	0.0006
Unisex restroom Sink Faucet by Main Office	21850601-046BF	1/28/2017	0.002
Drinking Fountain by Gym Right Side	21850601-047DW	1/28/2017	None Detected
Drinking Fountain by Gym Left Side	21850601-048DF	1/28/2017	0.0002
Restroom Sink Faucet in room #301	21850601-049BF	1/28/2017	0.0009

ND = Non Detect - Lead level is below the set detection of X ppb