

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, Average/1,1-DICHLOROETHYLENE**

The Texas Commission on Environmental Quality (TCEQ) has notified the **City of Idalou TX1520001** the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for 1,1-DICHLOROETHYLENE. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for 1,1-DICHLOROETHYLENE to be 0.007 milligrams per liter (mg/L) based on a running annual average (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for 1,1-DICHLOROETHYLENE indicates a compliance value in **quarter four 2019 of 0.014 mg/L for EP001.**

Some people who drink water containing 1,1-DICHLOROETHYLENE in excess of the maximum contaminant level (MCL) over many years could experience problems with their liver.

We are taking the following actions to address this issue:

The City of Idalou has increased aeration at the well to lower the levels. The city is also increasing the time that the water remains in the storage tank to allow for additional aeration.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Contact Information:

**Suzette Williams
City Administrator
City of Idalou
Ph: 892-2531
Fax: 892-3298**